

# **Cogeneration Facility 2010 Annual Air Emissions Inventory**

**The University of North Carolina at Chapel Hill  
Chapel Hill, North Carolina**

**Facility ID # 6800043  
Permit # 03069T28**

*Prepared for:*

**The University of North Carolina at Chapel Hill**  
Department of Environment, Health, and Safety  
1120 Estes Drive Extension  
Chapel Hill, North Carolina 27599-1650

*Prepared by:*

**RST Engineering**  
5416 Orchard Oriole Trail  
Wake Forest, North Carolina 27587-6770

**June 2011**

# **Cogeneration Facility 2010 Annual Air Emissions Inventory**

**The University of North Carolina at Chapel Hill  
Chapel Hill, North Carolina**

Facility ID # 6800043

Permit # 03069T28

*Prepared for:*

**The University of North Carolina at Chapel Hill**

Department of Environment, Health, and Safety

1120 Estes Drive Extension

Chapel Hill, North Carolina 27599-1650

*Prepared by:*

**RST Engineering**

5416 Orchard Oriole Trail

Wake Forest, North Carolina 27587-6770

**June 2011**

# The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Table of Contents

#### Supporting Documentation

Cogeneration Facility Boiler Fuel Usage

Cogeneration Facility Boiler Coal Usage

Blackstart Generator Fuel Usage

#### Emissions Calculations

<u>ES ID</u>	<u>Source/Operating Scenario Description</u>
ES-007-ES-008	Two Blackstart Generators at the Cogeneration Facility
ES-010	Enclosed Railcar Dump Pits
ES-1, ES-2	Coal Storage Silos
ES-3.1 - ES-3.5	Silo Conveyors
T-001	Fuel Oil Storage Tank
T-002	Fuel Oil Storage Tank
ES-001	Boiler #6 <ul style="list-style-type: none"><li>- No. 2 Fuel Oil Firing</li><li>- Wood Pellet Firing</li><li>- Coal Firing</li><li>- Natural Gas Firing</li><li>- No. 6 Fuel Oil Firing</li></ul>
ES-002	Boiler #7 <ul style="list-style-type: none"><li>- Wood Pellet Firing</li><li>- No. 2 Fuel Oil Firing</li><li>- Coal Firing</li><li>- Natural Gas Firing</li><li>- No. 6 Fuel Oil Firing</li></ul>
ES-003	Boiler #8 <ul style="list-style-type: none"><li>- Natural Gas Firing</li><li>- No. 2 Fuel Oil Firing</li></ul>
ES-010A	Coal Crusher/Conveyor Building
ES-030	Ash Silo with Loadout
ES-030A	Wet Ash Loadout
IS-53	Enclosed Sorbent Railcar Dump Pit

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Cogeneration Boilers

#### Seasonal Fuel Usage Breakdown

Month	Boiler #6				Boiler #7				Boiler #8	
	Coal (tons)	Wood(tons)	Gas (1,000cf)	Oil (gallons)	Coal (tons)	Wood(tons)	Gas (1,000cf)	Oil (gallons)	Gas (1,000cf)	Oil (gallons)
December 2010	7,449	0	0	27	6,003	0	42	32	4,188	19,433
January 2010	6,019	0	0	23	5,515	0	1,220	59,140	481	99,345
February 2010	5,475	0	802	0	6,137	0	593	0	6,455	0
<i>1st Quarter Total</i>	<i>18,942</i>	<i>0</i>	<i>802</i>	<i>50</i>	<i>17,656</i>	<i>0</i>	<i>1,855</i>	<i>59,172</i>	<i>11,124</i>	<i>118,778</i>
March 2010	4,865	0	640	0	2,468	0	850	0	10,130	0
April 2010	4,128	0	30	0	211	0	910	0	20	0
May 2010	4,088	0	0	0	3,106	0	1,060	0	800	0
<i>2nd Quarter Total</i>	<i>13,081</i>	<i>0</i>	<i>670</i>	<i>0</i>	<i>5,785</i>	<i>0</i>	<i>2,820</i>	<i>0</i>	<i>10,950</i>	<i>0</i>
June 2010	5,488	0	20	0	2,242	0	492	0	1,809	0
July 2010	6,249	0	0	0	4,199	0	70	0	340	0
August 2010	5,904	0	10	0	3,440	0	140	0	1,470	0
<i>3rd Quarter Total</i>	<i>17,641</i>	<i>0</i>	<i>30</i>	<i>0</i>	<i>9,882</i>	<i>0</i>	<i>702</i>	<i>0</i>	<i>3,619</i>	<i>0</i>
September 2010	1,890	16	515	0	4,839	0	7,663	0	2,233	0
October 2010	3,261	0	1,918	0	4,303	0	590	0	5,262	0
November 2010	4,021	0	3,488	0	3,488	0	30,146	0	23,787	0
<i>4th Quarter Total</i>	<i>9,172</i>	<i>16</i>	<i>5,921</i>	<i>0</i>	<i>12,629</i>	<i>0</i>	<i>38,400</i>	<i>0</i>	<i>31,282</i>	<i>0</i>
<b>2010 TOTAL</b>	<b>58,836</b>	<b>16</b>	<b>7,423</b>	<b>50</b>	<b>45,952</b>	<b>0</b>	<b>43,777</b>	<b>59,172</b>	<b>56,975</b>	<b>118,778</b>

#### Seasonal Btu Breakdown

Coal (btu/lb)	12,598	Wood (btu/lb)	8,000	Natural Gas (btu/ft <sup>3</sup> )	1,030	Fuel Oil (btu/gal)	139,144
---------------	--------	---------------	-------	------------------------------------	-------	--------------------	---------

Month	Boiler #6				Boiler #7				Boiler #8	
	Coal	Wood	Gas	Oil	Coal	Wood	Gas	Oil	Gas	Oil
December 2010	1.88E+11	0.00E+00	0.00E+00	3.78E+06	1.51E+11	0.00E+00	4.33E+07	4.49E+06	4.31E+09	2.70E+09
January 2010	1.52E+11	0.00E+00	0.00E+00	3.23E+06	1.39E+11	0.00E+00	1.26E+09	8.23E+09	4.95E+08	1.38E+10
February 2010	1.38E+11	0.00E+00	8.26E+08	0.00E+00	1.55E+11	0.00E+00	6.11E+08	0.00E+00	6.65E+09	0.00E+00
<i>1st Quarter Total</i>	<i>4.77E+11</i>	<i>0.00E+00</i>	<i>8.26E+08</i>	<i>7.01E+06</i>	<i>4.45E+11</i>	<i>0.00E+00</i>	<i>1.91E+09</i>	<i>8.23E+09</i>	<i>1.15E+10</i>	<i>1.65E+10</i>
March 2010	1.23E+11	0.00E+00	6.59E+08	0.00E+00	6.22E+10	0.00E+00	8.76E+08	0.00E+00	1.04E+10	0.00E+00
April 2010	1.04E+11	0.00E+00	3.09E+07	0.00E+00	5.33E+09	0.00E+00	9.37E+08	0.00E+00	2.06E+07	0.00E+00
May 2010	1.03E+11	0.00E+00	2.06E+05	0.00E+00	7.83E+10	0.00E+00	1.09E+09	0.00E+00	8.24E+08	0.00E+00
<i>2nd Quarter Total</i>	<i>3.30E+11</i>	<i>0.00E+00</i>	<i>6.90E+08</i>	<i>0.00E+00</i>	<i>1.46E+11</i>	<i>0.00E+00</i>	<i>2.90E+09</i>	<i>0.00E+00</i>	<i>1.13E+10</i>	<i>0.00E+00</i>
June 2010	1.38E+11	0.00E+00	2.06E+07	0.00E+00	5.65E+10	0.00E+00	5.07E+08	0.00E+00	1.86E+09	0.00E+00
July 2010	1.57E+11	0.00E+00	0.00E+00	0.00E+00	1.06E+11	0.00E+00	7.21E+07	0.00E+00	3.50E+08	0.00E+00
August 2010	1.49E+11	0.00E+00	1.03E+07	0.00E+00	8.67E+10	0.00E+00	1.44E+08	0.00E+00	1.51E+09	0.00E+00
<i>3rd Quarter Total</i>	<i>4.44E+11</i>	<i>0.00E+00</i>	<i>3.09E+07</i>	<i>0.00E+00</i>	<i>2.49E+11</i>	<i>0.00E+00</i>	<i>7.23E+08</i>	<i>0.00E+00</i>	<i>3.73E+09</i>	<i>0.00E+00</i>
September 2010	4.76E+10	2.54E+08	5.30E+08	0.00E+00	1.22E+11	0.00E+00	7.89E+09	0.00E+00	2.30E+09	0.00E+00
October 2010	8.22E+10	0.00E+00	1.98E+09	0.00E+00	1.08E+11	0.00E+00	6.08E+08	0.00E+00	5.42E+09	0.00E+00
November 2010	1.01E+11	0.00E+00	3.59E+09	0.00E+00	8.79E+10	0.00E+00	3.11E+10	0.00E+00	2.45E+10	0.00E+00
<i>4th Quarter Total</i>	<i>2.31E+11</i>	<i>2.54E+08</i>	<i>6.10E+09</i>	<i>0.00E+00</i>	<i>3.18E+11</i>	<i>0.00E+00</i>	<i>3.96E+10</i>	<i>0.00E+00</i>	<i>3.22E+10</i>	<i>0.00E+00</i>
<b>2010 TOTAL</b>	<b>1.48E+12</b>	<b>2.54E+08</b>	<b>7.65E+09</b>	<b>7.01E+06</b>	<b>1.16E+12</b>	<b>0.00E+00</b>	<b>4.51E+10</b>	<b>8.23E+09</b>	<b>5.87E+10</b>	<b>1.65E+10</b>

#### Seasonal Total Fuel Usage (%)

	Boiler #6	Boiler #7	Boiler #8
Dec., Jan., Feb.	32.08	37.57	37.21
Mar., Apr., May	22.16	12.27	15
June, July, Aug.	29.83	20.62	4.96
Sept., Oct., Nov.	15.93	29.54	42.84
	100	100	100

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Coal Usage Breakdown

Month	Boiler #6 Coal (tons)	Boiler #7 Coal (tons)
December 2010	7,449	6,003
January 2010	6,019	5,515
February 2010	5,475	6,137
<i>1st Quarter Total</i>	<b>18,942</b>	<b>17,656</b>
March 2010	4,865	2,468
April 2010	4,128	211
May 2010	4,088	3,106
<i>2nd Quarter Total</i>	<b>13,081</b>	<b>5,785</b>
June 2010	5,488	2,242
July 2010	6,249	4,199
August 2010	5,904	3,440
<i>3rd Quarter Total</i>	<b>17,641</b>	<b>9,882</b>
September 2010	1,890	4,839
October 2010	3,261	4,303
November 2010	4,021	3,488
<i>4th Quarter Total</i>	<b>9,172</b>	<b>12,629</b>
<b>2010 TOTAL</b>	<b>58,836</b>	<b>45,952</b>

**Facility-Wide Coal Usage                      104,788                      Tons/year**

### Seasonal Coal Usage (%)

	Boiler #6	Boiler #7	Average (%)
<b>Dec., Jan., Feb.</b>	32.19%	38.42%	35.31%
<b>Mar., Apr., May</b>	22.23%	12.59%	17.41%
<b>June, July, Aug.</b>	29.98%	21.51%	25.74%
<b>Sept., Oct., Nov.</b>	15.59%	27.48%	21.54%
	100%	100%	100%

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Blackstart Generator Fuel Usage Breakdown

Month	DG1 & DG2 #2 Oil (gallons)
December 2010	885
January 2010	1380
February 2010	274
<i>1st Quarter Total</i>	<b>2,539</b>
March 2010	0
April 2010	113
May 2010	218
<i>2nd Quarter Total</i>	<b>331</b>
June 2010	6,207
July 2010	19,510
August 2010	14,566
<i>3rd Quarter Total</i>	<b>40,282</b>
September 2010	2,552
October 2010	622
November 2010	741
<i>4th Quarter Total</i>	<b>3,914</b>
<b>2010 TOTAL</b>	<b>47,065</b>

### Seasonal Oil Usage (%)

	DG1 & DG2
<b>Dec., Jan., Feb.</b>	5.39%
<b>Mar., Apr., May</b>	0.70%
<b>June, July, Aug.</b>	85.59%
<b>Sept., Oct., Nov.</b>	8.32%
	100%

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**DG No.1 and No.2 - Two 2,000 kW Generators  
Cogeneration Facility**

**(ES-007 & ES-008)**

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2		Facility ID #: <b>6800043</b>					
<i>Emergency Generators Classified as Insignificant Sources</i>		Permit #: <b>03069T28</b>					
Facility Name: <u>University of North Carolina at Chapel Hill</u>		County: <b>Orange</b>					
		DAQ Region: <b>Raleigh</b>					
<b>North Carolina Department of Environment and Natural Resources</b> <b>Division of Air Quality</b> <b>Air Pollutant Point Source Emissions Inventory - Calendar Year 2010</b>							
1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-007 & ES-008					
2. Emission Source Description		Two Blackstart Generators located at Cogeneration Facility					
3. Operating Scenario Description		Operating Scenario #1 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		270 gal/hr - 2 units					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		47,065					
		gallons/year, Total No. 2 Fuel Oil					
6. Fuel Information (if fuel used)		% Sulfur	0.1%				
		% Ash	N/A				
		Heat Content (Btu/lb or mmCF)	139,144 Btu/gallon				
If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.							
7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)		N/A					
8. Control Device Information, if none, write "none"							
	Control Device ID # (as listed in permit)	Control Device Description					
i. (nearest stack)	None	None					
ii.	None	None					
iii.	None	None					
iv.	None	None					
9. Stack Information (sources vented to more than one stack use additional entry lines)							
Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)	
<b>Common Stack Parameters with 2-generators and Boiler No. 8 operating concurrently</b>							
Stk No.4	208	6	400	70	118,752	Vertical	
--	--	--	--	--	--	--	
10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	N/A	Days/Week	N/A	Weeks/Year	N/A	Hours/Year	N/A
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2007 + Dec, 2007	5.4%	Mar-May	0.7%	June-Aug	85.6%	Sept-Nov	8.3%



Two-2,000 kW No.2 oil-fired generators

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-007 & ES-008

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.83	8	N/A
NOx	NOx	6.22	8	N/A
PM Total	PM	0.33	8	N/A
PM-2.5	PM-2.5	0.33	8	N/A
PM-10	PM-10	0.33	8	N/A
SO2	SO2	0.33	8	N/A
VOC	VOC	0.27	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	75-07-0	0.17	8	N/A
Acrolein	107-02-8	0.05	8	N/A
Benzene	71-43-2	5.08	8	N/A
Formaldehyde	50-00-0	0.52	8	N/A
Napthalene	91-20-3	0.85	8	N/A
Propylene	115-07-1	18.27	8	N/A
Toluene	108-88-3	1.84	8	N/A
Xylene	1330-20-7	1.26	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	533.90	8	N/A
Methane	CH <sub>4</sub>	2.17E-02	8	N/A
Nitrous Oxide	N <sub>2</sub> O	4.33E-03	8	N/A

**University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

2010 Annual Emissions Inventory

**Blackstart Generators G1 & G2**

(ES-007 & ES-008)

<b>Fuel Input Rates</b>	
Hourly Fuel Usage (gallons):	270 (2-units)
Annual Fuel Usage (gallons):	47,065 (2-units)
Fuel Sulfur Content (%)	0.1
<b>Heat Input Rates</b>	
Fuel Heating Values (Btu/gallon)	139,144
Hourly Fuel Usage (mmBtu):	37.57
Annual Fuel Usage (mmBtu):	6,549

70.00% CO control\*  
\*Cat. Oxydizer

<b>Emissions Output</b>				Emission Factor (lb/mmBtu)
<b>Criteria Pollutants</b>				
Pollutant	lb/hr	lb/yr	tpy	
PM	3.8E+00	6.5E+02	3.3E-01	1.00E-01
PM-10	3.8E+00	6.5E+02	3.3E-01	1.00E-01
PM-2.5	3.8E+00	6.5E+02	3.3E-01	1.00E-01
NOx	7.1E+01	1.2E+04	6.2E+00	1.90E+00
NMTOC, Total	3.1E+00	5.4E+02	2.7E-01	8.19E-02
CO	9.6E+00	1.7E+03	8.3E-01	2.55E-01
SO <sub>x</sub>	3.8E+00	6.6E+02	3.3E-01	1.01E-01
<b>Toxic/Hazardous Air Pollutants</b>				
Pollutant	lb/hr	lb/day	lb/yr	
Acetaldehyde	9.5E-04	NA	1.7E-01	2.52E-05
Acrolein	3.0E-04	NA	5.2E-02	7.88E-06
Benzene	2.9E-02	NA	5.1E+00	7.76E-04
Formaldehyde	3.0E-03	NA	5.2E-01	7.89E-05
Naphthalene	4.9E-03	NA	8.5E-01	1.30E-04
Propylene	1.0E-01	NA	1.8E+01	2.79E-03
Toluene	1.1E-02	2.5E-01	1.8E+00	2.81E-04
Xylene	7.3E-03	1.7E-01	1.3E+00	1.93E-04
<b>Greenhouse Gas Pollutants</b>				Em. Factor (lb/mmBtu)
Pollutant	lb/hr	lb/yr	tpy	
Carbon dioxide	6,126	1,067,807	533.90	163
Methane	2.5E-01	4.3E+01	2.2E-02	6.61E-03
Nitrous Oxide	5.0E-02	8.7E+00	4.3E-03	1.32E-03

Emission factors are from AP-42 Chapter 3, Section 3.4, Large Stationary Diesel Engines, dated October 1996.

Hourly emission rates for all pollutants are based on the hourly engine output. Annual emissions are based on the annual engine output.

Daily emissions are based on operation at the hourly input rate for 24 hours.

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**Three Enclosed Railcar Dump Pits  
(ES-010)**

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2	<b>Facility ID #:</b> 6800043
<b>Railcar Dump Pits</b>	<b>Permit #:</b> 03069T28
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	<b>County:</b> Orange
<b>Facility Name:</b> University of North Carolina at Chapel Hill	<b>DAQ Region:</b> Raleigh

**North Carolina Department of Environment and Natural Resources**  
**Division of Air Quality**  
**Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-010</b>
<b>2. Emission Source Description</b>	<b>Three Enclosed Railcar Dump Pits</b>	
<b>3. Operating Scenario Description</b>	N/A	
<b>4. Maximum Permitted Operating Rate</b> With Units (Ex. gal/hr, mmBtu/hr)	<b>350 tons/hr</b>	
<b>5. Throughput in CY</b> (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)	<b>103,555</b>	<b>tons/yr</b>
<b>6. Fuel Information</b> (if fuel used)	% Sulfur	N/A
	% Ash	N/A
	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)	<b>N/A</b>
---	------------

**8. Control Device Information**, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
<i>i. (nearest stack)</i>	N/A	<b>Enclosed Dump Pits</b>
<i>ii.</i>	<b>CD-018</b>	<b>Wet Spray Dust Suppression System</b>
<i>iii.</i>	N/A	N/A
<i>iv.</i>	N/A	N/A

**9. Stack Information** (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature  (F)	Velocity  (feet/sec)	Volume Flow Rate  (acfm)	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
<b>Fugitive</b>						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

**10. Operating Schedule** (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	<b>1.5</b>	Days/Week	<b>5</b>	Weeks/Year	<b>52</b>	Hours/Year	<b>390</b>
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

**11. Seasonal Periods Percent Annual Throughput** (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------

*Railcar Dump Pits*

If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

**Emission Source ID No.** (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-010

<b>Criteria (NAAQS) Pollutants</b>	<b>Pollutant Code</b>	<b>Emissions Criteria (Tons/Year)</b>	<b>Emissions Estimation Method Code (see instructions for code)</b>	<b>Control Efficiency (Net after all controls)</b>
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	<b>6.84E-03</b>	2	<b>67%</b>
PM-2.5	PM-2.5	<b>1.02E-03</b>	2	<b>40%</b>
PM-10	PM-10	<b>3.23E-03</b>	2	<b>63%</b>
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
<b>HAP/TAP Pollutants (In Alphabetical Order)</b>	<b>CAS # (or other code - see instructions)</b>	<b>Emissions HAP/TAP (Pounds/Year)</b>	<b>Emissions Estimation Method Code (see instructions for code)</b>	<b>Control Efficiency (Net after all controls)</b>

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Fugitive Losses from the unloading of coal from railcars into a dump pit.

(ES-010)

Actual tonnage of coal received in 2010 is less than total burned in boilers.

Boiler #6		Tons/yr
Boiler #7		Tons/yr
Total	103,555	Tons/yr

From section 13.2.4 of the AP-42, coal handling is well approximated by aggregate handling operations. The following equation represents the particulate emissions generated by the dropping of coal into the dump pit.

$$E = k (0.0032) \frac{(u/5)^{1.3}}{(m/2)^{1.4}}$$

E = Emission Factor (lb/ton)

k = Particle Size Multiplier

u = Mean Wind Speed (mph)

m = Material Moisture Content (%)

k Value	Particulate Size	Emission Factor (lb/ton)
0.74	PM	1.32E-04
0.35	PM-10	6.25E-05
0.11	PM-2.5	1.96E-05

Average moisture content of coal is 4.5%

The dump area is fully enclosed, therefore the minimum wind speed of 1.3 mph was used.

**Total Coal            103,555 tons/yr**

*Emissions from the unloading of coal:*

	Emission Factor (lb/ton)	Emissions (lb/yr)	Emissions (ton/yr)
PM	1.32E-04	13.68	6.84E-03
PM-10	6.25E-05	6.47	3.23E-03
PM-2.5	1.96E-05	2.03	1.02E-03

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

**Coal Silos  
(ES-1, ES-2)**

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2	Facility ID #: <b>6800043</b>
<i>Coal Silos</i>	Permit #: <b>03069T28</b>
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	County: <b>Orange</b>
Facility Name: <u>University of North Carolina at Chapel Hill</u>	DAQ Region: <b>Raleigh</b>

**North Carolina Department of Environment and Natural Resources**  
**Division of Air Quality**  
**Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-1 and ES-2</b>					
2. Emission Source Description		<b>Two Coal Storage Silos</b>					
3. Operating Scenario Description		<b>N/A</b>					
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		<b>350 tons/hr</b>					
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>		<b>103,555</b>				<b>tons/yr</b>	
6. Fuel Information (if fuel used)	% Sulfur	<b>N/A</b>	% Ash	<b>N/A</b>	Heat Content (Btu/lb or mmCF)	<b>N/A</b>	

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	<b>100%</b>
--	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
i. (nearest stack)	<b>CD-011</b>	<b>Bagfilter Installed on Silo ES-1</b>
ii.	<b>CD-012</b>	<b>Bagfilter Installed on Silo ES-2</b>
iii.	<b>N/A</b>	<b>N/A</b>
iv.	<b>N/A</b>	<b>N/A</b>

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) <small>(in 0.1 feet)</small></small>	Temperature  <small>(F)</small>	Velocity  <small>(feet/sec)</small>	Volume Flow Rate  <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
<b>EP-12-028</b>	<b>140</b>	<b>0.9</b>	<b>Ambient</b>	<b>61</b>	<b>2,500</b>	<b>Horizontal</b>
<b>EP-12-036</b>	<b>140</b>	<b>0.9</b>	<b>Ambient</b>	<b>61</b>	<b>2,500</b>	<b>Horizontal</b>
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	<b>1.5</b>	Days/Week	<b>5</b>	Weeks/Year	<b>52</b>	Hours/Year	<b>390</b>
Typical Start & End Times in CY:				Start:	<b>N/A</b>	End:	<b>N/A</b>

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------



*Coal Silos*

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-1 and ES-2

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	<b>4.72E-03</b>	<b>2</b>	<b>99.80%</b>
PM-2.5	PM-2.5	<b>4.49E-03</b>	<b>2</b>	<b>97.90%</b>
PM-10	PM-10	<b>4.72E-03</b>	<b>2</b>	<b>99.60%</b>
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Emissions from the loading of 2 coal storage silos.

(ES-1, ES-2)

Actual tonnage of coal received in 2010 is less than total burned in boilers.

Boiler #6		Tons/yr
Boiler #7		Tons/yr
Total	103,555	Tons/yr

The bulk density of coal is 47 lb/ft<sup>3</sup>

Total volume of coal combusted is = 4,406,596 ft<sup>3</sup>/yr  
(Volume of coal combusted = volume of displaced air through bin filter)

These emissions are routed through bin filters (baghouses). Emissions from the bin filters are conservatively estimated at 0.015 gr/acfm (displaced air through bin filters).

$$\text{lb/yr} = (\text{volume of coal, ft}^3/\text{yr}) (0.015 \text{ gr/acf}) (1/7000 \text{ lb/gr})$$

<b>Total Emissions from the silos</b>	<b>66,099</b>	<b>gr/yr</b>
	<b>9.443</b>	<b>lb/yr</b>
	<b>0.0047</b>	<b>ton/yr</b>

100% of these emissions are PM-10

95% of these emissions are PM-2.5

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**Silo Feed Conveyors  
(ES-3)**

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2		<b>Facility ID #:</b> 6800043							
<b>Silo Feed Conveyors</b>		<b>Permit #:</b> 03069T28							
<small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>									
<b>Facility Name:</b> University of North Carolina at Chapel Hill		<b>County:</b> Orange							
		<b>DAQ Region:</b> Raleigh							
<b>North Carolina Department of Environment and Natural Resources</b>									
<b>Division of Air Quality</b>									
<b>Air Pollutant Point Source Emissions Inventory - Calendar Year 2010</b>									
<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)			<b>ES-3</b>						
<b>2. Emission Source Description</b>		<b>Silo Feed Conveyors</b>							
<b>3. Operating Scenario Description</b>		<b>N/A</b>							
<b>4. Maximum Permitted Operating Rate</b> <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		<b>700 tons/hr</b>							
<b>5. Throughput in CY</b> (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>		<b>103,555 tons/yr</b>							
<b>6. Fuel Information</b> (if fuel used)		<b>% Sulfur</b> N/A	<b>% Ash</b> N/A						
		<b>Heat Content</b> (Btu/lb or mmCF)	N/A						
<small>If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.</small>									
<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)			<b>100%</b>						
<b>8. Control Device Information</b> , if none, write "none"									
	<b>Control Device ID #</b> <small>(as listed in permit)</small>	<b>Control Device Description</b>							
<i>i. (nearest stack)</i>	<b>CD-019</b>	<b>Bagfilter</b>							
<i>ii.</i>	N/A	N/A							
<i>iii.</i>	N/A	N/A							
<i>iv.</i>	N/A	N/A							
<b>9. Stack Information</b> (sources vented to more than one stack use additional entry lines)									
<b>Stack ID #</b>	<b>Height</b> <small>(in whole feet)</small>	<b>Diameter (feet)</b> <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	<b>Temperature</b>  (F)	<b>Velocity</b>  (feet/sec)	<b>Volume Flow Rate</b>  (acfm)	<b>Release Point Description</b> <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>			
EP-12-6901	200	2	Ambient	45	8,500	Vertical			
--	--	--	--	--	--	--			
--	--	--	--	--	--	--			
<b>10. Operating Schedule</b> (Source/Operating Scenario that best characterizes calendar year)									
Hours/Day	N/A		Days/Week	N/A		Weeks/Year	N/A		
Typical Start & End Times in CY:				Start:	N/A		End:	N/A	
<b>11. Seasonal Periods Percent Annual Throughput</b> (for Emission Source in CY, MUST total 100%)									
Jan-Feb, 2002 + Dec, 2002		<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>	

Silo Feed Conveyors

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-03

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	4.72E-03	2	99.80%
PM-2.5	PM-2.5	4.49E-03	2	97.90%
PM-10	PM-10	4.72E-03	2	99.60%
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Emissions from silo feed conveyors.

(ES-3)

Actual tonnage of coal received in 2010 is less than total burned in boilers.

Boiler #6		Tons/yr
Boiler #7		Tons/yr
Total	103,555	Tons/yr

The bulk density of coal is 47 lb/ft<sup>3</sup>

Total volume of coal combusted is = 4,406,596 ft<sup>3</sup>/yr  
(Volume of coal combusted = volume of displaced air through bin filter)

These emissions are routed through bin filters (baghouses). Emissions from the bin filters are conservatively estimated at 0.015 gr/acfm (displaced air through bin filters).

$$\text{lb/yr} = (\text{volume of coal, ft}^3/\text{yr}) (0.015 \text{ gr/acf}) (1/7000 \text{ lb/gr})$$

<b>Total Emissions from the conveyors</b>	<b>66,099</b>	<b>gr/yr</b>
	<b>9.443</b>	<b>lb/yr</b>
	<b>0.0047</b>	<b>ton/yr</b>

100% of these emissions are PM-10

95% of these emissions are PM-2.5

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

### **Fuel Oil Storage Tanks**

**(T-001 and T-002)**

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## *2010 Annual Emissions Inventory*

### **Summary of Emissions from Tanks T-001 & T-002** **(ES-T-001 and ES-T-002)**

VOC Emissions calculated with EPA TANKS 4.0 Program

T-001	226.06	lb/yr	0.113	Tons/yr
T-002	226.06	lb/yr	0.113	Tons/yr
Total	452.12	lb/yr	0.226	Tons/yr



# The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### **Boiler #6 (ES-001-Boiler #6)**

#### Operating Scenarios

#1 - Coal Firing

#2 - Natural Gas Firing

#4 - No.2 Fuel Oil Firing

#5 - Wood Pellet Firing

(#3 - No.6 Fuel Oil Firing is no longer permitted)

Boilers #6 and #7 are equipped with Continuous Emission Monitoring (CEMs) devices to measure SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> emissions from each of the boilers. The monthly averages presented in the attached spreadsheets are for the total emissions from firing all types of fuel. The 2010 Annual Emission Inventory forms require that the emissions be divided among the three possible operating scenarios.

NO<sub>x</sub> and CO<sub>2</sub> emissions have been divided between the four operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

SO<sub>2</sub> emissions from natural gas and wood pellet combustion are insignificant, therefore, SO<sub>2</sub> emissions have been divided between the fuel oil and coal operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

#### *Emissions Calculations*

SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> Emissions are taken from CEMs data  
Other emission factors are from stack test or DAQ spreadsheets

**Boiler #6 - Operating Scenario #4 - No. 2 Fuel Oil**

If Emission Source has multiple Operating Scenarios, complete one form for each.

(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #4 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		50		gallons/yr			
6. Fuel Information (if fuel used)		% Sulfur	0.1%	% Ash		Heat Content (Btu/lb or mmCF)	139,144 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

## 8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

## 9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

## 10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8,057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

## 11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	100.00%	Mar-May	0.00%	June-Aug	0.00%	Sept-Nov	0.00%
------------------------------	---------	---------	-------	----------	-------	----------	-------

## Boiler #6 - Operating Scenario #4 - No. 2 Fuel Oil

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	1.26E-04	8	N/A
NOx	NOx	1.18E-03	1	N/A
PM Total	PM	3.33E-05	8	99.0%
PM-2.5	PM-2.5	8.32E-06	8	99.0%
PM-10	PM-10	3.33E-05	8	99.0%
SO2	SO2	6.11E-04	1	90.0%
VOC	VOC	5.04E-06	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Antimony	ANTIMONYPDS	0.00E+00	8	99.0%
Arsenic	ARSENICPDS	2.82E-07	8	99.0%
Benzene	71-43-2	1.39E-04	8	N/A
Beryllium	BERYLCPDS	2.12E-07	8	99.0%
Cadmium	CADMIUMCPDS	2.12E-07	8	99.0%
Chromium	CROMCPDS	2.12E-07	8	99.0%
Chromium VI	CHROM6CPDS	6.21E-08	8	99.0%
Cobalt	COBALTCPDS	0.00E+00	8	99.0%
Ethylbenzene	100-41-4	4.12E-05	8	N/A
Fluoride	16984-48-8	0.00	8	N/A
Formaldehyde	50-00-0	0.00	8	N/A
Lead	LEADCPDS	6.35E-07	8	99.0%
Manganese	MANGCPDS	4.23E-07	8	99.0%
Mercury	MERCPDS	2.12E-05	8	99.0%
Methyl chloroform	71-55-6	1.19E-05	8	N/A
Napthalene	91-20-3	1.68E-07	8	N/A
Nickel	NICKCPDS	2.12E-07	8	99.0%
POM	POM	1.66E-06	8	99.0%
Selenium	SEC	1.06E-06	8	99.0%
Toluene	108-88-3	0.00	8	N/A
Xylene	1330-20-7	7.06E-05	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	0.63	8	N/A
Methane	CH <sub>4</sub>	2.32E-05	8	N/A
Nitrous oxide	N <sub>2</sub> O	4.64E-06	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

**Boiler #6 - Operating Scenario #1 - Coal**

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043  
 Permit #: 03069T28  
 County: Orange  
 DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #1 - Coal					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			58,836			tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	1.53%	% Ash	8.79%	Heat Content (Btu/lb or mmCF)	12,678 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	32.19%	Mar-May	22.23%	June-Aug	29.98%	Sept-Nov	15.59%
------------------------------	--------	---------	--------	----------	--------	----------	--------

## Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	25.50	8	N/A
NOx	NOx	250.16	1	N/A
PM Total	PM	6.32	8	99.80%
PM-2.5	PM-2.5	3.65	8	97.90%
PM-10	PM-10	6.32	8	99.60%
SO2	SO2	129.16	1	90.00%
VOC	VOC	0.34	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	33.54	8	N/A
Acetophenone	98-86-2	0.88	8	N/A
Acrolein	107-02-8	17.06	8	N/A
Arsenic*	ARSENICPDS	0.45	8	99.60%
Benzene	71-43-2	76.49	8	N/A
Benzo(a)pyrene	50-32-8	2.24E-03	8	N/A
Benzyl chloride	100-44-7	41.18	8	N/A
Beryllium*	BERYLCPDS	0.08	8	N/A
Biphenyl	92-52-4	1.00E-01	8	N/A
Bis(2-ethylhexyl)phthalate (DEHP)	117-81-7	4.30	8	N/A
Bromine	7726-95-6	12.26	8	99.60%
Bromoform	75-25-2	2.29	8	N/A
Cadmium*	CADMIUMCPDS	2.08E-01	8	99.60%
Carbon disulfide	75-10-0	7.65	8	N/A
2-Chloroacetophenone	532-27-4	0.41	8	N/A
Chlorobenzene	108-90-7	1.29	8	N/A
Chloroform	67-66-3	3.47	8	N/A
Chromium*	CROMCPDS	7.18	8	99.60%
Chromium (VI)	CHROM6CPDS	0.01	8	99.60%
Cumene	98-82-8	0.31	8	N/A
Cyanide	CNC	147.09	8	N/A
Dibenzofurans	132-64-9	1.18E-02	8	N/A
Dimethyl sulfate	77-78-1	2.82	8	N/A
2,4-Dinitrotoluene	121-14-2	1.65E-02	8	N/A
Ethyl benzene	100-41-4	5.53	8	N/A
Ethyl chloride	75-00-3	2.47	8	N/A
Ethylene dibromide	106-93-4	7.06E-02	8	N/A
Ethylene dichloride	107-06-2	2.35	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

## Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

## North Carolina Department of Environment and Natural Resources

## Division of Air Quality

## Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Formaldehyde*	50-0-00	98.40	8	N/A
Hexane	HEXANEISO	3.94	8	N/A
Hydrogen Chloride *	7647-01-0	19142.22	8	N/A
Hydrogen Fluoride *	7664-39-3	343.96	8	90% Control with CaCO <sub>3</sub>
Isophorone	78-59-1	34.12	8	N/A
Lead*	LEADCPDS	2.63	8	99.60%
Manganese*	MANGCPDS	17.95	8	99.60%
Mercury*	MERCCPDS	1.25	8	N/A
Methyl bromide	74-83-9	9.41	8	N/A
Methyl chloride	74-87-3	31.18	8	N/A
Methyl ethyl ketone	78-93-3	22.95	8	N/A
Methyl hydrazine	60-34-4	10.00	8	N/A
Methyl methacrylate	80-62-6	1.18	8	N/A
Methyl tert butyl ether	1634-04-4	2.06	8	N/A
Methylene chloride	75-09-2	17.06	8	N/A
Naphthalene	91-20-3	0.76	8	N/A
Nickel	NICKCPDS	14.61	8	99.60%
Phenol	108-95-2	0.94	8	N/A
POM	POM	3.35	8	N/A
Propionaldehyde	123-38-6	22.36	8	N/A
Styrene	100-42-5	1.47	8	N/A
2,3,7,8-TCDD	1746-01-6	8.41E-07	8	N/A
Tetrachloroethylene	79-34-5	2.53	8	N/A
Toluene	108-88-3	14.12	8	N/A
1,1,1-Trichloroethane	79-00-5	1.18	8	N/A
Vinyl acetate	108-05-4	0.45	8	N/A
Xylenes	1330-20-7	2.18	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	168,576.87	8	N/A
Methane	CH <sub>4</sub>	0.28	8	N/A
Nitrous oxide	N <sub>2</sub> O	2.64	8	N/A

**Boiler #6 - Operating Scenario #3 - Natural Gas**

If Emission Source has multiple Operating Scenarios, complete one form for each.

(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #2 - Natural Gas					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		7,423			1,000 ft <sup>3</sup> /yr		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	1,030 Btu/ft <sup>3</sup>

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

## 8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

## 9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

## 10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8059 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

## 11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	10.80%	Mar-May	9.03%	June-Aug	0.40%	Sept-Nov	79.77%
------------------------------	--------	---------	-------	----------	-------	----------	--------

## Boiler #6 - Operating Scenario #3 - Natural Gas

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.31	8	N/A
NOx	NOx	1.29	1	N/A
PM Total	PM	0.03	8	N/A
PM-2.5	PM-2.5	0.03	8	N/A
PM-10	PM-10	0.03	8	N/A
SO2	SO2	0.00	1	N/A
VOC	VOC	0.02	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICCPDS	1.48E-03	8	N/A
Benzene	71-43-2	0.02	8	N/A
Cadmium	CADMIUMCPDS	8.17E-03	8	N/A
Chromium	CROMCPDS	1.04E-02	8	N/A
Chromium VI	CHROM6CPDS	1.04E-02	8	N/A
Dichlorobenzene	106-46-7	8.91E-03	8	N/A
Formaldehyde	50-00-0	0.56	8	N/A
Hexane	HEXANEISO	13.36	8	N/A
Lead	LEADCPDS	3.71E-03	8	N/A
Manganese	MANGCPDS	2.82E-03	8	N/A
Mercury	MERCPDS	1.93E-03	8	N/A
Napthalene	91-20-3	4.53E-03	8	N/A
Nickel	NICKCPDS	0.02	8	N/A
POM	POM	4.91E-03	8	N/A
Toluene	108-88-3	0.03	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	493.54	8	N/A
Methane	CH <sub>4</sub>	8.428E-03	8	N/A
Nitrous oxide	N <sub>2</sub> O	8.428E-04	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.



**Boiler #6 - Operating Scenario #5 - Wood Pellets**  
 If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**  
 Permit #: **03069T28**  
 County: **Orange**  
 DAQ Region: **Raleigh**

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #5 - Wood Pellets					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		64.63 MMBtu/hr (20% HI from wood pellets)					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			15.9			tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	NA	% Ash	NA	Heat Content (Btu/lb or mmCF)	8,000 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	0.00%	Mar-May	0.00%	June-Aug	0.00%	Sept-Nov	100.00%
------------------------------	-------	---------	-------	----------	-------	----------	---------

Boiler #6 - Operating Scenario #5 - Wood Pellets  
 If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.022	8	N/A
NOx	NOx	0.043	1	N/A
PM Total	PM	0.00011	8	99.80%
PM-2.5	PM-2.5	0.00008	8	97.90%
PM-10	PM-10	0.00010	8	99.60%
SO2	SO2	CEM w/coal	1	90.00%
VOC	VOC	0.0022	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	2.11E-01	8	N/A
Acetophenone	98-86-2	8.14E-07	8	N/A
Acrolein	107-02-8	1.02E+00	8	N/A
Antimony	7440-36-0	8.04E-06	8	99.60%
Arsenic	ARSENICPDS	2.24E-05	8	99.60%
Benzene	71-43-2	1.07E+00	8	N/A
Benzo(a)pyrene	50-32-8	6.61E-04	8	N/A
Beryllium	BERYLCPDS	1.12E-06	8	99.60%
Cadmium	CADMIUMCPDS	4.17E-06	8	99.60%
Carbon tetrachloride	56-23-5	1.14E-02	8	N/A
Chlorine	7782-50-5	2.01E-01	8	N/A
Chlorobenzene	108-90-7	8.40E-03	8	N/A
Chloroform	67-66-3	7.12E-03	8	N/A
Chromium	CROMCPDS	1.78E-05	8	99.60%
Cobalt	7440-48-4	6.61E-06	8	99.60%
Di(2-ethylhexy)phthalate	117-81-7	1.20E-05	8	N/A
Dinitrophenol, 2,4-	51-28-5	4.58E-05	8	N/A
Ethyl benzene	100-41-4	7.89E-03	8	N/A
Ethylene dichloride	107-06-2	7.38E-03	8	N/A
Formaldehyde*	50-0-00	1.12E+00	8	N/A
Hexachlorodib-dioxin	57653-85-7	4.07E-04	8	N/A
Hydrogen Chloride *	7647-01-0	1.56E+00	8	68% Control with CaCO <sub>3</sub>
Lead*	LEADCPDS	4.88E-05	8	99.60%
Manganese*	MANGCPDS	1.63E-03	8	99.60%
Mercury*	MERCCPDS	6.86E-05	8	92%
Methyl bromide	74-83-9	3.82E-03	8	N/A
Methyl chloride	74-87-3	5.85E-03	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

## Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Methyl chloroform	71-55-6	7.89E-03	8	N/A
Methyl ethyl ketone	78-93-3	1.37E-03	8	N/A
Methylene chloride	75-09-2	7.38E-02	8	N/A
Naphthalene	91-20-3	2.47E-02	8	N/A
Nickel	NICKCPDS	3.36E-05	8	99.60%
Nitrophenol, 4-	100-02-07	2.80E-05	8	N/A
Pentachlorophenol	87-86-5	1.30E-05	8	N/A
Perchloroethylene	127-18-4	9.67E-03	8	N/A
Phenol	108-95-2	1.30E-02	8	N/A
Phosphorus	7723-14-0	2.75E-05	8	99.60%
Polychlorinated biphenyls	1336-36-3	2.07E-06	8	N/A
POM	POM	3.18E-02	8	N/A
Propionaldehyde	123-38-6	1.55E-02	8	N/A
Propylene dichloride	78-87-5	8.40E-03	8	N/A
Selenium	7782-49-2	2.85E-06	8	99.60%
Styrene	100-42-5	4.83E-01	8	N/A
2,3,7,8-TCDD	1746-01-6	2.19E-09	8	N/A
Toluene	108-88-3	2.34E-01	8	N/A
Trichloroethylene	79-01-6	7.63E-03	8	N/A
Trichlorofluoromethane	75-69-4	1.04E-02	8	N/A
Trichlorophenol	95-95-4	5.60E-06	8	N/A
Vinyl chloride	75-01-4	4.58E-03	8	N/A
Xylenes	1330-20-7	6.36E-03	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	29.05	8	N/A
Methane	CH <sub>4</sub>	0.0090	8	N/A
Nitrous oxide	N <sub>2</sub> O	0.0012	8	N/A

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

**Boiler #6**

**(ES-001-Boiler #6)**

*Emissions Calculations*

SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> Emissions are Taken from CEMs Data  
Other emission factors are from stack test or DAQ spreadsheets

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A  
2010 Annual Emissions Inventory**

**Boiler #6  
(ES-001-Boiler #6)  
Facility ID # 6800043  
Permit # 03069T28**

Operating Scenario #4 - No.2 Fuel Oil

<b>User Input</b>	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T28
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	0.050
Maximum fuel sulfur content (%):	0.1
Latest Construction/Modification Date:	N/A
<b>Enter the boiler type below ↘</b>	
	15

<b>Boilers =&gt;100 mmBtu/hr</b>	<b>Boilers =&gt;100 mmBtu/hr (cont'd)</b>
1 = No. 6 oil fired, normal firing (U)	16 = No. 2 oil fired (C)
2 = No. 6 oil fired, normal firing (I)	17 = No. 2 oil fired, LNB/FGR (U,I)
3 = No. 6 oil fired, normal firing (C)	18 = No. 2 oil fired, LNB/FGR (C)
4 = No. 6 oil fired, normal firing, low NOx burner (U)	
5 = No. 6 oil fired, normal firing, low NOx burner (I)	19 = Vertical fired utility boiler
6 = No. 6 oil fired, normal firing, low NOx burner (C)	
7 = No. 6 oil fired, tangential firing (U)	<b>Small Boilers (&lt;100 mmBtu/hr)</b>
8 = No. 6 oil fired, tangential firing, low NOx burner (U)	20 = No. 6 oil fired (I)
9 = No. 5 oil fired, normal firing (U)	21 = No. 6 oil fired (C)
10 = No. 5 oil fired, normal firing (I)	22 = No. 5 oil fired (C)
11 = No. 5 oil fired, tangential firing (U)	23 = No. 4 oil fired (C)
12 = No. 4 oil fired, normal firing (U)	24 = No. 2 oil fired (I)
13 = No. 4 oil fired, normal firing (I)	25 = No. 2 oil fired (C)
14 = No. 4 oil fired, tangential firing (U)	
15 = No. 2 oil fired (U,I)	26 = Residential Furnace

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**

**2010 Annual Emissions Inventory**

**Boiler #6**

**(ES-001-Boiler #6)**

**Facility ID # 6800043**

**Permit # 03069T28**

Operating Scenario #4 - No.2 Fuel Oil

<b>User Input</b>	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T28
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	0.050
Maximum fuel sulfur content (%):	0.1
Latest Construction/Modification Date:	N/A

**Emission Controls**

Particulate controls

<b>Enter the control type below</b> ▾	Message Area	Or enter a PM control efficiency below to override built in values.
3		
<u>Control Device</u>	<u>Avg. Cont. Effic.</u>	<u>User Input PM Cont. Effic.</u>
0 = None/other		Message Area
1 = ESP		
2 = Scrubber		
3 = Bagfilter	99.0	
4 = Multiple cyclone		

Postcombustion SO<sub>2</sub> controls

<b>Enter the control type below</b> ▾	Message Area	Or enter an SO <sub>2</sub> control efficiency below to override built in values.
0		
<u>Control Technology/Process</u>	<u>Avg. Cont. Effic.</u>	<u>User Input SO<sub>2</sub> Cont. Effic.</u>
0 = None/other		90.0
1 = Wet scrubber, Lime/limestone		User entered control efficiency may be overestimated and should be documented.
2 = Wet scrubber, Sodium carbonate	0.0	
3 = Wet scrubber, Magnesium oxide/hydroxide		
4 = Wet scrubber, Dual alkali		
5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel	<u>Remarks</u>	
6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity	NA	
7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray		

NO<sub>x</sub> controls

<b>Enter the control type below</b> ▾	Message Area	Or enter a NO <sub>x</sub> control efficiency below to override built in values.
5		
<u>Control Technology/Process</u>	<u>Avg. Cont. Effic.</u>	<u>User Input NO<sub>x</sub> Cont. Effic.</u>
0 = None/other		0.0
1 = Low excess air (LEA)		Message Area
2 = Staged combustion (SC)	39.0	
3 = Burners out of service (BOOS)		
4 = Flue gas recirculation (FGR)		
5 = Flue gas recirculation plus staged combustion	<u>Remarks</u>	
6 = Low NO <sub>x</sub> burners (LNB)	Available for boilers with sufficient operational flexibility	
7 = Reduced air preheat (RAP)		
8 = Selective noncatalytic reduction (SNCR)		
9 = Conventional selective catalytic reduction (SCR)		

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**  
**2010 Annual Emissions Inventory**

**Boiler #6**  
**(ES-001-Boiler #6)**  
**Facility ID # 6800043**  
**Permit # 03069T28**

Operating Scenario #4 - No.2 Fuel Oil

<b>User Input</b>	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T28
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	0.050
Maximum fuel sulfur content (%):	0.1
Latest Construction/Modification Date:	N/A

<b>Emissions Output (for operation 3.42 hr/yr)</b>				Emission Factor <sup>1</sup>
<b>Criteria Pollutants</b>				(lb/10 <sup>3</sup> gal)
Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	
Total PM (FPM + CPM)	3.0	0.000	0	3.30E+00
Filterable PM (FPM) rates @ 99% control	0.0	0.000	0	2.00E+00
Condensable PM (CPM) <sup>4</sup>	3.0	0.000	0	1.30E+00
Filterable PM-10 <sup>5</sup>	0.0	0.000	0	1.00E+00
Filterable PM-2.5 <sup>5</sup>	0.0	0.000	0	2.50E-01
NOx rates @ 39% control	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.000	0	2.00E-01
CO	12	0.000	0	5.00E+00
SO2 rates @ 90% control	see attached CEMs-based calculations			2.98E+02
Total HAP <sup>6</sup>	4.17E-01	0.000	0	1.81E-01
Largest HAP <sup>6</sup>	1.84E-01	0.000	0	7.97E-02

<b>Toxic/Hazardous Air Pollutants</b>				Emission Factor <sup>1</sup>
Pollutant	lb/hr <sup>2</sup>	lb/day <sup>7</sup>	lb/yr <sup>3</sup>	(lb/10 <sup>3</sup> gal)
Antimony rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates @ 99% control	1.29E-05	NA	2.82E-07	5.60E-04
Benzene	6.35E-03	NA	1.39E-04	2.75E-03
Beryllium rates @ 99% control	9.70E-06	NA	2.12E-07	4.20E-04
Cadmium rates @ 99% control	9.70E-06	NA	2.12E-07	4.20E-04
Chromium rates @ 99% control	9.70E-06	NA	2.12E-07	4.20E-04
Chromium VI rates @ 99% control	2.85E-06	NA	6.21E-08	1.23E-04
Cobalt rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.89E-03	NA	4.12E-05	8.17E-04
Fluoride	8.61E-02	2.07E+00	1.88E-03	3.73E-02
Formaldehyde	1.11E-01	2.66E+00	2.42E-03	4.80E-02
Lead rates @ 99% control	2.91E-05	NA	6.35E-07	1.26E-03
Manganese rates @ 99% control	1.94E-05	4.65E-04	4.23E-07	8.40E-04
Mercury	9.70E-04	2.33E-02	2.12E-05	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.45E-04	1.31E-02	1.19E-05	2.36E-04
Naphthalene	7.69E-04	NA	1.68E-07	3.33E-04
Nickel rates @ 99% control	9.70E-06	2.33E-04	2.12E-07	4.20E-04
POM rates @ 99% control	7.62E-05	NA	1.66E-06	3.30E-03
Selenium rates @ 99% control	4.85E-05	NA	1.06E-06	2.10E-03
Toluene	1.84E-01	4.41E+00	4.02E-03	7.97E-02
Xylene	3.23E-03	7.76E-02	7.06E-05	1.40E-03

<b>Greenhouse Gases</b>				Emission Factor
Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	(lb/10 <sup>3</sup> gal)
Carbon dioxide	see attached CEMs-based calculations			22687.74
Methane	2.12E+00	2.32E-05	4.64E-02	0.920
Nitrous Oxide	4.25E-01	4.64E-06	9.28E-03	0.18

<sup>1</sup>Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

<sup>2</sup>Hourly emission rates for all pollutants are based on hourly rated capacity.

<sup>3</sup>Annual emission rates for all pollutants are based on maximum annual fuel throughput.

<sup>4</sup>Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

<sup>5</sup>AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

<sup>6</sup>Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

Fuel Oil Combustion Emissions Calculator **FO2000 Revision A**  
2010 Annual Emissions Inventory

Boiler #6  
(ES-001-Boiler #6)  
Facility ID # 6800043  
Permit # 03069T28

Operating Scenario #4 - No.2 Fuel Oil

<b>User Input</b>	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T28
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	0.050
Maximum fuel sulfur content (%):	0.1
Latest Construction/Modification Date:	N/A

<sup>7</sup>Daily emission rates are based on operation 24 hours per day at rated capacity.



# Bituminous Coal Combustion

2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #6**  
 (ES-001-Boiler #6)

Operating Scenario #1

## Data Input

Maximum Heat Input	<input type="text" value="323.17"/>	mmBtu/hr	<b>Boiler Type:</b>	<input type="text" value="7"/>
Boiler Size/Type	Large Industrial		1) Pulverized/Dry Bottom	6) Underfeed Stoker
Actual Fuel Usage	<input type="text" value="58,836"/>	ton/yr	2) Pulverized/Wet Bottom	7) Fluidized Bed Cir.
or	or		3) Cyclone Furnace	8) Fluidized Bed Bub.
Hours of Operation	<input type="text"/>	hr/yr	4) Spreader Stoker	9) Hand Fed
and	and		5) Overfeed Stoker	
Heating Value	<input type="text" value="12,709"/>	Btu/lb	<b>Control Device Efficiencies:</b>	
		ton/yr	PM	<input type="text" value="99.80"/> %
Sulfur Content	<input type="text" value="1.53"/>	%	PM-10	<input type="text" value="98.00"/> %
Ash Content :	<input type="text" value="8.8"/>	%	PM-2.5	<input type="text" value="97.90"/> %
(B)ituminous or (S)ubbituminous?	<input type="text" value="B"/>	(B/S)	SOx*	<input type="text" value="90.00"/> %
Calcium to Sulfur Ratio	<input type="text" value="2.22"/>		NOx*	<input type="text" value="0.00"/> %

*\*SOx and NOx emission estimates were calculated using CEMS data. Please refer to the SOx and NOx emissions data presented in the following CEMs spreadsheets.  
 HCl, HF, and Hg emissions based on stack test data.*

# Bituminous Coal Combustion

2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #6**  
**(ES-001-Boiler #6)**

Operating Scenario #1

## ACTUAL CRITERIA EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
PM*	0.21	2.73	12,644	6.32
PM-10*	0.21	2.73	12,644	6.32
PM-2.5*	0.12	1.58	7,290	3.65
SO2	13.31	**	**	**
SO3	0.09	**	**	**
NOx	3.90	**	**	**
VOC*	0.01	0.15	688	0.34
CO*	0.87	11.02	50,996	25.50

## ACTUAL TOXIC EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Acetaldehyde	5.70E-04	7.25E-03	3.35E+01	1.68E-02
Acetophenone	1.50E-05	1.91E-04	8.83E-01	4.41E-04
Acrolein	2.90E-04	3.69E-03	1.71E+01	8.53E-03
Antimony*	8.21E-06	1.04E-04	4.83E-01	2.42E-04
Arsenic*	7.65E-06	9.73E-05	4.50E-01	2.25E-04
Benzene	1.30E-03	1.65E-02	7.65E+01	3.82E-02
Benzo(a)pyrene	3.80E-08	4.83E-07	2.24E-03	1.12E-06
Benzyl chloride	7.00E-04	8.90E-03	4.12E+01	2.06E-02
Beryllium*	1.34E-06	1.71E-05	7.90E-02	3.95E-05
Biphenyl	1.70E-06	2.16E-05	1.00E-01	5.00E-05
Bis(2-ethylhexyl)phthalate (DEHP)	7.30E-05	9.28E-04	4.30E+00	2.15E-03
Bromine	1.04E-01	2.65E-03	1.23E+01	6.13E-03
Bromoform	3.90E-05	4.96E-04	2.29E+00	1.15E-03
Cadmium*	3.53E-06	4.49E-05	2.08E-01	1.04E-04
Carbon disulfide	1.30E-04	1.65E-03	7.65E+00	3.82E-03
2-Chloroacetophenone	7.00E-06	8.90E-05	4.12E-01	2.06E-04
Chlorobenzene	2.20E-05	2.80E-04	1.29E+00	6.47E-04
Chlorine*	2.75E-03	3.49E-02	1.62E+02	8.08E-02
Chloroform	5.90E-05	7.50E-04	3.47E+00	1.74E-03
Chromium*	1.22E-04	1.55E-03	7.18E+00	3.59E-03
Chromium (VI)	1.22E-04	3.10E-06	1.44E-02	7.18E-06
Cobalt*	7.02E-06	8.92E-05	4.13E-01	2.06E-04
Cumene	5.30E-06	6.74E-05	3.12E-01	1.56E-04
Cyanide	2.50E-03	3.18E-02	1.47E+02	7.35E-02
Dibenzofurans	2.01E-07	2.56E-06	1.18E-02	5.91E-06
Dimethyl sulfate	4.80E-05	6.10E-04	2.82E+00	1.41E-03
2,4-Dinitrotoluene	2.80E-07	3.56E-06	1.65E-02	8.24E-06
Ethyl benzene	9.40E-05	1.20E-03	5.53E+00	2.77E-03
Ethyl chloride	4.20E-05	5.34E-04	2.47E+00	1.24E-03
Ethylene dibromide	1.20E-06	1.53E-05	7.06E-02	3.53E-05
Ethylene dichloride	4.00E-05	5.09E-04	2.35E+00	1.18E-03
Formaldehyde*	1.67E-03	2.13E-02	9.84E+01	4.92E-02
Hexane	6.70E-05	8.52E-04	3.94E+00	1.97E-03
Hydrogen Chloride *	3.25E-01	4.14E+00	1.91E+04	9.57E+00
Hydrogen Fluoride *	5.85E-03	7.43E-02	3.44E+02	1.72E-01
Isophorone	5.80E-04	7.37E-03	3.41E+01	1.71E-02
Lead*	4.47E-05	5.69E-04	2.63E+00	1.32E-03

\*\*SO<sub>2</sub> and NOx emissions were estimated using CEMS data, please refer to the attached data sheets entitled "Sulfur Dioxide Emissions from Boiler #6" and Nitrogen Dioxide Emissions from Boiler #6".

# Bituminous Coal Combustion

2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #6**  
**(ES-001-Boiler #6)**

Operating Scenario #1

## ACTUAL TOXIC EMISSIONS (continued)

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
<i>Manganese*</i>	3.05E-04	3.88E-03	1.79E+01	8.97E-03
<i>Mercury*</i>	2.13E-05	2.70E-04	1.25E+00	6.26E-04
Methyl bromide	1.60E-04	2.03E-03	9.41E+00	4.71E-03
Methyl chloride	5.30E-04	6.74E-03	3.12E+01	1.56E-02
Methyl ethyl ketone	3.90E-04	4.96E-03	2.29E+01	1.15E-02
Methyl hydrazine	1.70E-04	2.16E-03	1.00E+01	5.00E-03
Methyl methacrylate	2.00E-05	2.54E-04	1.18E+00	5.88E-04
Methyl tert butyl ether	3.50E-05	4.45E-04	2.06E+00	1.03E-03
Methylene chloride	2.90E-04	3.69E-03	1.71E+01	8.53E-03
Naphthalene	1.30E-05	1.65E-04	7.65E-01	3.82E-04
<i>Nickel*</i>	2.48E-04	3.16E-03	1.46E+01	7.31E-03
Phenol	1.60E-05	2.03E-04	9.41E-01	4.71E-04
<i>Phosphorus*</i>	3.71E-05	4.72E-04	2.18E+00	1.09E-03
POM	5.69E-05	7.24E-04	3.35E+00	1.67E-03
Propionaldehyde	3.80E-04	4.83E-03	2.24E+01	1.12E-02
<i>Selenium*</i>	5.46E-06	6.95E-05	3.22E-01	1.61E-04
Styrene	2.50E-05	3.18E-04	1.47E+00	7.35E-04
2,3,7,8-TCDD	1.43E-11	1.82E-10	8.41E-07	4.21E-10
Tetrachloroethylene	4.30E-05	5.47E-04	2.53E+00	1.26E-03
Toluene	2.40E-04	3.05E-03	1.41E+01	7.06E-03
1,1,1-Trichloroethane	2.00E-05	2.54E-04	1.18E+00	5.88E-04
Vinyl acetate	7.60E-06	9.66E-05	4.47E-01	2.24E-04
Xylenes	3.70E-05	4.70E-04	2.18E+00	1.09E-03
Total HAPs		4.39	20,324.45	10.16

## Greenhouse Gases

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Carbon dioxide			see attached CEMs-based calculations	
<i>Methane*</i>	0.010	0.12	568.28	0.28
Nitrous Oxide	0.09	1.14	5,275	2.64

**\*Emission rates for pollutants in italics from August 2009 Section 114 test of Boiler #6.**

Notes :

- Emission factors are from Supplement B to the 5th edition of AP-42, unless otherwise noted
- Emission calculations will be based on the hours of operation only when actual fuel usage is not supplied
- Particulate controls affect PM, PM-10, PM-2.5, and all toxics that are regulated as particulates except Mercury
- VOC = NMTOC = TOC \* (1-%METHANE)
- PM-2.5 and SO3 do not currently need to be reported
- Dibenzofurans = Polychlorinated dibenzo-p-furans
- The Br emission factor is based on a mass balance generated from a 3 year coal analysis for Duke Power (1990-1992, 7 samples per year). The average concentration of bromine was 55.33 ppm (wet basis) and a heating value of 13,500 Btu/lb was assumed
- For fluidized bed combustion the emission factor for underfeed stokers is utilized whenever the calcium-to-sulfur ratio is outside of the acceptable range of 1.5 to 7

**Natural Gas Combustion Emissions Calculator NG2000 Revision C**  
**2010 Annual Emissions Inventory**

**Boiler #6**

(ES-001-Boiler #6)

Facility ID # 6800043  
 Permit # 03069T28

**Operating Scenario #2**

User Input	Emissions Output																																																																																							
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Company Name:</td> <td>University of North Carolina at Chapel Hill</td> </tr> <tr> <td>Plant County:</td> <td>Orange County</td> </tr> <tr> <td>Plant City:</td> <td>Chapel Hill</td> </tr> <tr> <td>Permit Number:</td> <td>03069T28</td> </tr> <tr> <td>User:</td> <td>RST Engineering</td> </tr> <tr> <td>Heat Input Capacity (mmBtu/hr):</td> <td align="right">323.17</td> </tr> <tr> <td>Fuel Input Capacity (10<sup>6</sup> scf/hr):</td> <td align="right">0.32</td> </tr> <tr> <td>Annual Fuel Throughput (10<sup>6</sup> scf):</td> <td align="right">7.42</td> </tr> <tr> <td>Latest Construction/Modification Date:</td> <td>N/A</td> </tr> </table>	Company Name:	University of North Carolina at Chapel Hill	Plant County:	Orange County	Plant City:	Chapel Hill	Permit Number:	03069T28	User:	RST Engineering	Heat Input Capacity (mmBtu/hr):	323.17	Fuel Input Capacity (10 <sup>6</sup> scf/hr):	0.32	Annual Fuel Throughput (10 <sup>6</sup> scf):	7.42	Latest Construction/Modification Date:	N/A	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="4">Criteria Pollutants</th> <th>Emission Factor (lb/mmscf)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> <th></th> </tr> <tr> <td>PM</td> <td align="right">2.4E+00</td> <td align="right">5.6E+01</td> <td align="right">2.8E-02</td> <td align="right">7.6E+00</td> </tr> <tr> <td>PM-10</td> <td align="right">2.4E+00</td> <td align="right">5.6E+01</td> <td align="right">2.8E-02</td> <td align="right">7.6E+00</td> </tr> <tr> <td>PM-2.5</td> <td align="right">2.4E+00</td> <td align="right">5.6E+01</td> <td align="right">2.8E-02</td> <td align="right">7.6E+00</td> </tr> <tr> <td>NOx</td> <td colspan="3">see attached CEMs-based calculations</td> <td align="right">1.9E+02</td> </tr> <tr> <td>VOC</td> <td align="right">1.7E+00</td> <td align="right">4.1E+01</td> <td align="right">2.0E-02</td> <td align="right">5.5E+00</td> </tr> <tr> <td>CO</td> <td align="right">2.7E+01</td> <td align="right">6.2E+02</td> <td align="right">3.1E-01</td> <td align="right">8.4E+01</td> </tr> <tr> <td>SO2</td> <td colspan="3">see attached CEMs-based calculations</td> <td align="right">6.0E-01</td> </tr> <tr> <td>Total HAP</td> <td align="right">6.0E-01</td> <td align="right">1.4E+01</td> <td align="right">7.0E-03</td> <td align="right">1.9E+00</td> </tr> <tr> <td>Largest HAP</td> <td align="right">5.7E-01</td> <td align="right">1.3E+01</td> <td align="right">6.7E-03</td> <td align="right">1.8E+00</td> </tr> </table>	Criteria Pollutants				Emission Factor (lb/mmscf)	Pollutant	lb/hr	lb/yr	tpy		PM	2.4E+00	5.6E+01	2.8E-02	7.6E+00	PM-10	2.4E+00	5.6E+01	2.8E-02	7.6E+00	PM-2.5	2.4E+00	5.6E+01	2.8E-02	7.6E+00	NOx	see attached CEMs-based calculations			1.9E+02	VOC	1.7E+00	4.1E+01	2.0E-02	5.5E+00	CO	2.7E+01	6.2E+02	3.1E-01	8.4E+01	SO2	see attached CEMs-based calculations			6.0E-01	Total HAP	6.0E-01	1.4E+01	7.0E-03	1.9E+00	Largest HAP	5.7E-01	1.3E+01	6.7E-03	1.8E+00														
Company Name:	University of North Carolina at Chapel Hill																																																																																							
Plant County:	Orange County																																																																																							
Plant City:	Chapel Hill																																																																																							
Permit Number:	03069T28																																																																																							
User:	RST Engineering																																																																																							
Heat Input Capacity (mmBtu/hr):	323.17																																																																																							
Fuel Input Capacity (10 <sup>6</sup> scf/hr):	0.32																																																																																							
Annual Fuel Throughput (10 <sup>6</sup> scf):	7.42																																																																																							
Latest Construction/Modification Date:	N/A																																																																																							
Criteria Pollutants				Emission Factor (lb/mmscf)																																																																																				
Pollutant	lb/hr	lb/yr	tpy																																																																																					
PM	2.4E+00	5.6E+01	2.8E-02	7.6E+00																																																																																				
PM-10	2.4E+00	5.6E+01	2.8E-02	7.6E+00																																																																																				
PM-2.5	2.4E+00	5.6E+01	2.8E-02	7.6E+00																																																																																				
NOx	see attached CEMs-based calculations			1.9E+02																																																																																				
VOC	1.7E+00	4.1E+01	2.0E-02	5.5E+00																																																																																				
CO	2.7E+01	6.2E+02	3.1E-01	8.4E+01																																																																																				
SO2	see attached CEMs-based calculations			6.0E-01																																																																																				
Total HAP	6.0E-01	1.4E+01	7.0E-03	1.9E+00																																																																																				
Largest HAP	5.7E-01	1.3E+01	6.7E-03	1.8E+00																																																																																				
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Enter the boiler type below ▾</td> <td align="center">2</td> </tr> </table>	Enter the boiler type below ▾	2	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5">Toxic/Hazardous Air Pollutants</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/day</th> <th>lb/yr</th> <th></th> </tr> <tr> <td>Arsenic</td> <td align="right">6.3E-05</td> <td align="center">NA</td> <td align="right">1.5E-03</td> <td align="right">2.0E-04</td> </tr> <tr> <td>Benzene</td> <td align="right">6.7E-04</td> <td align="center">NA</td> <td align="right">1.6E-02</td> <td align="right">2.1E-03</td> </tr> <tr> <td>Cadmium</td> <td align="right">3.5E-04</td> <td align="center">NA</td> <td align="right">8.2E-03</td> <td align="right">1.1E-03</td> </tr> <tr> <td>Chromium</td> <td align="right">4.4E-04</td> <td align="center">NA</td> <td align="right">1.0E-02</td> <td align="right">1.4E-03</td> </tr> <tr> <td>Chromium VI</td> <td align="right">4.4E-04</td> <td align="center">NA</td> <td align="right">1.0E-02</td> <td align="right">1.4E-03</td> </tr> <tr> <td>Dichlorobenzene</td> <td align="right">3.8E-04</td> <td align="center">NA</td> <td align="right">8.9E-03</td> <td align="right">1.2E-03</td> </tr> <tr> <td>Formaldehyde</td> <td align="right">2.4E-02</td> <td align="center">NA</td> <td align="right">5.6E-01</td> <td align="right">7.5E-02</td> </tr> <tr> <td>Hexane</td> <td align="right">5.7E-01</td> <td align="right">1.4E+01</td> <td align="right">1.3E+01</td> <td align="right">1.8E+00</td> </tr> <tr> <td>Lead</td> <td align="right">1.6E-04</td> <td align="center">NA</td> <td align="right">3.7E-03</td> <td align="right">5.0E-04</td> </tr> <tr> <td>Manganese</td> <td align="right">1.2E-04</td> <td align="right">2.9E-03</td> <td align="right">2.8E-03</td> <td align="right">3.8E-04</td> </tr> <tr> <td>Mercury</td> <td align="right">8.2E-05</td> <td align="right">2.0E-03</td> <td align="right">1.9E-03</td> <td align="right">2.6E-04</td> </tr> <tr> <td>Naphthalene</td> <td align="right">1.9E-04</td> <td align="center">NA</td> <td align="right">4.5E-03</td> <td align="right">6.1E-04</td> </tr> <tr> <td>Nickel</td> <td align="right">6.7E-04</td> <td align="right">1.6E-02</td> <td align="right">1.6E-02</td> <td align="right">2.1E-03</td> </tr> <tr> <td>POM</td> <td align="right">2.1E-04</td> <td align="center">NA</td> <td align="right">4.9E-03</td> <td align="right">6.6E-04</td> </tr> <tr> <td>Toluene</td> <td align="right">1.1E-03</td> <td align="right">2.6E-02</td> <td align="right">2.5E-02</td> <td align="right">3.4E-03</td> </tr> </table>	Toxic/Hazardous Air Pollutants					Pollutant	lb/hr	lb/day	lb/yr		Arsenic	6.3E-05	NA	1.5E-03	2.0E-04	Benzene	6.7E-04	NA	1.6E-02	2.1E-03	Cadmium	3.5E-04	NA	8.2E-03	1.1E-03	Chromium	4.4E-04	NA	1.0E-02	1.4E-03	Chromium VI	4.4E-04	NA	1.0E-02	1.4E-03	Dichlorobenzene	3.8E-04	NA	8.9E-03	1.2E-03	Formaldehyde	2.4E-02	NA	5.6E-01	7.5E-02	Hexane	5.7E-01	1.4E+01	1.3E+01	1.8E+00	Lead	1.6E-04	NA	3.7E-03	5.0E-04	Manganese	1.2E-04	2.9E-03	2.8E-03	3.8E-04	Mercury	8.2E-05	2.0E-03	1.9E-03	2.6E-04	Naphthalene	1.9E-04	NA	4.5E-03	6.1E-04	Nickel	6.7E-04	1.6E-02	1.6E-02	2.1E-03	POM	2.1E-04	NA	4.9E-03	6.6E-04	Toluene	1.1E-03	2.6E-02	2.5E-02	3.4E-03
Enter the boiler type below ▾	2																																																																																							
Toxic/Hazardous Air Pollutants																																																																																								
Pollutant	lb/hr	lb/day	lb/yr																																																																																					
Arsenic	6.3E-05	NA	1.5E-03	2.0E-04																																																																																				
Benzene	6.7E-04	NA	1.6E-02	2.1E-03																																																																																				
Cadmium	3.5E-04	NA	8.2E-03	1.1E-03																																																																																				
Chromium	4.4E-04	NA	1.0E-02	1.4E-03																																																																																				
Chromium VI	4.4E-04	NA	1.0E-02	1.4E-03																																																																																				
Dichlorobenzene	3.8E-04	NA	8.9E-03	1.2E-03																																																																																				
Formaldehyde	2.4E-02	NA	5.6E-01	7.5E-02																																																																																				
Hexane	5.7E-01	1.4E+01	1.3E+01	1.8E+00																																																																																				
Lead	1.6E-04	NA	3.7E-03	5.0E-04																																																																																				
Manganese	1.2E-04	2.9E-03	2.8E-03	3.8E-04																																																																																				
Mercury	8.2E-05	2.0E-03	1.9E-03	2.6E-04																																																																																				
Naphthalene	1.9E-04	NA	4.5E-03	6.1E-04																																																																																				
Nickel	6.7E-04	1.6E-02	1.6E-02	2.1E-03																																																																																				
POM	2.1E-04	NA	4.9E-03	6.6E-04																																																																																				
Toluene	1.1E-03	2.6E-02	2.5E-02	3.4E-03																																																																																				
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Other NOx Control</td> <td align="center">4</td> </tr> </table>	Other NOx Control	4	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="4">Greenhouse Gas Pollutants</th> <th>Em. Factor (lb/mmBtu)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> <th></th> </tr> <tr> <td>Carbon dioxide</td> <td colspan="3">see attached CEMs-based calculations</td> <td align="right">116.89</td> </tr> <tr> <td>Methane</td> <td align="right">0.71</td> <td align="right">16.86</td> <td align="right">8.43E-03</td> <td align="right">2.20E-03</td> </tr> <tr> <td>Nitrous Oxide</td> <td align="right">0.071</td> <td align="right">1.69</td> <td align="right">8.43E-04</td> <td align="right">2.20E-04</td> </tr> </table>	Greenhouse Gas Pollutants				Em. Factor (lb/mmBtu)	Pollutant	lb/hr	lb/yr	tpy		Carbon dioxide	see attached CEMs-based calculations			116.89	Methane	0.71	16.86	8.43E-03	2.20E-03	Nitrous Oxide	0.071	1.69	8.43E-04	2.20E-04																																																												
Other NOx Control	4																																																																																							
Greenhouse Gas Pollutants				Em. Factor (lb/mmBtu)																																																																																				
Pollutant	lb/hr	lb/yr	tpy																																																																																					
Carbon dioxide	see attached CEMs-based calculations			116.89																																																																																				
Methane	0.71	16.86	8.43E-03	2.20E-03																																																																																				
Nitrous Oxide	0.071	1.69	8.43E-04	2.20E-04																																																																																				
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Large Wall-Fired Boilers (=&gt;100 mmBtu/hr)</td> </tr> <tr> <td>1 = Uncontrolled (Pre-NSPS)</td> </tr> <tr> <td>2 = Uncontrolled (Post-NSPS)</td> </tr> <tr> <td>3 = Controlled - Low NOx burners</td> </tr> <tr> <td>4 = Controlled - Flue gas recirculation (FGR)</td> </tr> </table>	Large Wall-Fired Boilers (=>100 mmBtu/hr)	1 = Uncontrolled (Pre-NSPS)	2 = Uncontrolled (Post-NSPS)	3 = Controlled - Low NOx burners	4 = Controlled - Flue gas recirculation (FGR)																																																																																			
Large Wall-Fired Boilers (=>100 mmBtu/hr)																																																																																								
1 = Uncontrolled (Pre-NSPS)																																																																																								
2 = Uncontrolled (Post-NSPS)																																																																																								
3 = Controlled - Low NOx burners																																																																																								
4 = Controlled - Flue gas recirculation (FGR)																																																																																								
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Small Boilers (&lt;100 mmBtu/hr)</td> </tr> <tr> <td>5 = Uncontrolled</td> </tr> <tr> <td>6 = Controlled - Low NOx burners</td> </tr> <tr> <td>7 = Controlled - Low NOx burners/FGR</td> </tr> </table>	Small Boilers (<100 mmBtu/hr)	5 = Uncontrolled	6 = Controlled - Low NOx burners	7 = Controlled - Low NOx burners/FGR																																																																																				
Small Boilers (<100 mmBtu/hr)																																																																																								
5 = Uncontrolled																																																																																								
6 = Controlled - Low NOx burners																																																																																								
7 = Controlled - Low NOx burners/FGR																																																																																								
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Tangential-Fired Boilers (All Sizes)</td> </tr> <tr> <td>8 = Uncontrolled</td> </tr> <tr> <td>9 = Controlled - FGR</td> </tr> </table>	Tangential-Fired Boilers (All Sizes)	8 = Uncontrolled	9 = Controlled - FGR																																																																																					
Tangential-Fired Boilers (All Sizes)																																																																																								
8 = Uncontrolled																																																																																								
9 = Controlled - FGR																																																																																								
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;">Residential Furnaces (&lt;0.3 mmBtu/hr)</td> </tr> <tr> <td>10 = Uncontrolled</td> </tr> </table>	Residential Furnaces (<0.3 mmBtu/hr)	10 = Uncontrolled																																																																																						
Residential Furnaces (<0.3 mmBtu/hr)																																																																																								
10 = Uncontrolled																																																																																								

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Boiler # 6 Wood Pellet Combustion

15.9 ton/yr, wood pellets burned                      2.54E+02 MMBtu/yr  
 64.63 MMBtu/hr, HI from wood                      99.8% PM control                      99.6% Metals control  
 8,000 Btu/lb, wood heating value                      67.8% HCl efficiency\*  
 4.04 ton/hr, max. wood firing rate                      92.3% Hg efficiency\*  
 8,760 hr/yr                      \*Calculated from August 2009 EPA Tests

Pollutant	Emission Factor (lb/MMBtu) <sup>1</sup>	Emissions (lb/hr)	Emissions (lb/yr)	Emissions (ton/yr)
<b>NOx</b>	see attached CEMs-based calculations			
<b>CO</b>	0.17	10.99	43.2	0.02
<b>SO<sub>2</sub></b>	see attached CEMs-based calculations			
PM	0.417	0.054	0.21	0.00011
PM <sub>10</sub>	0.377	0.049	0.19	0.00010
PM <sub>2.5</sub>	0.327	0.042	0.17	0.00008
VOC	0.017	1.10	4.3	0.002
	<b>lb/MMBtu</b>			
Acetaldehyde	8.30E-04	5.36E-02	2.11E-01	1.06E-04
Acetophenone	3.20E-09	2.07E-07	8.14E-07	4.07E-10
Acrolein	4.00E-03	2.59E-01	1.02E+00	5.09E-04
Antimony	7.90E-06	2.04E-06	8.04E-06	4.02E-09
Arsenic	2.20E-05	5.69E-06	2.24E-05	1.12E-08
Benzene	4.20E-03	2.71E-01	1.07E+00	5.34E-04
Benzo(a)pyrene	2.60E-06	1.68E-04	6.61E-04	3.31E-07
Beryllium	1.10E-06	2.84E-07	1.12E-06	5.60E-10
Cadmium	4.10E-06	1.06E-06	4.17E-06	2.09E-09
Carbon tetrachloride	4.50E-05	2.91E-03	1.14E-02	5.72E-06
Chlorine	7.90E-04	5.11E-02	2.01E-01	1.00E-04
Chlorobenzene	3.30E-05	2.13E-03	8.40E-03	4.20E-06
Chloroform	2.80E-05	1.81E-03	7.12E-03	3.56E-06
Chromium	1.75E-05	4.52E-06	1.78E-05	8.90E-09
Cobalt	6.50E-06	1.68E-06	6.61E-06	3.31E-09
Di(2-ethylhexyl)phthalate	4.70E-08	3.04E-06	1.20E-05	5.98E-09
Dinitrophenol, 2,4-	1.80E-07	1.16E-05	4.58E-05	2.29E-08
Ethyl Benzene	3.10E-05	2.00E-03	7.89E-03	3.94E-06
Ethylene dichloride	2.90E-05	1.87E-03	7.38E-03	3.69E-06
Formaldehyde	4.40E-03	2.84E-01	1.12E+00	5.60E-04
Hexachlorodibenzo-p-dioxin	1.60E-06	1.03E-04	4.07E-04	2.04E-07
Hydrogen Chloride	1.90E-02	3.95E-01	1.56E+00	7.78E-04
Lead	4.80E-05	1.24E-05	4.88E-05	2.44E-08
Manganese	1.60E-03	4.14E-04	1.63E-03	8.14E-07
Mercury	3.50E-06	1.74E-05	6.86E-05	3.43E-08
Methyl bromide	1.50E-05	9.70E-04	3.82E-03	1.91E-06
Methyl chloride	2.30E-05	1.49E-03	5.85E-03	2.93E-06
Methyl chloroform	3.10E-05	2.00E-03	7.89E-03	3.94E-06
Methyl ethyl ketone	5.40E-06	3.49E-04	1.37E-03	6.87E-07
Methylene chloride	2.90E-04	1.87E-02	7.38E-02	3.69E-05
Naphthalene	9.70E-05	6.27E-03	2.47E-02	1.23E-05
Nickel	3.30E-05	8.53E-06	3.36E-05	1.68E-08
Nitrophenol, 4-	1.10E-07	7.11E-06	2.80E-05	1.40E-08
Pentachlorophenol	5.10E-08	3.30E-06	1.30E-05	6.49E-09
Perchloroethylene	3.80E-05	2.46E-03	9.67E-03	4.83E-06
Phenol	5.10E-05	3.30E-03	1.30E-02	6.49E-06
Phosphorus	2.70E-05	6.98E-06	2.75E-05	1.37E-08
Polychlorinated biphenyls	8.15E-09	5.27E-07	2.07E-06	1.04E-09
POM	1.25E-04	8.08E-03	3.18E-02	1.59E-05
Propionaldehyde	6.10E-05	3.94E-03	1.55E-02	7.76E-06
Propylene dichloride	3.30E-05	2.13E-03	8.40E-03	4.20E-06
Selenium	2.80E-06	7.24E-07	2.85E-06	1.42E-09
Styrene	1.90E-03	1.23E-01	4.83E-01	2.42E-04
2,3,7,8-TCDD	8.60E-12	5.56E-10	2.19E-09	1.09E-12
Toluene	9.20E-04	5.95E-02	2.34E-01	1.17E-04
Trichloroethylene	3.00E-05	1.94E-03	7.63E-03	3.82E-06
Trichlorofluoromethane	4.10E-05	2.65E-03	1.04E-02	5.22E-06
Trichlorophenol	2.20E-08	1.42E-06	5.60E-06	2.80E-09
Vinyl chloride	1.80E-05	1.16E-03	4.58E-03	2.29E-06
Xylenes	2.50E-05	1.62E-03	6.36E-03	3.18E-06
Carbon Dioxide	see attached CEMs-based calculations			
Methane	0.0705	4.557	17.9	0.0090
N <sub>2</sub> O	0.00926	0.60	2.4	0.0012

<sup>1</sup>Emission factors based on DAQ wood combustion spreadsheet

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Sulfur Dioxide Emissions from Boiler #6

#### (ES-001-Boiler #6)

The exhaust duct at Boiler #6 is equipped with a continuous emissions monitor (CEMs) for SO<sub>2</sub> emissions.

For the 2010 calendar year, 30 day facility averages for the SO<sub>2</sub> emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2010	0.18
February 2010	0.17
March 2010	0.18
April 2010	0.17
May 2010	0.17
June 2010	0.18
July 2010	0.17
August 2010	0.18
September 2010	0.18
October 2010	0.18
November 2010	0.16
December 2010	0.16
<b>Annual Average</b>	<b>0.173</b>

This average includes SO<sub>2</sub> emissions from coal, wood, fuel oil, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #6 for 2010

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
<b>58,836</b>	<b>7,423</b>	<b>50</b>	<b>15.9</b>
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.48E+06	7.65E+03	7.01E+00	254.4

Total for Boiler #6 (MMBtu/yr)	1.49E+06
--------------------------------	----------

Total SO <sub>2</sub> Emissions from Boiler #6 (lb/yr)	258,324
<b>Total SO<sub>2</sub> Emissions from Boiler #6 (ton/yr)</b>	<b>129.16</b>

SO <sub>2</sub> Emissions Associated with Coal Combustion (ton/yr)	<b>129.16</b>
SO <sub>2</sub> Emissions Associated with No. 2 Fuel Oil Combustion (ton/yr)	<b>0.00061</b>
SO <sub>2</sub> Emissions Associated with Natural Gas Combustion (ton/yr)	<b>0*</b>
SO <sub>2</sub> Emissions Associated with Wood Pellet Combustion (ton/yr)	<b>0*</b>

\*All SO<sub>2</sub> measured by CEMS allocated to coal and No.2 fuel oil.

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Nitrogen Dioxide Emissions from Boiler #6

#### (ES-001-Boiler #6)

The exhaust duct at Boiler #6 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2010 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2010	0.38
February 2010	0.41
March 2010	0.39
April 2010	0.34
May 2010	0.28
June 2010	0.32
July 2010	0.31
August 2010	0.34
September 2010	0.29
October 2010	0.26
November 2010	0.28
December 2010	0.45
<b>Annual Average</b>	<b>0.34</b>

This average includes NOx emissions from coal, fuel oil, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #6 for 2010

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
<b>58,836</b>	<b>7,423</b>	<b>50</b>	<b>15.9</b>
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.48E+06	7.65E+03	7.01E+00	254.4

Total for Boiler #6 (MMBtu/yr)	1.49E+06
--------------------------------	----------

Total NOx Emissions from Boiler #6 (lb/yr)	502,987
<b>Total NOx Emissions from Boiler #6 (ton/yr)</b>	<b>251.49</b>

<b>NOx Emissions Associated with Coal Combustion (ton/yr)</b>	<b>250.16</b>
<b>NOx Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)</b>	<b>0.0012</b>
<b>NOx Emissions Associated with Natural Gas Combustion (ton/yr)</b>	<b>1.29</b>
<b>NOx Emissions Associated with Wood Pellet Combustion (ton/yr)</b>	<b>0.043</b>

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### CO<sub>2</sub> Emissions from Boiler No.6 (ES-3)

The exhaust system on Boiler #6 is equipped with a continuous emissions monitor (CEMs) for CO<sub>2</sub> concentrations. The exhaust also includes a flow monitor. Mass CO<sub>2</sub> emissions are calculated by the DAHS for GHG reporting. For the 2010 calendar year, the monthly CO<sub>2</sub> emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2010	16,058	17,701
February 2010	14,262	15,721
March 2010	12,654	13,948
April 2010	10,708	11,804
May 2010	10,240	11,287
June 2010	14,293	15,755
July 2010	16,259	17,922
August 2010	15,239	16,798
September 2010	4,846	5,342
October 2010	8,512	9,383
November 2010	10,437	11,505
December 2010	19,900	21,936
<b>Annual Total</b>	<b>153,407</b>	<b>169,100</b>

This total includes CO<sub>2</sub> emissions from coal, fuel oil, wood pellets, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #6 for 2010

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
<b>58,836</b>	<b>7,423</b>	<b>50</b>	<b>15.9</b>
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.48E+06	7.65E+03	7.01E+00	254.4

Total for Boiler #6 (MMBtu/yr)	1.49E+06
-----------------------------------	----------

#### CO<sub>2</sub> Emission Rate Ratios

	kg/MMBtu	Ratio
coal	93.40	1
n.gas	53.02	0.56767
No.2 oil	73.96	0.79186
wood	93.80	1.00428

<b>CO<sub>2</sub> Emissions Associated with Coal Combustion (ton/yr)</b>	<b>168,576.9</b>
<b>CO<sub>2</sub> Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)</b>	<b>0.63</b>
<b>CO<sub>2</sub> Emissions Associated with Natural Gas Combustion (ton/yr)</b>	<b>493.5</b>
<b>CO<sub>2</sub> Emissions Associated with Wood Pellet Combustion (ton/yr)</b>	<b>29.05</b>

1.49E+06 Dist. Factor

169,100



# The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

### **Boiler #7 (ES-002-Boiler #7)**

#### Operating Scenarios

#1 - Coal Firing

#2 - Natural Gas Firing

#4 - No.2 Fuel Oil Firing

#5 - Wood Pellet Firing

(#3 - No.6 Fuel Oil Firing is no longer permitted)

Boilers #6 and #7 are equipped with Continuous Emission Monitoring (CEMs) devices to measure SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> emissions from each of the boilers. The monthly averages presented in the attached spreadsheets are for the total emissions from firing all types of fuel. The 2010 Annual Emission Inventory forms require that the emissions be divided among the three possible operating scenarios.

NO<sub>x</sub> and CO<sub>2</sub> emissions have been divided between the four operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

SO<sub>2</sub> emissions from natural gas and wood pellet combustion are insignificant, therefore, SO<sub>2</sub> emissions have been divided between the fuel oil and coal operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

#### *Emissions Calculations*

SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> Emissions are taken from CEMs data

Other emission factors are from stack test or DAQ spreadsheets

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2		<b>Facility ID #:</b> 6800043					
<i>Boiler #7 - Operating Scenario #4 - No. 2 Fuel Oil</i>		<b>Permit #:</b> 03069T28					
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)		<b>County:</b> Orange					
<b>Facility Name:</b> University of North Carolina at Chapel Hill		<b>DAQ Region:</b> Raleigh					
<b>North Carolina Department of Environment and Natural Resources</b> <b>Division of Air Quality</b> <b>Air Pollutant Point Source Emissions Inventory - Calendar Year 2010</b>							
<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)			<b>ES-002-Boiler #7</b>				
<b>2. Emission Source Description</b>		<b>Coal / Natural Gas / No. 6 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit</b>					
<b>3. Operating Scenario Description</b>		<b>Operating Scenario #4 - No. 2 Fuel Oil</b>					
<b>4. Maximum Permitted Operating Rate</b> With Units (Ex. gal/hr, mmBtu/hr)		<b>323.17 MMBtu/hr</b>					
<b>5. Throughput in CY</b> (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		<b>59,172</b>	<b>gallons/yr</b>				
<b>6. Fuel Information</b> (if fuel used)		% Sulfur	<b>0.1%</b>				
		% Ash					
		Heat Content (Btu/lb or mmCF)	<b>139,144 Btu/gal</b>				
If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.							
<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)			<b>100%</b>				
<b>8. Control Device Information</b> , if none, write "none"							
	<b>Control Device ID #</b> (as listed in permit)	<b>Control Device Description</b>					
<i>i. (nearest stack)</i>	<b>CD-004</b>	<b>Bagfilter with Calcium Carbonate (CaCO<sub>3</sub>) Sorbent Injection</b>					
<i>ii.</i>	<b>N/A</b>	<b>N/A</b>					
<i>iii.</i>	<b>N/A</b>	<b>N/A</b>					
<i>iv.</i>	<b>N/A</b>	<b>N/A</b>					
<b>9. Stack Information</b> (sources vented to more than one stack use additional entry lines)							
<b>Stack ID #</b>	<b>Height</b> (in whole feet)	<b>Diameter (feet)</b> Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	<b>Temperature</b> (F)	<b>Velocity</b> (feet/sec)	<b>Volume Flow Rate</b> (acfm)	<b>Release Point Description</b> (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)	
<b>EP-14-136</b>	<b>220</b>	<b>9</b>	<b>305</b>	<b>56.1</b>	<b>214,000</b>	<b>Vertical</b>	
--	--	--	--	--	--	--	
--	--	--	--	--	--	--	
<b>10. Operating Schedule</b> (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	<b>24</b>	Days/Week	<b>7</b>	Weeks/Year	<b>50</b>	Hours/Year	<b>7,848 Total</b>
Typical Start & End Times in CY:				Start:	<b>N/A</b>	End:	<b>N/A</b>
<b>11. Seasonal Periods Percent Annual Throughput</b> (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	<b>100.00%</b>	Mar-May	<b>0.00%</b>	June-Aug	<b>0%</b>	Sept-Nov	<b>0.00%</b>

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

**Emission Source/Operating Scenario Data** Page 2 of 2  
**Boiler #7 - Operating Scenario #4 - No. 2 Fuel Oil**  
If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043  
 Permit #: 03069T28  
 County: Orange  
 DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.15	8	N/A
NOx	NOx	1.45	1	N/A
PM Total	PM	0.04	8	99.0%
PM-2.5	PM-2.5	0.01	8	99.0%
PM-10	PM-10	0.04	8	99.0%
SO2	SO2	0.76	1	90.00%
VOC	VOC	0.01	8	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Antimony	ANTIMONYPDS	0.00E+00	8	99.0%
Arsenic	ARSENICPDS	3.31E-04	8	99.0%
Benzene	71-43-2	1.63E-01	8	N/A
Beryllium	BERYLCPDS	2.49E-04	8	99.0%
Cadmium	CADMIUMPDS	2.49E-04	8	99.0%
Chromium	CROMCPDS	2.49E-04	8	99.0%
Chromium VI	CHROM6PDS	7.29E-05	8	99.0%
Cobalt	COBALTCPDS	0.00E+00	8	99.0%
Ethylbenzene	100-41-4	4.84E-02	8	N/A
Fluoride	16984-48-8	2.21	8	N/A
Formaldehyde	50-00-0	2.84	8	N/A
Lead	LEADCPDS	7.46E-04	8	99.0%
Manganese	MANGCPDS	4.97E-04	8	99.0%
Mercury	MERCPDS	2.49E-02	8	99.0%
Methyl chloroform	71-55-6	1.40E-02	8	N/A
Napthalene	91-20-3	0.020	8	N/A
Nickel	NICKCPDS	2.49E-04	8	99.0%
POM	POM	1.95E-03	8	99.0%
Selenium	SEC	1.24E-03	8	99.0%
Toluene	108-88-3	4.71	8	N/A
Xylene	1330-20-7	8.29E-02	8	N/A

Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	769.06	8	N/A
Methane	CH <sub>4</sub>	2.72E-02	8	N/A
Nitrous oxide	N <sub>2</sub> O	5.45E-03	8	N/A

**Emissions and data on this form required to report or verify emissions cannot be held confidential.**  
 To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>  
 Copy and Use additional Sheets as needed.

**Boiler #7 - Operating Scenario #1 - Coal**

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-002-Boiler #7					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #1 - Coal					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		45,952				tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	1.53%	% Ash	8.79%	Heat Content (Btu/lb or mmCF)	12,519 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8,154 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	38.42%	Mar-May	12.59%	June-Aug	21.51%	Sept-Nov	27.48%
------------------------------	--------	---------	--------	----------	--------	----------	--------

## Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	19.74	8	N/A
NOx	NOx	203.58	1	N/A
PM Total	PM	4.94	8	99.80%
PM-2.5	PM-2.5	2.85	8	97.90%
PM-10	PM-10	4.94	8	99.60%
SO2	SO2	106.73	1	90.00%
VOC	VOC	0.27	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	26.19	8	N/A
Acetophenone	98-86-2	0.69	8	N/A
Acrolein	107-02-8	13.33	8	N/A
Arsenic*	ARSENICPDS	0.35	8	99.60%
Benzene	71-43-2	59.74	8	N/A
Benzo(a)pyrene	50-32-8	1.75E-03	8	N/A
Benzyl chloride	100-44-7	32.17	8	N/A
Beryllium*	BERYLCPDS	0.06	8	N/A
Biphenyl	92-52-4	7.81E-02	8	N/A
Bis(2-ethylhexyl)phthalate (DEHP)	117-81-7	3.35	8	N/A
Bromine	7726-95-6	9.49	8	99.60%
Bromoform	75-25-2	1.79	8	N/A
Cadmium*	CADMIUMCPDS	1.61E-01	8	99.60%
Carbon disulfide	75-10-0	5.97	8	N/A
2-Chloroacetophenone	532-27-4	0.32	8	N/A
Chlorobenzene	108-90-7	1.01	8	N/A
Chloroform	67-66-3	2.71	8	N/A
Chromium*	CROMCPDS	5.56	8	99.60%
Chromium (VI)	CHROM6CPDS	0.01	8	99.60%
Cumene	98-82-8	0.24	8	N/A
Cyanide	CNC	114.88	8	N/A
Dibenzofurans	132-64-9	9.24E-03	8	N/A
Dimethyl sulfate	77-78-1	2.21	8	N/A
2,4-Dinitrotoluene	121-14-2	1.29E-02	8	N/A
Ethyl benzene	100-41-4	4.32	8	N/A
Ethyl chloride	75-00-3	1.93	8	N/A
Ethylene dibromide	106-93-4	5.51E-02	8	N/A
Ethylene dichloride	107-06-2	1.84	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

## Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

## North Carolina Department of Environment and Natural Resources

## Division of Air Quality

## Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Formaldehyde*	50-0-00	76.18	8	N/A
Hexane	HEXANEISO	3.08	8	N/A
Hydrogen Chloride *	7647-01-0	14818.81	8	N/A
Hydrogen Fluoride *	7664-39-3	266.28	8	90% Control with CaCO <sub>3</sub>
Isophorone	78-59-1	26.65	8	N/A
Lead*	LEADCPDS	2.04	8	99.60%
Manganese*	MANGCPDS	13.89	8	99.60%
Mercury*	MERCCPDS	0.97	8	N/A
Methyl bromide	74-83-9	7.35	8	N/A
Methyl chloride	74-87-3	24.35	8	N/A
Methyl ethyl ketone	78-93-3	17.92	8	N/A
Methyl hydrazine	60-34-4	7.81	8	N/A
Methyl methacrylate	80-62-6	0.92	8	N/A
Methyl tert butyl ether	1634-04-4	1.61	8	N/A
Methylene chloride	75-09-2	13.33	8	N/A
Naphthalene	91-20-3	0.60	8	N/A
Nickel	NICKCPDS	11.31	8	99.60%
Phenol	108-95-2	0.74	8	N/A
POM	POM	2.59	8	N/A
Propionaldehyde	123-38-6	17.46	8	N/A
Styrene	100-42-5	1.15	8	N/A
2,3,7,8-TCDD	1746-01-6	6.57E-07	8	N/A
Tetrachloroethylene	79-34-5	1.98	8	N/A
Toluene	108-88-3	11.03	8	N/A
1,1,1-Trichloroethane	79-00-5	0.92	8	N/A
Vinyl acetate	108-05-4	0.35	8	N/A
Xylenes	1330-20-7	1.70	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	136,573.59	8	N/A
Methane	CH <sub>4</sub>	0.22	8	N/A
Nitrous oxide	N <sub>2</sub> O	2.04	8	N/A

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2		<b>Facility ID #:</b> 6800043					
<b>Boiler #7 - Operating Scenario #2 - Natural Gas</b> <small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>		<b>Permit #:</b> 03069T28					
<b>Facility Name:</b> University of North Carolina at Chapel Hill		<b>County:</b> Orange					
		<b>DAQ Region:</b> Raleigh					
<b>North Carolina Department of Environment and Natural Resources</b> <b>Division of Air Quality</b> <b>Air Pollutant Point Source Emissions Inventory - Calendar Year 2010</b>							
<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)			<b>ES-002-Boiler #7</b>				
<b>2. Emission Source Description</b>		<b>Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit</b>					
<b>3. Operating Scenario Description</b>		<b>Operating Scenario #2 - Natural Gas</b>					
<b>4. Maximum Permitted Operating Rate</b> <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		<b>323.17 MMBtu/hr</b>					
<b>5. Throughput in CY</b> (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>		<b>43,777</b>	<b>1,000 ft<sup>3</sup>/yr</b>				
<b>6. Fuel Information</b> (if fuel used)		<b>% Sulfur</b> N/A	<b>% Ash</b> N/A				
		<b>Heat Content</b> (Btu/lb or mmCF)	<b>1,030 Btu/ft<sup>3</sup></b>				
<small>If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.</small>							
<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)			<b>100%</b>				
<b>8. Control Device Information</b> , if none, write "none"							
	<b>Control Device ID #</b> <small>(as listed in permit)</small>	<b>Control Device Description</b>					
<i>i. (nearest stack)</i>	<b>CD-004</b>	<b>Bagfilter with Calcium Carbonate (CaCO<sub>3</sub>) Sorbent Injection</b>					
<i>ii.</i>	N/A	N/A					
<i>iii.</i>	N/A	N/A					
<i>iv.</i>	N/A	N/A					
<b>9. Stack Information</b> (sources vented to more than one stack use additional entry lines)							
<b>Stack ID #</b>	<b>Height</b> <small>(in whole feet)</small>	<b>Diameter (feet)</b> <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	<b>Temperature</b> <small>(F)</small>	<b>Velocity</b> <small>(feet/sec)</small>	<b>Volume Flow Rate</b> <small>(acfm)</small>	<b>Release Point Description</b> <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>	
EP-14-136	220	9	305	56.1	214,000	Vertical	
--	--	--	--	--	--	--	
--	--	--	--	--	--	--	
<b>10. Operating Schedule</b> (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	7,848 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
<b>11. Seasonal Periods Percent Annual Throughput</b> (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	4.24%	Mar-May	6.44%	June-Aug	1.60%	Sept-Nov	87.72%

<b>Emission Source/Operating Scenario Data</b> Page 2 of 2 <i>Boiler #7 - Operating Scenario #2 - Natural Gas</i> <small>If Emission Source has multiple Operating Scenarios, complete one form for each.          (All permitted, Insignificant and/or Non-permitted Sources)</small>	Facility ID #: <u>6800043</u> Permit #: <u>03069T28</u> County: <u>Orange</u> DAQ Region: <u>Raleigh</u>
Facility Name: <u>University of North Carolina at Chapel Hill</u>	

**North Carolina Department of Environment and Natural Resources**  
**Division of Air Quality**  
**Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	1.84	8	N/A
NOx	NOx	7.93	1	N/A
PM Total	PM	0.17	8	N/A
PM-2.5	PM-2.5	0.17	8	N/A
PM-10	PM-10	0.17	8	N/A
SO2	SO2	0.00	1	N/A
VOC	VOC	0.12	8	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICCPDS	8.76E-03	8	N/A
Benzene	71-43-2	0.09	8	N/A
Cadmium	CADMIUMCPDS	4.82E-02	8	N/A
Chromium	CROMCPDS	6.13E-02	8	N/A
Chromium VI	CHROM6CPDS	6.13E-02	8	N/A
Dichlorobenzene	106-46-7	5.25E-02	8	N/A
Formaldehyde	50-00-0	3.28	8	N/A
Hexane	HEXANEISO	7.88E+01	8	N/A
Lead	LEADCPDS	2.19E-02	8	N/A
Manganese	MANGCPDS	1.66E-02	8	N/A
Mercury	MERCPDS	1.14E-02	8	N/A
Napthalene	91-20-3	2.67E-02	8	N/A
Nickel	NICKCPDS	0.09	8	N/A
POM	POM	2.90E-02	8	N/A
Toluene	108-88-3	0.15	8	N/A

Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	3,019.27	8	N/A
Methane	CH <sub>4</sub>	4.97E-02	8	N/A
Nitrous oxide	N <sub>2</sub> O	4.97E-03	8	N/A



**Boiler #7 - Operating Scenario #5 - Wood Pellets**  
 If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**  
 Permit #: **03069T28**  
 County: **Orange**  
 DAQ Region: **Raleigh**

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-002-Boiler #7					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #5 - Wood Pellets					
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		64.63 MMBtu/hr (20% HI from wood pellets)					
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>			0.0			tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	NA	% Ash	NA	Heat Content (Btu/lb or mmCF)	8,000 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO <sub>3</sub> ) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature <small>(F)</small>	Velocity <small>(feet/sec)</small>	Volume Flow Rate <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	#DIV/0!	Mar-May	#DIV/0!	June-Aug	#DIV/0!	Sept-Nov	#DIV/0!
------------------------------	---------	---------	---------	----------	---------	----------	---------

Boiler #7 - Operating Scenario #5 - Wood Pellets  
 If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.000	8	N/A
NOx	NOx	0.000	1	N/A
PM Total	PM	0.00000	8	99.80%
PM-2.5	PM-2.5	0.00000	8	97.90%
PM-10	PM-10	0.00000	8	99.60%
SO2	SO2	CEM w/coal	1	90.00%
VOC	VOC	0.0000	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	0.00E+00	8	N/A
Acetophenone	98-86-2	0.00E+00	8	N/A
Acrolein	107-02-8	0.00E+00	8	N/A
Antimony	7440-36-0	0.00E+00	8	99.60%
Arsenic	ARSENICPDS	0.00E+00	8	99.60%
Benzene	71-43-2	0.00E+00	8	N/A
Benzo(a)pyrene	50-32-8	0.00E+00	8	N/A
Beryllium	BERYLCPDS	0.00E+00	8	99.60%
Cadmium	CADMIUMCPDS	0.00E+00	8	99.60%
Carbon tetrachloride	56-23-5	0.00E+00	8	N/A
Chlorine	7782-50-5	0.00E+00	8	N/A
Chlorobenzene	108-90-7	0.00E+00	8	N/A
Chloroform	67-66-3	0.00E+00	8	N/A
Chromium	CROMCPDS	0.00E+00	8	99.60%
Cobalt	7440-48-4	0.00E+00	8	99.60%
Di(2-ethylhexy)phthalate		0.00E+00	8	N/A
Dinitrophenol, 2,4-	51-28-5	0.00E+00	8	N/A
Ethyl benzene	100-41-4	0.00E+00	8	N/A
Ethylene dichloride	107-06-2	0.00E+00	8	N/A
Formaldehyde*	50-0-00	0.00E+00	8	N/A
Hexachlorodib-dioxin	57653-85-7	0.00E+00	8	N/A
Hydrogen Chloride *	7647-01-0	0.00E+00	8	68% Control with CaCO <sub>3</sub>
Lead*	LEADCPDS	0.00E+00	8	99.60%
Manganese*	MANGCPDS	0.00E+00	8	99.60%
Mercury*	MERCCPDS	0.00E+00	8	92%
Methyl bromide	74-83-9	0.00E+00	8	N/A
Methyl chloride	74-87-3	0.00E+00	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

## Boiler #7 - Operating Scenario #5 - Wood Pellets

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Methyl chloroform	71-55-6	0.00E+00	8	N/A
Methyl ethyl ketone	78-93-3	0.00E+00	8	N/A
Methylene chloride	75-09-2	0.00E+00	8	N/A
Naphthalene	91-20-3	0.00E+00	8	N/A
Nickel	NICKCPDS	0.00E+00	8	99.60%
Nitrophenol, 4-	100-02-07	0.00E+00	8	N/A
Pentachlorophenol	87-86-5	0.00E+00	8	N/A
Perchloroethylene	127-18-4	0.00E+00	8	N/A
Phenol	108-95-2	0.00E+00	8	N/A
Phosphorus	7723-14-0	0.00E+00	8	99.60%
Polychlorinated biphenyls	1336-36-3	0.00E+00	8	N/A
POM	POM	0.00E+00	8	N/A
Propionaldehyde	123-38-6	0.00E+00	8	N/A
Propylene dichloride	78-87-5	0.00E+00	8	N/A
Selenium	7782-49-2	0.00E+00	8	99.60%
Styrene	100-42-5	0.00E+00	8	N/A
2,3,7,8-TCDD	1746-01-6	0.00E+00	8	N/A
Toluene	108-88-3	0.00E+00	8	N/A
Trichloroethylene	79-01-6	0.00E+00	8	N/A
Trichlorofluoromethane	75-69-4	0.00E+00	8	N/A
Trichlorophenol		0.00E+00	8	N/A
Vinyl chloride	75-01-4	0.00E+00	8	N/A
Xylenes	1330-20-7	0.00E+00	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	0.00	8	N/A
Methane	CH <sub>4</sub>	0.0000	8	N/A
Nitrous oxide	N <sub>2</sub> O	0.0000	8	N/A

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

**Boiler #7**

**(ES-002-Boiler #7)**

***Emissions Calculations***

SO<sub>2</sub>, NO<sub>x</sub>, and CO<sub>2</sub> Emissions are Taken from CEMs Data  
Other emission factors are from stack test or DAQ spreadsheets

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**  
**2010 Annual Emissions Inventory**  
**Boiler #7**  
**(ES-002-Boiler #7)**  
**Facility ID # 6800043**  
**Permit # 03069T28**

Operating Scenario #4 - No.2 Fuel Oil

<b>User Input</b>	
Company Name:	University of North Carolina at
Plant County:	Chapel Hill
Plant City:	Orange County
Permit Number:	Chapel Hill
User:	03069T28
Heat Input Capacity (mmBtu/hr):	RST Engineering
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	323.17
Annual Fuel Throughput (1000 gal):	2.31
Maximum fuel sulfur content (%):	59.172
Latest Construction/Modification Date:	0.1
	N/A
<b>Enter the boiler type below</b> ▾	
	15

<b>Boilers =&gt;100 mmBtu/hr</b> 1 = No. 6 oil fired, normal firing (U) 2 = No. 6 oil fired, normal firing (I) 3 = No. 6 oil fired, normal firing (C) 4 = No. 6 oil fired, normal firing, low NOx burner (U) 5 = No. 6 oil fired, normal firing, low NOx burner (I) 6 = No. 6 oil fired, normal firing, low NOx burner (C) 7 = No. 6 oil fired, tangential firing (U) 8 = No. 6 oil fired, tangential firing, low NOx burner (U) 9 = No. 5 oil fired, normal firing (U) 10 = No. 5 oil fired, normal firing (I) 11 = No. 5 oil fired, tangential firing (U) 12 = No. 4 oil fired, normal firing (U) 13 = No. 4 oil fired, normal firing (I) 14 = No. 4 oil fired, tangential firing (U) 15 = No. 2 oil fired (U,I)	<b>Boilers =&gt;100 mmBtu/hr (cont'd)</b> 16 = No. 2 oil fired (C) 17 = No. 2 oil fired, LNB/FGR (U,I) 18 = No. 2 oil fired, LNB/FGR (C)
	19 = Vertical fired utility boiler
	<b>Small Boilers (&lt;100 mmBtu/hr)</b> 20 = No. 6 oil fired (I) 21 = No. 6 oil fired (C) 22 = No. 5 oil fired (C) 23 = No. 4 oil fired (C) 24 = No. 2 oil fired (I) 25 = No. 2 oil fired (C)
	26 = Residential Furnace

**Emission Controls**

Particulate controls

<b>Enter the control type below</b> ▾	Message Area	Or enter a PM control efficiency below to override built in values.
	3	
Control Device	Avg. Cont. Effic.	User Input PM Cont. Effic.
0 = None/other		Message Area
1 = ESP		
2 = Scrubber		
3 = Bagfilter	99.0	
4 = Multiple cyclone		

Postcombustion SO<sub>2</sub> controls

<b>Enter the control type below</b> ▾	Message Area	Or enter an SO <sub>2</sub> control efficiency
---------------------------------------	--------------	--

0	below to override built in values.
<b>Control Technology/Process</b>	<b>User Input SO<sub>2</sub> Cont. Effic.</b>
0 = None/other	90.0
1 = Wet scrubber, Lime/limestone	<b>User entered control efficiency may be overestimated and should be documented.</b>
2 = Wet scrubber, Sodium carbonate	<b>Avg. Cont. Effic.</b>
3 = Wet scrubber, Magnesium oxide/hydroxide	0.0
4 = Wet scrubber, Dual alkali	<b>Remarks</b>
5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel	NA
6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity	
7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray	

NO<sub>x</sub> controls

<b>Enter the control type below</b> ▾	Message Area	Or enter a NO <sub>x</sub> control efficiency below to override built in values.
0		
<b>Control Technology/Process</b>	<b>User Input NO<sub>x</sub> Cont. Effic.</b>	
0 = None/other	0.0	
1 = Low excess air (LEA)	<b>Avg. Cont. Effic.</b>	Message Area
2 = Staged combustion (SC)	0.0	
3 = Burners out of service (BOOS)	<b>Remarks</b>	
4 = Flue gas recirculation (FGR)	NA	
5 = Flue gas recirculation plus staged combustion		
6 = Low NO <sub>x</sub> burners (LNB)		
7 = Reduced air preheat (RAP)		
8 = Selective noncatalytic reduction (SNCR)		
9 = Conventional selective catalytic reduction (SCR)		

**Emissions Output (for operation 6.79 hr/yr)**

<b>Criteria Pollutants</b>				<b>Emission Factor<sup>1</sup></b>
Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	(lb/10 <sup>3</sup> gal)
Total PM (FPM + CPM)	3.0	0.0391	78	3.30E+00
Filterable PM (FPM) rates @ 99% control	0.0	0.0006	1	2.00E+00
Condensable PM (CPM) <sup>4</sup>	3.0	0.0385	77	1.30E+00
Filterable PM-10 <sup>5</sup>	0.0	0.0003	1	1.00E+00
Filterable PM-2.5 <sup>5</sup>	0.0	0.0001	0	2.50E-01
NO <sub>x</sub> rates uncontrolled	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.0059	12	2.00E-01
CO	12	0.1479	296	5.00E+00
SO <sub>2</sub> rates @ 90% control	see attached CEMs-based calculations			2.98E+02
Total HAP <sup>6</sup>	4.17E-01	0.0053	11	1.81E-01
Largest HAP <sup>6</sup>	1.84E-01	0.0024	5	7.97E-02

<b>Toxic/Hazardous Air Pollutants.</b>				<b>Emission Factor<sup>1</sup></b>
Pollutant	lb/hr <sup>2</sup>	lb/day <sup>7</sup>	lb/yr <sup>3</sup>	(lb/10 <sup>3</sup> gal)
Antimony rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates @ 99% control	1.29E-05	NA	3.31E-04	5.60E-04
Benzene	6.35E-03	NA	1.63E-01	2.75E-03
Beryllium rates @ 99% control	9.70E-06	NA	2.49E-04	4.20E-04
Cadmium rates @ 99% control	9.70E-06	NA	2.49E-04	4.20E-04
Chromium rates @ 99% control	9.70E-06	NA	2.49E-04	4.20E-04
Chromium VI rates @ 99% control	2.85E-06	NA	7.29E-05	1.23E-04
Cobalt rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.89E-03	NA	4.84E-02	8.17E-04
Fluoride	8.61E-02	2.07E+00	2.21E+00	3.73E-02
Formaldehyde	1.11E-01	2.66E+00	2.84E+00	4.80E-02
Lead rates @ 99% control	2.91E-05	NA	7.46E-04	1.26E-03
Manganese rates @ 99% control	1.94E-05	4.65E-04	4.97E-04	8.40E-04
Mercury	9.70E-04	2.33E-02	2.49E-02	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.45E-04	1.31E-02	1.40E-02	2.36E-04
Napthalene	7.69E-04	NA	1.97E-02	3.33E-04
Nickel rates @ 99% control	9.70E-06	2.33E-04	2.49E-04	4.20E-04
POM rates @ 99% control	7.62E-05	NA	1.95E-03	3.30E-03
Selenium rates @ 99% control	4.85E-05	NA	1.24E-03	2.10E-03

Toluene	1.84E-01	4.41E+00	4.71E+00	7.97E-02
Xylene	3.23E-03	7.76E-02	8.29E-02	1.40E-03

Greenhouse Gases				Emission Factor (lb/10 <sup>3</sup> gal)
Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	
Carbon dioxide	see attached CEMs-based calculations			22687.74
Methane	2.12E+00	2.72E-02	5.45E+01	0.920
Nitrous Oxide	4.25E-01	5.45E-03	1.09E+01	0.18

<sup>1</sup>Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

<sup>2</sup>Hourly emission rates for all pollutants are based on hourly rated capacity.

<sup>3</sup>Annual emission rates for all pollutants are based on maximum annual fuel throughput.

<sup>4</sup>Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

<sup>5</sup>AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

<sup>6</sup>Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

<sup>7</sup>Daily emission rates are based on operation 24 hours per day at rated capacity.

# Bituminous Coal Combustion

2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

## Data Input

Maximum Heat Input	<input type="text" value="323.17"/>	mmBtu/hr	<b>Boiler Type:</b>	<input type="text" value="7"/>
Boiler Size/Type	Large Industrial		1) Pulverized/Dry Bottom	6) Underfeed Stoker
Actual Fuel Usage	<input type="text" value="45,952"/>	ton/yr	2) Pulverized/Wet Bottom	7) Fluidized Bed Cir.
or	or		3) Cyclone Furnace	8) Fluidized Bed Bub.
Hours of Operation	<input type="text"/>	hr/yr	4) Spreader Stoker	9) Hand Fed
and	and		<b>Control Device Efficiencies:</b>	
Heating Value	<input type="text" value="12,597"/>	Btu/lb	PM	<input type="text" value="99.80"/> %
		ton/yr	PM-10	<input type="text" value="98.00"/> %
Sulfur Content	<input type="text" value="1.34"/>	%	PM-2.5	<input type="text" value="97.90"/> %
Ash Content :	<input type="text" value="10.7"/>	%	SOx*	<input type="text" value="90.00"/> %
(B)ituminous or (S)ubbituminous?	<input type="text" value="B"/>	(B/S)	NOx*	<input type="text" value="0.00"/> %
Calcium to Sulfur Ratio	<input type="text" value="2.22"/>		<p><i>*SOx and NOx emission estimates were calculated using CEMS data. Please refer to the SOx and NOX emissions data presented in the following CEMs spreadsheets.                      HCl, HF, and Hg emissions based on stack test data.</i></p>	



# Bituminous Coal Combustion

2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

## ACTUAL CRITERIA EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
PM*	0.21	2.73	9,876	4.94
PM-10*	0.21	2.73	9,876	4.94
PM-2.5*	0.12	1.58	5,694	2.85
SO2	11.66	**	**	**
SO3	0.08	**	**	**
NOx	3.90	**	**	**
VOC*	0.01	0.15	533	0.27
CO*	0.86	11.02	39,478	19.74

## ACTUAL TOXIC EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Acetaldehyde	5.70E-04	7.31E-03	2.62E+01	1.31E-02
Acetophenone	1.50E-05	1.92E-04	6.89E-01	3.45E-04
Acrolein	2.90E-04	3.72E-03	1.33E+01	6.66E-03
Antimony*	8.14E-06	1.04E-04	3.74E-01	1.87E-04
Arsenic*	7.58E-06	9.73E-05	3.48E-01	1.74E-04
Benzene	1.30E-03	1.67E-02	5.97E+01	2.99E-02
Benzo(a)pyrene	3.80E-08	4.87E-07	1.75E-03	8.73E-07
Benzyl chloride	7.00E-04	8.98E-03	3.22E+01	1.61E-02
Beryllium*	1.33E-06	1.71E-05	6.11E-02	3.06E-05
Biphenyl	1.70E-06	2.18E-05	7.81E-02	3.91E-05
Bis(2-ethylhexyl)phthalate (DEHP)	7.30E-05	9.36E-04	3.35E+00	1.68E-03
Bromine	1.03E-01	2.65E-03	9.49E+00	4.75E-03
Bromoforn	3.90E-05	5.00E-04	1.79E+00	8.96E-04
Cadmium*	3.50E-06	4.49E-05	1.61E-01	8.05E-05
Carbon disulfide	1.30E-04	1.67E-03	5.97E+00	2.99E-03
2-Chloroacetophenone	7.00E-06	8.98E-05	3.22E-01	1.61E-04
Chlorobenzene	2.20E-05	2.82E-04	1.01E+00	5.05E-04
Chlorine*	2.72E-03	3.49E-02	1.25E+02	6.25E-02
Chloroform	5.90E-05	7.57E-04	2.71E+00	1.36E-03
Chromium*	1.21E-04	1.55E-03	5.56E+00	2.78E-03
Chromium (VI)	1.21E-04	3.10E-06	1.11E-02	5.56E-06
Cobalt*	6.95E-06	8.92E-05	3.20E-01	1.60E-04
Cumene	5.30E-06	6.80E-05	2.44E-01	1.22E-04
Cyanide	2.50E-03	3.21E-02	1.15E+02	5.74E-02
Dibenzofurans	2.01E-07	2.58E-06	9.24E-03	4.62E-06
Dimethyl sulfate	4.80E-05	6.16E-04	2.21E+00	1.10E-03
2,4-Dinitrotoluene	2.80E-07	3.59E-06	1.29E-02	6.43E-06
Ethyl benzene	9.40E-05	1.21E-03	4.32E+00	2.16E-03
Ethyl chloride	4.20E-05	5.39E-04	1.93E+00	9.65E-04
Ethylene dibromide	1.20E-06	1.54E-05	5.51E-02	2.76E-05
Ethylene dichloride	4.00E-05	5.13E-04	1.84E+00	9.19E-04
Formaldehyde*	1.66E-03	2.13E-02	7.62E+01	3.81E-02
Hexane	6.70E-05	8.59E-04	3.08E+00	1.54E-03
Hydrogen Chloride *	3.22E-01	4.14E+00	1.48E+04	7.41E+00
Hydrogen Fluoride *	5.79E-03	7.43E-02	2.66E+02	1.33E-01
Isophorone	5.80E-04	7.44E-03	2.67E+01	1.33E-02
Lead*	4.43E-05	5.69E-04	2.04E+00	1.02E-03

\*\*SO<sub>2</sub> and NOx emissions were estimated using CEMS data, please refer to the attached data sheets entitled "Sulfur Dioxide Emissions from Boiler #7" and Nitrogen Dioxide Emissions from Boiler #7".

# Bituminous Coal Combustion

## 2010 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**  
 City **Chapel Hill**  
 County **Orange County**

APP #/Fac ID **6800043**  
 Input By **RST Engineering**  
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

### ACTUAL TOXIC EMISSIONS (continued)

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
<i>Manganese*</i>	<i>3.02E-04</i>	<i>3.88E-03</i>	<i>1.39E+01</i>	<i>6.95E-03</i>
<i>Mercury*</i>	<i>2.11E-05</i>	<i>2.70E-04</i>	<i>9.69E-01</i>	<i>4.85E-04</i>
Methyl bromide	1.60E-04	2.05E-03	7.35E+00	3.68E-03
Methyl chloride	5.30E-04	6.80E-03	2.44E+01	1.22E-02
Methyl ethyl ketone	3.90E-04	5.00E-03	1.79E+01	8.96E-03
Methyl hydrazine	1.70E-04	2.18E-03	7.81E+00	3.91E-03
Methyl methacrylate	2.00E-05	2.57E-04	9.19E-01	4.60E-04
Methyl tert butyl ether	3.50E-05	4.49E-04	1.61E+00	8.04E-04
Methylene chloride	2.90E-04	3.72E-03	1.33E+01	6.66E-03
Naphthalene	1.30E-05	1.67E-04	5.97E-01	2.99E-04
<i>Nickel*</i>	<i>2.46E-04</i>	<i>3.16E-03</i>	<i>1.13E+01</i>	<i>5.66E-03</i>
Phenol	1.60E-05	2.05E-04	7.35E-01	3.68E-04
<i>Phosphorus*</i>	<i>3.68E-05</i>	<i>4.72E-04</i>	<i>1.69E+00</i>	<i>8.45E-04</i>
POM	5.64E-05	7.24E-04	2.59E+00	1.30E-03
Propionaldehyde	3.80E-04	4.87E-03	1.75E+01	8.73E-03
<i>Selenium*</i>	<i>5.42E-06</i>	<i>6.95E-05</i>	<i>2.49E-01</i>	<i>1.24E-04</i>
Styrene	2.50E-05	3.21E-04	1.15E+00	5.74E-04
2,3,7,8-TCDD	1.43E-11	1.83E-10	6.57E-07	3.29E-10
Tetrachloroethylene	4.30E-05	5.52E-04	1.98E+00	9.88E-04
Toluene	2.40E-04	3.08E-03	1.10E+01	5.51E-03
1,1,1-Trichloroethane	2.00E-05	2.57E-04	9.19E-01	4.60E-04
Vinyl acetate	7.60E-06	9.75E-05	3.49E-01	1.75E-04
Xylenes	3.70E-05	4.75E-04	1.70E+00	8.50E-04
Total HAPs		4.39	15,737.65	7.87

### Greenhouse Gases

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Carbon dioxide			see attached CEMs-based calculations	
<i>Methane*</i>	<i>0.010</i>	<i>0.12</i>	439.93	0.22
Nitrous Oxide	0.09	1.14	4,084	2.04

\*Emission rates for pollutants in italics from August 2009 Section 114 test of Boiler #6.

#### Notes :

- 1) Emission factors are from Supplement B to the 5th edition of AP-42, unless otherwise noted
- 2) Emission calculations will be based on the hours of operation only when actual fuel usage is not supplied
- 3) Particulate controls affect PM, PM-10, PM-2.5, and all toxics that are regulated as particulates except Mercury
- 4) VOC = NMTOC = TOC \* (1-%METHANE)
- 5) PM-2.5 and SO3 do not currently need to be reported
- 6) Dibenzofurans = Polychlorinated dibenzo-p-furans
- 7) The Br emission factor is based on a mass balance generated from a 3 year coal analysis for Duke Power (1990-1992, 7 samples per year). The average concentration of bromine was 55.33 ppm (wet basis) and a heating value of 13,500 Btu/lb was assumed
- 8) For fluidized bed combustion the emission factor for underfeed stokers is utilized whenever the calcium-to-sulfur ratio is outside of the acceptable range of 1.5 to 7

**Natural Gas Combustion Emissions Calculator NG2000 Revision C**  
**2010 Annual Emissions Inventory**  
**Boiler #7**  
*(ES-002-Boiler #7)*

Facility ID # 6800043  
 Permit # 03069T28

**Operating Scenario #2**

<b>User Input</b>	<b>Emissions Output (for operation 19.22 hr/yr)</b>																																																																																																																																																																					
<p>Company Name: <b>University of North Carolina at Chapel Hill</b></p> <p>Plant County: <b>Orange County</b></p> <p>Plant City: <b>Chapel Hill</b></p> <p>Permit Number: <b>03069T28</b></p> <p>User: <b>RST Engineering</b></p> <p>Heat Input Capacity (mmBtu/hr): <b>323.17</b></p> <p>Fuel Input Capacity (10<sup>6</sup> scf/hr): <b>0.32</b></p> <p>Annual Fuel Throughput (10<sup>6</sup> scf): <b>43.78</b></p> <p>Latest Construction/Modification Date: <b>N/A</b></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4"><b>Criteria Pollutants</b></th> <th style="text-align: center;">Emission Factor (lb/mmMscf)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> <th></th> </tr> </thead> <tbody> <tr> <td>PM</td> <td>2.4E+00</td> <td>3.3E+02</td> <td>1.7E-01</td> <td style="color: green;">7.6E+00</td> </tr> <tr> <td>PM-10</td> <td>2.4E+00</td> <td>3.3E+02</td> <td>1.7E-01</td> <td style="color: green;">7.6E+00</td> </tr> <tr> <td>PM-2.5</td> <td>2.4E+00</td> <td>3.3E+02</td> <td>1.7E-01</td> <td style="color: green;">7.6E+00</td> </tr> <tr> <td>NOx</td> <td colspan="3">see attached CEMs-based calculations</td> <td style="color: green;">1.9E+02</td> </tr> <tr> <td>VOC</td> <td>1.7E+00</td> <td>2.4E+02</td> <td>1.2E-01</td> <td style="color: green;">5.5E+00</td> </tr> <tr> <td>CO</td> <td>2.7E+01</td> <td>3.7E+03</td> <td>1.8E+00</td> <td style="color: green;">8.4E+01</td> </tr> <tr> <td>SO2</td> <td colspan="3">see attached CEMs-based calculations</td> <td style="color: green;">6.0E-01</td> </tr> <tr> <td>Total HAP</td> <td>6.0E-01</td> <td>8.3E+01</td> <td>4.1E-02</td> <td style="color: green;">1.9E+00</td> </tr> <tr> <td>Largest HAP</td> <td>5.7E-01</td> <td>7.9E+01</td> <td>3.9E-02</td> <td style="color: green;">1.8E+00</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5"><b>Toxic/Hazardous Air Pollutants</b></th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/day</th> <th>lb/yr</th> <th></th> </tr> </thead> <tbody> <tr> <td>Arsenic</td> <td>6.3E-05</td> <td>NA</td> <td>8.8E-03</td> <td style="color: green;">2.0E-04</td> </tr> <tr> <td>Benzene</td> <td>6.7E-04</td> <td>NA</td> <td>9.2E-02</td> <td style="color: green;">2.1E-03</td> </tr> <tr> <td>Cadmium</td> <td>3.5E-04</td> <td>NA</td> <td>4.8E-02</td> <td style="color: green;">1.1E-03</td> </tr> <tr> <td>Chromium</td> <td style="color: red;">4.4E-04</td> <td style="color: red;">NA</td> <td style="color: red;">6.1E-02</td> <td style="color: green;">1.4E-03</td> </tr> <tr> <td>Chromium VI</td> <td style="color: red;">4.4E-04</td> <td style="color: red;">NA</td> <td style="color: red;">6.1E-02</td> <td style="color: green;">1.4E-03</td> </tr> <tr> <td>Dichlorobenzene</td> <td>3.8E-04</td> <td>NA</td> <td>5.3E-02</td> <td style="color: green;">1.2E-03</td> </tr> <tr> <td>Formaldehyde</td> <td>2.4E-02</td> <td>NA</td> <td>3.3E+00</td> <td style="color: green;">7.5E-02</td> </tr> <tr> <td>Hexane</td> <td>5.7E-01</td> <td>1.4E+01</td> <td>7.9E+01</td> <td style="color: green;">1.8E+00</td> </tr> <tr> <td>Lead</td> <td style="color: red;">1.6E-04</td> <td style="color: red;">NA</td> <td style="color: red;">2.2E-02</td> <td style="color: green;">5.0E-04</td> </tr> <tr> <td>Manganese</td> <td>1.2E-04</td> <td>2.9E-03</td> <td>1.7E-02</td> <td style="color: green;">3.8E-04</td> </tr> <tr> <td>Mercury</td> <td>8.2E-05</td> <td>2.0E-03</td> <td>1.1E-02</td> <td style="color: green;">2.6E-04</td> </tr> <tr> <td>Naphthalene</td> <td style="color: red;">1.9E-04</td> <td style="color: red;">NA</td> <td style="color: red;">2.7E-02</td> <td style="color: green;">6.1E-04</td> </tr> <tr> <td>Nickel</td> <td>6.7E-04</td> <td>1.6E-02</td> <td>9.2E-02</td> <td style="color: green;">2.1E-03</td> </tr> <tr> <td>POM</td> <td style="color: red;">2.1E-04</td> <td style="color: red;">NA</td> <td style="color: red;">2.9E-02</td> <td style="color: green;">6.6E-04</td> </tr> <tr> <td>Toluene</td> <td>1.1E-03</td> <td>2.6E-02</td> <td>1.5E-01</td> <td style="color: green;">3.4E-03</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4"><b>Greenhouse Gas Pollutants</b></th> <th style="text-align: center;">Em. Factor (lb/mmBtu)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> <th></th> </tr> </thead> <tbody> <tr> <td>Carbon dioxide</td> <td colspan="3">see attached CEMs-based calculations</td> <td style="color: green;">116.89</td> </tr> <tr> <td>Methane</td> <td>0.71</td> <td>99.41</td> <td>4.97E-02</td> <td style="color: green;">2.20E-03</td> </tr> <tr> <td>Nitrous Oxide</td> <td>0.071</td> <td>9.94</td> <td>4.97E-03</td> <td style="color: green;">2.20E-04</td> </tr> </tbody> </table>	<b>Criteria Pollutants</b>				Emission Factor (lb/mmMscf)	Pollutant	lb/hr	lb/yr	tpy		PM	2.4E+00	3.3E+02	1.7E-01	7.6E+00	PM-10	2.4E+00	3.3E+02	1.7E-01	7.6E+00	PM-2.5	2.4E+00	3.3E+02	1.7E-01	7.6E+00	NOx	see attached CEMs-based calculations			1.9E+02	VOC	1.7E+00	2.4E+02	1.2E-01	5.5E+00	CO	2.7E+01	3.7E+03	1.8E+00	8.4E+01	SO2	see attached CEMs-based calculations			6.0E-01	Total HAP	6.0E-01	8.3E+01	4.1E-02	1.9E+00	Largest HAP	5.7E-01	7.9E+01	3.9E-02	1.8E+00	<b>Toxic/Hazardous Air Pollutants</b>					Pollutant	lb/hr	lb/day	lb/yr		Arsenic	6.3E-05	NA	8.8E-03	2.0E-04	Benzene	6.7E-04	NA	9.2E-02	2.1E-03	Cadmium	3.5E-04	NA	4.8E-02	1.1E-03	Chromium	4.4E-04	NA	6.1E-02	1.4E-03	Chromium VI	4.4E-04	NA	6.1E-02	1.4E-03	Dichlorobenzene	3.8E-04	NA	5.3E-02	1.2E-03	Formaldehyde	2.4E-02	NA	3.3E+00	7.5E-02	Hexane	5.7E-01	1.4E+01	7.9E+01	1.8E+00	Lead	1.6E-04	NA	2.2E-02	5.0E-04	Manganese	1.2E-04	2.9E-03	1.7E-02	3.8E-04	Mercury	8.2E-05	2.0E-03	1.1E-02	2.6E-04	Naphthalene	1.9E-04	NA	2.7E-02	6.1E-04	Nickel	6.7E-04	1.6E-02	9.2E-02	2.1E-03	POM	2.1E-04	NA	2.9E-02	6.6E-04	Toluene	1.1E-03	2.6E-02	1.5E-01	3.4E-03	<b>Greenhouse Gas Pollutants</b>				Em. Factor (lb/mmBtu)	Pollutant	lb/hr	lb/yr	tpy		Carbon dioxide	see attached CEMs-based calculations			116.89	Methane	0.71	99.41	4.97E-02	2.20E-03	Nitrous Oxide	0.071	9.94	4.97E-03	2.20E-04
<b>Criteria Pollutants</b>				Emission Factor (lb/mmMscf)																																																																																																																																																																		
Pollutant	lb/hr	lb/yr	tpy																																																																																																																																																																			
PM	2.4E+00	3.3E+02	1.7E-01	7.6E+00																																																																																																																																																																		
PM-10	2.4E+00	3.3E+02	1.7E-01	7.6E+00																																																																																																																																																																		
PM-2.5	2.4E+00	3.3E+02	1.7E-01	7.6E+00																																																																																																																																																																		
NOx	see attached CEMs-based calculations			1.9E+02																																																																																																																																																																		
VOC	1.7E+00	2.4E+02	1.2E-01	5.5E+00																																																																																																																																																																		
CO	2.7E+01	3.7E+03	1.8E+00	8.4E+01																																																																																																																																																																		
SO2	see attached CEMs-based calculations			6.0E-01																																																																																																																																																																		
Total HAP	6.0E-01	8.3E+01	4.1E-02	1.9E+00																																																																																																																																																																		
Largest HAP	5.7E-01	7.9E+01	3.9E-02	1.8E+00																																																																																																																																																																		
<b>Toxic/Hazardous Air Pollutants</b>																																																																																																																																																																						
Pollutant	lb/hr	lb/day	lb/yr																																																																																																																																																																			
Arsenic	6.3E-05	NA	8.8E-03	2.0E-04																																																																																																																																																																		
Benzene	6.7E-04	NA	9.2E-02	2.1E-03																																																																																																																																																																		
Cadmium	3.5E-04	NA	4.8E-02	1.1E-03																																																																																																																																																																		
Chromium	4.4E-04	NA	6.1E-02	1.4E-03																																																																																																																																																																		
Chromium VI	4.4E-04	NA	6.1E-02	1.4E-03																																																																																																																																																																		
Dichlorobenzene	3.8E-04	NA	5.3E-02	1.2E-03																																																																																																																																																																		
Formaldehyde	2.4E-02	NA	3.3E+00	7.5E-02																																																																																																																																																																		
Hexane	5.7E-01	1.4E+01	7.9E+01	1.8E+00																																																																																																																																																																		
Lead	1.6E-04	NA	2.2E-02	5.0E-04																																																																																																																																																																		
Manganese	1.2E-04	2.9E-03	1.7E-02	3.8E-04																																																																																																																																																																		
Mercury	8.2E-05	2.0E-03	1.1E-02	2.6E-04																																																																																																																																																																		
Naphthalene	1.9E-04	NA	2.7E-02	6.1E-04																																																																																																																																																																		
Nickel	6.7E-04	1.6E-02	9.2E-02	2.1E-03																																																																																																																																																																		
POM	2.1E-04	NA	2.9E-02	6.6E-04																																																																																																																																																																		
Toluene	1.1E-03	2.6E-02	1.5E-01	3.4E-03																																																																																																																																																																		
<b>Greenhouse Gas Pollutants</b>				Em. Factor (lb/mmBtu)																																																																																																																																																																		
Pollutant	lb/hr	lb/yr	tpy																																																																																																																																																																			
Carbon dioxide	see attached CEMs-based calculations			116.89																																																																																																																																																																		
Methane	0.71	99.41	4.97E-02	2.20E-03																																																																																																																																																																		
Nitrous Oxide	0.071	9.94	4.97E-03	2.20E-04																																																																																																																																																																		
<p><b>Enter the boiler type below</b> ▾</p> <p style="text-align: right; color: blue;">2</p>																																																																																																																																																																						
<p><b>Other NOx Control</b></p> <p style="text-align: right; color: blue;">4</p>																																																																																																																																																																						
<p><b>Large Wall-Fired Boilers (=&gt;100 mmBtu/hr)</b></p> <p>1 = Uncontrolled (Pre-NSPS)</p> <p>2 = Uncontrolled (Post-NSPS)</p> <p>3 = Controlled - Low NOx burners</p> <p>4 = Controlled - Flue gas recirculation (FGR)</p>																																																																																																																																																																						
<p><b>Small Boilers (&lt;100 mmBtu/hr)</b></p> <p>5 = Uncontrolled</p> <p>6 = Controlled - Low NOx burners</p> <p>7 = Controlled - Low NOx burners/FGR</p>																																																																																																																																																																						
<p><b>Tangential-Fired Boilers (All Sizes)</b></p> <p>8 = Uncontrolled</p> <p>9 = Controlled - FGR</p>																																																																																																																																																																						
<p><b>Residential Furnaces (&lt;0.3 mmBtu/hr)</b></p> <p>10 = Uncontrolled</p>																																																																																																																																																																						

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

2010 Annual Emissions Inventory

Revise per Stk Test

## Boiler # 7 Wood Pellet Combustion

0.0 ton/yr, wood pellets burned                      0.00E+00 MMBtu/yr  
 64.63 MMBtu/hr, HI from wood                      99.8% PM control                      99.6% Metals control  
 8,000 Btu/lb, wood heating value                      67.8% HCl efficiency\*  
 4.04 ton/hr, max. wood firing rate                      92.3% Hg efficiency\*  
 8,760 hr/yr                      \*Calculated from August 2009 EPA Tests

Pollutant	Emission Factor (lb/MMBtu) <sup>1</sup>	Emissions (lb/hr)	Emissions (lb/yr)	Emissions (ton/yr)
<b>NOx</b>	see attached CEMs-based calculations			
<b>CO</b>	0.17	10.99	0.0	0.00
<b>SO<sub>2</sub></b>	see attached CEMs-based calculations			
PM	0.417	0.054	0.00	0.00000
PM <sub>10</sub>	0.377	0.049	0.00	0.00000
PM <sub>2.5</sub>	0.327	0.042	0.00	0.00000
VOC	0.017	1.10	0.0	0.000
	<b>lb/MMBtu</b>			
Acetaldehyde	8.30E-04	5.36E-02	0.00E+00	0.00E+00
Acetophenone	3.20E-09	2.07E-07	0.00E+00	0.00E+00
Acrolein	4.00E-03	2.59E-01	0.00E+00	0.00E+00
Antimony	7.90E-06	2.04E-06	0.00E+00	0.00E+00
Arsenic	2.20E-05	5.69E-06	0.00E+00	0.00E+00
Benzene	4.20E-03	2.71E-01	0.00E+00	0.00E+00
Benzo(a)pyrene	2.60E-06	1.68E-04	0.00E+00	0.00E+00
Beryllium	1.10E-06	2.84E-07	0.00E+00	0.00E+00
Cadmium	4.10E-06	1.06E-06	0.00E+00	0.00E+00
Carbon tetrachloride	4.50E-05	2.91E-03	0.00E+00	0.00E+00
Chlorine	7.90E-04	5.11E-02	0.00E+00	0.00E+00
Chlorobenzene	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Chloroform	2.80E-05	1.81E-03	0.00E+00	0.00E+00
Chromium	1.75E-05	4.52E-06	0.00E+00	0.00E+00
Cobalt	6.50E-06	1.68E-06	0.00E+00	0.00E+00
Di(2-ethylhexyl)phthalate	4.70E-08	3.04E-06	0.00E+00	0.00E+00
Dinitrophenol, 2,4-	1.80E-07	1.16E-05	0.00E+00	0.00E+00
Ethyl Benzene	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Ethylene dichloride	2.90E-05	1.87E-03	0.00E+00	0.00E+00
Formaldehyde	4.40E-03	2.84E-01	0.00E+00	0.00E+00
Hexachlorodibenzo-p-dioxin	1.60E-06	1.03E-04	0.00E+00	0.00E+00
<b>Hydrogen Chloride</b>	1.90E-02	3.95E-01	0.00E+00	0.00E+00
Lead	4.80E-05	1.24E-05	0.00E+00	0.00E+00
Manganese	1.60E-03	4.14E-04	0.00E+00	0.00E+00
<b>Mercury</b>	3.50E-06	1.74E-05	0.00E+00	0.00E+00
Methyl bromide	1.50E-05	9.70E-04	0.00E+00	0.00E+00
Methyl chloride	2.30E-05	1.49E-03	0.00E+00	0.00E+00
Methyl chloroform	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Methyl ethyl ketone	5.40E-06	3.49E-04	0.00E+00	0.00E+00
Methylene chloride	2.90E-04	1.87E-02	0.00E+00	0.00E+00
Naphthalene	9.70E-05	6.27E-03	0.00E+00	0.00E+00
Nickel	3.30E-05	8.53E-06	0.00E+00	0.00E+00
Nitrophenol, 4-	1.10E-07	7.11E-06	0.00E+00	0.00E+00
Pentachlorophenol	5.10E-08	3.30E-06	0.00E+00	0.00E+00
Perchloroethylene	3.80E-05	2.46E-03	0.00E+00	0.00E+00
Phenol	5.10E-05	3.30E-03	0.00E+00	0.00E+00
Phosphorus	2.70E-05	6.98E-06	0.00E+00	0.00E+00
Polychlorinated biphenyls	8.15E-09	5.27E-07	0.00E+00	0.00E+00
POM	1.25E-04	8.08E-03	0.00E+00	0.00E+00
Propionaldehyde	6.10E-05	3.94E-03	0.00E+00	0.00E+00
Propylene dichloride	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Selenium	2.80E-06	7.24E-07	0.00E+00	0.00E+00
Styrene	1.90E-03	1.23E-01	0.00E+00	0.00E+00
2,3,7,8-TCDD	8.60E-12	5.56E-10	0.00E+00	0.00E+00
Toluene	9.20E-04	5.95E-02	0.00E+00	0.00E+00
Trichloroethylene	3.00E-05	1.94E-03	0.00E+00	0.00E+00
Trichlorofluoromethane	4.10E-05	2.65E-03	0.00E+00	0.00E+00
Trichlorophenol	2.20E-08	1.42E-06	0.00E+00	0.00E+00
Vinyl chloride	1.80E-05	1.16E-03	0.00E+00	0.00E+00
Xylenes	2.50E-05	1.62E-03	0.00E+00	0.00E+00
Carbon Dioxide	see attached CEMs-based calculations			
Methane	0.0705	4.557	0.0	0.0000
N <sub>2</sub> O	0.00926	0.60	0.0	0.0000

1-Emission factors based on DAQ wood combustion spreadsheet

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Sulfur Dioxide Emissions from Boiler #7 (ES-002-Boiler #7)

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for SO<sub>2</sub> emissions.

For the 2010 calendar year, 30 day facility averages for the SO<sub>2</sub> emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2010	0.18
February 2010	0.18
March 2010	0.18
April 2010	0.18
May 2010	0.18
June 2010	0.18
July 2010	0.18
August 2010	0.18
September 2010	0.18
October 2010	0.19
November 2010	0.16
December 2010	0.16
<b>Annual Average</b>	<b>0.178</b>

This average includes SO<sub>2</sub> emissions from coal, fuel oil, wood, and natural gas from Boiler #7 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #7 for 2010

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
45,952	43,777	59,172	0.0
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.16E+06	4.51E+04	8.23E+03	0

Total for Boiler #7 (MMBtu/yr)	1.21E+06
--------------------------------	----------

Total SO <sub>2</sub> Emissions from Boiler #7 (lb/yr)	214,976
<b>Total SO<sub>2</sub> Emissions from Boiler #7 (ton/yr)</b>	<b>107.488</b>

SO <sub>2</sub> Emissions Associated with Coal Combustion (ton/yr)	106.73
SO <sub>2</sub> Emissions Associated with No. 2 Fuel Oil Combustion (ton/yr)	0.75898
SO <sub>2</sub> Emissions Associated with Natural Gas Combustion (ton/yr)	0*
SO <sub>2</sub> Emissions Associated with Wood Pellet Combustion (ton/yr)	0*

\*All SO<sub>2</sub> measured by CEMS allocated to coal and No.2 fuel oil.

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Nitrogen Dioxide Emissions from Boiler #7

#### (ES-002-Boiler #7)

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2010 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2010	0.40
February 2010	0.43
March 2010	0.41
April 2010	0.39
May 2010	0.32
June 2010	0.31
July 2010	0.23
August 2010	0.26
September 2010	0.30
October 2010	0.31
November 2010	0.39
December 2010	0.47
<b>Annual Average</b>	<b>0.35</b>

This average includes NOx emissions from coal, fuel oil, wood, and natural gas within Boiler #7 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #7 for 2010

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
45,952	43,777	59,172	0.0
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.16E+06	4.51E+04	8.23E+03	0

Total for Boiler #7 (MMBtu/yr)	1.21E+06
--------------------------------	----------

NOx Emissions from Boiler #7 (lb/yr)	425,916
<b>NOx Emissions from Boiler #7 (ton/yr)</b>	<b>212.96</b>

NOx Emissions Associated with Coal Combustion (ton/yr)	203.58
NOx Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	1.45
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	7.93
NOx Emissions Associated with Wood Pellet Combustion (ton/yr)	0.0

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### CO<sub>2</sub> Emissions from Boiler No.7 (ES-3)

The exhaust system on Boiler #7 is equipped with a continuous emissions monitor (CEMs) for CO<sub>2</sub> concentrations. The exhaust also includes a flow monitor. Mass CO<sub>2</sub> emissions are calculated by the DAHS for GHG reporting. For the 2010 calendar year, the monthly CO<sub>2</sub> emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2010	15,798	17,414
February 2010	16,017	17,656
March 2010	6,514	7,180
April 2010	611	674
May 2010	8,532	9,405
June 2010	6,017	6,633
July 2010	11,281	12,435
August 2010	9,422	10,386
September 2010	13,131	14,474
October 2010	11,997	13,224
November 2010	11,225	12,374
December 2010	16,789	18,507
<b>Annual Total</b>	<b>127,336</b>	<b>140,362</b>

This total includes CO<sub>2</sub> emissions from coal, fuel oil, wood pellets, and natural gas from Boiler #7 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #7 for 2010

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
<b>45,952</b>	<b>43,777</b>	<b>59,172</b>	<b>0.0</b>
Coal (12,598 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)	Wood (8,000 btu/lb)
MMBtu/yr			
1.16E+06	4.51E+04	8.23E+03	0

Total for Boiler #7 (MMBtu/yr)	1.21E+06
-----------------------------------	----------

#### CO<sub>2</sub> Emission Rate Ratios

	kg/MMBtu	Ratio
coal	93.40	1
n.gas	53.02	0.56767
No.2 oil	73.96	0.79186
wood	93.80	1.00428

<b>CO<sub>2</sub> Emissions Associated with Coal Combustion (ton/yr)</b>	<b>136,573.6</b>
<b>CO<sub>2</sub> Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)</b>	<b>769.06</b>
<b>CO<sub>2</sub> Emissions Associated with Natural Gas Combustion (ton/yr)</b>	<b>3019.3</b>
<b>CO<sub>2</sub> Emissions Associated with Wood Pellet Combustion (ton/yr)</b>	<b>0.0</b>

1.19E+06 Dist. Factor

140,362

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

**Boiler #8**

**(ES-003-Boiler #8)**

*Operating Scenario #1 - Natural Gas Firing*  
*Operating Scenario #2 - No. 2 Fuel Oil Firing*



**Boiler #8 - Operating Scenario #1 - Natural Gas**

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**

Permit #: **03069T28**

County: **Orange**

DAQ Region: **Raleigh**

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-003-Boiler #8</b>					
2. Emission Source Description		<b>Natural Gas / No. 2 Fuel Oil Fired Boiler</b>					
3. Operating Scenario Description		<b>Operating Scenario #1 - Natural Gas</b>					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		<b>338.0 MMBtu/hr</b>					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		<b>56,975</b>			<b>1,000 ft<sup>3</sup>/yr</b>		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	<b>1,030 Btu/ft<sup>3</sup></b>

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	<b>N/A</b>
--	------------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	<b>None</b>	<b>None</b>
ii.	<b>None</b>	<b>None</b>
iii.	<b>None</b>	<b>None</b>
iv.	<b>None</b>	<b>None</b>

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	<b>Standby</b>	Days/Week	<b>Standby</b>	Weeks/Year	<b>Standby</b>	Hours/Year	<b>1,833 Total</b>
Typical Start & End Times in CY:				Start:	<b>N/A</b>	End:	<b>N/A</b>

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>20%</b>	Mar-May	<b>19%</b>	June-Aug	<b>6%</b>	Sept-Nov	<b>55%</b>
------------------------------	------------	---------	------------	----------	-----------	----------	------------

**Boiler #8 - Operating Scenario #1 - Natural Gas**  
 If Emission Source has multiple Operating Scenarios, complete one form for each.  
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043  
 Permit #: 03069T28  
 County: Orange  
 DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources  
 Division of Air Quality  
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-003-Boiler #8

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	2.39	8	N/A
NOx	NOx	2.25	8	N/A
PM Total	PM	0.22	8	N/A
PM-2.5	PM-2.5	0.22	8	N/A
PM-10	PM-10	0.22	8	N/A
SO2	SO2	0.02	8	N/A
VOC	VOC	0.16	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	1.14E-02	8	N/A
Benzene	71-43-2	0.12	8	N/A
Cadmium	CADMIUMCPDS	6.27E-02	8	N/A
Chromium	CROMCPDS	7.98E-02	8	N/A
Chromium VI	CHROM6CPDS	7.98E-02	8	N/A
Dichlorobenzene	106-46-7	6.84E-02	8	N/A
Formaldehyde	50-00-0	4.27	8	N/A
Hexane	HEXANEISO	1.03E+02	8	N/A
Lead	LEADCPDS	2.85E-02	8	N/A
Manganese	MANGCPDS	2.17E-02	8	N/A
Mercury	MERCPDS	1.48E-02	8	N/A
Napthalene	91-20-3	3.48E-02	8	N/A
Nickel	NICKCPDS	0.12	8	N/A
POM	POM	3.77E-02	8	N/A
Toluene	108-88-3	0.19	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	3,357.24	8	N/A
Methane	CH <sub>4</sub>	6.47E-02	8	N/A
Nitrous oxide	N <sub>2</sub> O	6.47E-03	8	N/A

**Boiler #8 - Operating Scenario #2 - No. 2 Fuel Oil**If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)Facility Name: University of North Carolina at Chapel HillFacility ID #: 6800043Permit #: 03069T28County: OrangeDAQ Region: Raleigh

## North Carolina Department of Environment and Natural Resources

## Division of Air Quality

## Air Pollutant Point Source Emissions Inventory - Calendar Year 2010

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-003-Boiler #8					
2. Emission Source Description		Natural Gas / No. 2 Fuel Oil Fired Boiler					
3. Operating Scenario Description		Operating Scenario #2 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		338.0 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		118,778			gallons/year		
6. Fuel Information (if fuel used)		% Sulfur	0.1%	% Ash		Heat Content (Btu/lb or mmCF)	139,144 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

## 8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	N/A	N/A
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

## 9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

## 10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	Standby	Days/Week	Standby	Weeks/Year	Standby	Hours/Year	1,833 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

## 11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	100%	Mar-May	0%	June-Aug	0%	Sept-Nov	0%
------------------------------	------	---------	----	----------	----	----------	----

<b>Emission Source/Operating Scenario Data</b> Page 2 of 2	<b>Facility ID #:</b> 6800043
<b>Boiler #8 - Operating Scenario #2 - No. 2 Fuel Oil</b>	<b>Permit #:</b> 03069T28
<small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>	<b>County:</b> Orange
<b>Facility Name:</b> University of North Carolina at Chapel Hill	<b>DAQ Region:</b> Raleigh

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

**Emissions:** Attach calculations and documentation of emission factors or other estimation methods used.

**Emission Source ID No.** (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-003-Boiler #8

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.30	8	N/A
NOx	NOx	0.63	8	N/A
PM Total	PM	0.20	8	N/A
PM-2.5	PM-2.5	0.01	8	N/A
PM-10	PM-10	0.06	8	N/A
SO2	SO2	1.46	8	N/A
VOC	VOC	0.01	8	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	6.65E-02	8	N/A
Benzene	71-43-2	3.27E-01	8	N/A
Beryllium	BERYLCPDS	4.99E-02	8	N/A
Cadmium	CADMIUMCPDS	4.99E-02	8	N/A
Chromium	CROMCPDS	4.99E-02	8	N/A
Chromium VI	CHROM6CPDS	1.46E-02	8	N/A
Ethylbenzene	100-41-4	9.71E-02	8	N/A
Fluoride	16984-48-8	4.43	8	N/A
Formaldehyde	50-00-0	5.70	8	N/A
Lead	LEADCPDS	1.50E-01	8	N/A
Manganese	MANGCPDS	9.98E-02	8	N/A
Mercury	MERCPDS	4.99E-02	8	N/A
Methyl chloroform	71-55-6	2.80E-02	8	N/A
Napthalene	91-20-3	0.0396	8	N/A
Nickel	NICKCPDS	4.99E-02	8	N/A
POM	POM	3.92E-01	8	N/A
Selenium	SEC	2.49E-01	8	N/A
Toluene	108-88-3	9.46	8	N/A
Xylene	1330-20-7	1.66E-01	8	N/A

Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO <sub>2</sub>	1,318.93	8	N/A
Methane	CH <sub>4</sub>	5.47E-02	8	N/A
Nitrous oxide	N <sub>2</sub> O	1.09E-02	8	N/A

**Emissions and data on this form required to report or verify emissions cannot be held confidential.**

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

**Natural Gas Combustion Emissions Calculator NG2000 Revision C**  
**2010 Annual Emissions Inventory**  
**Boiler #8**  
*(ES-003-Boiler #8)*

Facility ID # 6800043  
 Permit # 03069T28

**Operating Scenario #1**

<b>User Input</b>	<b>Emissions Output</b>																																																																																																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Company Name:</b></td> <td style="text-align: center;"><b>University of North Carolina at Chapel Hill</b></td> </tr> <tr> <td><b>Plant County:</b></td> <td style="text-align: center;"><b>Orange County</b></td> </tr> <tr> <td><b>Plant City:</b></td> <td style="text-align: center;"><b>Chapel Hill</b></td> </tr> <tr> <td><b>Permit Number:</b></td> <td style="text-align: center;"><b>03069T28</b></td> </tr> <tr> <td><b>User:</b></td> <td style="text-align: center;"><b>RST Engineering</b></td> </tr> <tr> <td><b>Heat Input Capacity (mmBtu/hr):</b></td> <td style="text-align: center;"><b>338</b></td> </tr> <tr> <td><b>Fuel Input Capacity (10<sup>6</sup> scf/hr):</b></td> <td style="text-align: center;">0.33</td> </tr> <tr> <td><b>Annual Fuel Throughput (10<sup>6</sup> scf):</b></td> <td style="text-align: center;"><b>56.97</b></td> </tr> <tr> <td><b>Latest Construction/Modification Date:</b></td> <td style="text-align: center;"><b>N/A</b></td> </tr> </table>	<b>Company Name:</b>	<b>University of North Carolina at Chapel Hill</b>	<b>Plant County:</b>	<b>Orange County</b>	<b>Plant City:</b>	<b>Chapel Hill</b>	<b>Permit Number:</b>	<b>03069T28</b>	<b>User:</b>	<b>RST Engineering</b>	<b>Heat Input Capacity (mmBtu/hr):</b>	<b>338</b>	<b>Fuel Input Capacity (10<sup>6</sup> scf/hr):</b>	0.33	<b>Annual Fuel Throughput (10<sup>6</sup> scf):</b>	<b>56.97</b>	<b>Latest Construction/Modification Date:</b>	<b>N/A</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Criteria Pollutants</b></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 10%;"></td> <td style="text-align: center;"><b>Emission Factor (lb/mmscf)</b></td> </tr> <tr> <td><b>Pollutant</b></td> <td><b>lb/hr</b></td> <td><b>lb/yr</b></td> <td><b>tpy</b></td> <td></td> <td></td> </tr> <tr> <td>PM</td> <td>2.5E+00</td> <td>4.3E+02</td> <td>2.2E-01</td> <td></td> <td style="text-align: center;">7.6E+00</td> </tr> <tr> <td>PM-10</td> <td>2.5E+00</td> <td>4.3E+02</td> <td>2.2E-01</td> <td></td> <td style="text-align: center;">7.6E+00</td> </tr> <tr> <td>PM-2.5</td> <td>2.5E+00</td> <td>4.3E+02</td> <td>2.2E-01</td> <td></td> <td style="text-align: center;">7.6E+00</td> </tr> <tr> <td>NOx</td> <td colspan="3">see attached CEMs-based calculations</td> <td></td> <td style="text-align: center;">1.9E+02</td> </tr> <tr> <td>VOC</td> <td>1.8E+00</td> <td>3.1E+02</td> <td>1.6E-01</td> <td></td> <td style="text-align: center;">5.5E+00</td> </tr> <tr> <td>CO</td> <td>2.8E+01</td> <td>4.8E+03</td> <td>2.4E+00</td> <td></td> <td style="text-align: center;">8.4E+01</td> </tr> <tr> <td>SO2</td> <td>2.0E-01</td> <td>3.4E+01</td> <td>1.7E-02</td> <td></td> <td style="text-align: center;">6.0E-01</td> </tr> <tr> <td>Total HAP</td> <td>6.3E-01</td> <td>1.1E+02</td> <td>5.4E-02</td> <td></td> <td style="text-align: center;">1.9E+00</td> </tr> <tr> <td>Largest HAP</td> <td>6.0E-01</td> <td>1.0E+02</td> <td>5.1E-02</td> <td></td> <td style="text-align: center;">1.8E+00</td> </tr> </table>	<b>Criteria Pollutants</b>					<b>Emission Factor (lb/mmscf)</b>	<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/yr</b>	<b>tpy</b>			PM	2.5E+00	4.3E+02	2.2E-01		7.6E+00	PM-10	2.5E+00	4.3E+02	2.2E-01		7.6E+00	PM-2.5	2.5E+00	4.3E+02	2.2E-01		7.6E+00	NOx	see attached CEMs-based calculations				1.9E+02	VOC	1.8E+00	3.1E+02	1.6E-01		5.5E+00	CO	2.8E+01	4.8E+03	2.4E+00		8.4E+01	SO2	2.0E-01	3.4E+01	1.7E-02		6.0E-01	Total HAP	6.3E-01	1.1E+02	5.4E-02		1.9E+00	Largest HAP	6.0E-01	1.0E+02	5.1E-02		1.8E+00																			
<b>Company Name:</b>	<b>University of North Carolina at Chapel Hill</b>																																																																																																							
<b>Plant County:</b>	<b>Orange County</b>																																																																																																							
<b>Plant City:</b>	<b>Chapel Hill</b>																																																																																																							
<b>Permit Number:</b>	<b>03069T28</b>																																																																																																							
<b>User:</b>	<b>RST Engineering</b>																																																																																																							
<b>Heat Input Capacity (mmBtu/hr):</b>	<b>338</b>																																																																																																							
<b>Fuel Input Capacity (10<sup>6</sup> scf/hr):</b>	0.33																																																																																																							
<b>Annual Fuel Throughput (10<sup>6</sup> scf):</b>	<b>56.97</b>																																																																																																							
<b>Latest Construction/Modification Date:</b>	<b>N/A</b>																																																																																																							
<b>Criteria Pollutants</b>					<b>Emission Factor (lb/mmscf)</b>																																																																																																			
<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/yr</b>	<b>tpy</b>																																																																																																					
PM	2.5E+00	4.3E+02	2.2E-01		7.6E+00																																																																																																			
PM-10	2.5E+00	4.3E+02	2.2E-01		7.6E+00																																																																																																			
PM-2.5	2.5E+00	4.3E+02	2.2E-01		7.6E+00																																																																																																			
NOx	see attached CEMs-based calculations				1.9E+02																																																																																																			
VOC	1.8E+00	3.1E+02	1.6E-01		5.5E+00																																																																																																			
CO	2.8E+01	4.8E+03	2.4E+00		8.4E+01																																																																																																			
SO2	2.0E-01	3.4E+01	1.7E-02		6.0E-01																																																																																																			
Total HAP	6.3E-01	1.1E+02	5.4E-02		1.9E+00																																																																																																			
Largest HAP	6.0E-01	1.0E+02	5.1E-02		1.8E+00																																																																																																			
<p style="color: red;"><b>Enter the boiler type below ▾</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;"><b>3 + 4</b></td> </tr> </table>	<b>3 + 4</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Toxic/Hazardous Air Pollutants</b></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><b>Pollutant</b></td> <td><b>lb/hr</b></td> <td><b>lb/day</b></td> <td><b>lb/yr</b></td> <td></td> <td></td> </tr> <tr> <td>Arsenic</td> <td>6.6E-05</td> <td>NA</td> <td>1.1E-02</td> <td></td> <td style="text-align: center;">2.0E-04</td> </tr> <tr> <td>Benzene</td> <td>7.0E-04</td> <td>NA</td> <td>1.2E-01</td> <td></td> <td style="text-align: center;">2.1E-03</td> </tr> <tr> <td>Cadmium</td> <td>3.6E-04</td> <td>NA</td> <td>6.3E-02</td> <td></td> <td style="text-align: center;">1.1E-03</td> </tr> <tr> <td style="color: red;">Chromium</td> <td style="color: red;">4.6E-04</td> <td style="color: red;">NA</td> <td style="color: red;">8.0E-02</td> <td></td> <td style="text-align: center;">1.4E-03</td> </tr> <tr> <td style="color: red;">Chromium VI</td> <td style="color: red;">4.6E-04</td> <td style="color: red;">NA</td> <td style="color: red;">8.0E-02</td> <td></td> <td style="text-align: center;">1.4E-03</td> </tr> <tr> <td>Dichlorobenzene</td> <td>4.0E-04</td> <td>NA</td> <td>6.8E-02</td> <td></td> <td style="text-align: center;">1.2E-03</td> </tr> <tr> <td>Formaldehyde</td> <td>2.5E-02</td> <td>NA</td> <td>4.3E+00</td> <td></td> <td style="text-align: center;">7.5E-02</td> </tr> <tr> <td>Hexane</td> <td>6.0E-01</td> <td>1.4E+01</td> <td>1.0E+02</td> <td></td> <td style="text-align: center;">1.8E+00</td> </tr> <tr> <td style="color: red;">Lead</td> <td style="color: red;">1.7E-04</td> <td style="color: red;">NA</td> <td style="color: red;">2.8E-02</td> <td></td> <td style="text-align: center;">5.0E-04</td> </tr> <tr> <td>Manganese</td> <td>1.3E-04</td> <td>3.0E-03</td> <td>2.2E-02</td> <td></td> <td style="text-align: center;">3.8E-04</td> </tr> <tr> <td>Mercury</td> <td>8.6E-05</td> <td>2.1E-03</td> <td>1.5E-02</td> <td></td> <td style="text-align: center;">2.6E-04</td> </tr> <tr> <td style="color: red;">Naphthalene</td> <td style="color: red;">2.0E-04</td> <td style="color: red;">NA</td> <td style="color: red;">3.5E-02</td> <td></td> <td style="text-align: center;">6.1E-04</td> </tr> <tr> <td>Nickel</td> <td>7.0E-04</td> <td>1.7E-02</td> <td>1.2E-01</td> <td></td> <td style="text-align: center;">2.1E-03</td> </tr> <tr> <td style="color: red;">POM</td> <td style="color: red;">2.2E-04</td> <td style="color: red;">NA</td> <td style="color: red;">3.8E-02</td> <td></td> <td style="text-align: center;">6.6E-04</td> </tr> <tr> <td>Toluene</td> <td>1.1E-03</td> <td>2.7E-02</td> <td>1.9E-01</td> <td></td> <td style="text-align: center;">3.4E-03</td> </tr> </table>	<b>Toxic/Hazardous Air Pollutants</b>						<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/day</b>	<b>lb/yr</b>			Arsenic	6.6E-05	NA	1.1E-02		2.0E-04	Benzene	7.0E-04	NA	1.2E-01		2.1E-03	Cadmium	3.6E-04	NA	6.3E-02		1.1E-03	Chromium	4.6E-04	NA	8.0E-02		1.4E-03	Chromium VI	4.6E-04	NA	8.0E-02		1.4E-03	Dichlorobenzene	4.0E-04	NA	6.8E-02		1.2E-03	Formaldehyde	2.5E-02	NA	4.3E+00		7.5E-02	Hexane	6.0E-01	1.4E+01	1.0E+02		1.8E+00	Lead	1.7E-04	NA	2.8E-02		5.0E-04	Manganese	1.3E-04	3.0E-03	2.2E-02		3.8E-04	Mercury	8.6E-05	2.1E-03	1.5E-02		2.6E-04	Naphthalene	2.0E-04	NA	3.5E-02		6.1E-04	Nickel	7.0E-04	1.7E-02	1.2E-01		2.1E-03	POM	2.2E-04	NA	3.8E-02		6.6E-04	Toluene	1.1E-03	2.7E-02	1.9E-01		3.4E-03
<b>3 + 4</b>																																																																																																								
<b>Toxic/Hazardous Air Pollutants</b>																																																																																																								
<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/day</b>	<b>lb/yr</b>																																																																																																					
Arsenic	6.6E-05	NA	1.1E-02		2.0E-04																																																																																																			
Benzene	7.0E-04	NA	1.2E-01		2.1E-03																																																																																																			
Cadmium	3.6E-04	NA	6.3E-02		1.1E-03																																																																																																			
Chromium	4.6E-04	NA	8.0E-02		1.4E-03																																																																																																			
Chromium VI	4.6E-04	NA	8.0E-02		1.4E-03																																																																																																			
Dichlorobenzene	4.0E-04	NA	6.8E-02		1.2E-03																																																																																																			
Formaldehyde	2.5E-02	NA	4.3E+00		7.5E-02																																																																																																			
Hexane	6.0E-01	1.4E+01	1.0E+02		1.8E+00																																																																																																			
Lead	1.7E-04	NA	2.8E-02		5.0E-04																																																																																																			
Manganese	1.3E-04	3.0E-03	2.2E-02		3.8E-04																																																																																																			
Mercury	8.6E-05	2.1E-03	1.5E-02		2.6E-04																																																																																																			
Naphthalene	2.0E-04	NA	3.5E-02		6.1E-04																																																																																																			
Nickel	7.0E-04	1.7E-02	1.2E-01		2.1E-03																																																																																																			
POM	2.2E-04	NA	3.8E-02		6.6E-04																																																																																																			
Toluene	1.1E-03	2.7E-02	1.9E-01		3.4E-03																																																																																																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Other NOx Control</b></td> <td style="width: 70%;"></td> </tr> <tr> <td>Enter 1 below if SNCR is applied to the boiler.</td> <td style="text-align: center;"><b>0</b></td> </tr> </table>	<b>Other NOx Control</b>		Enter 1 below if SNCR is applied to the boiler.	<b>0</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Greenhouse Gas Pollutants</b></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td><b>Pollutant</b></td> <td><b>lb/hr</b></td> <td><b>lb/yr</b></td> <td><b>tpy</b></td> <td></td> <td style="text-align: center;"><b>Em. Factor (lb/mmBtu)</b></td> </tr> <tr> <td>Carbon dioxide</td> <td colspan="3">see attached CEMs-based calculations</td> <td></td> <td style="text-align: center;">116.89</td> </tr> <tr> <td>Methane</td> <td>0.75</td> <td>129.37</td> <td>6.47E-02</td> <td></td> <td style="text-align: center;">2.20E-03</td> </tr> <tr> <td>Nitrous Oxide</td> <td>0.075</td> <td>12.94</td> <td>6.47E-03</td> <td></td> <td style="text-align: center;">2.20E-04</td> </tr> </table>	<b>Greenhouse Gas Pollutants</b>						<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/yr</b>	<b>tpy</b>		<b>Em. Factor (lb/mmBtu)</b>	Carbon dioxide	see attached CEMs-based calculations				116.89	Methane	0.75	129.37	6.47E-02		2.20E-03	Nitrous Oxide	0.075	12.94	6.47E-03		2.20E-04																																																																					
<b>Other NOx Control</b>																																																																																																								
Enter 1 below if SNCR is applied to the boiler.	<b>0</b>																																																																																																							
<b>Greenhouse Gas Pollutants</b>																																																																																																								
<b>Pollutant</b>	<b>lb/hr</b>	<b>lb/yr</b>	<b>tpy</b>		<b>Em. Factor (lb/mmBtu)</b>																																																																																																			
Carbon dioxide	see attached CEMs-based calculations				116.89																																																																																																			
Methane	0.75	129.37	6.47E-02		2.20E-03																																																																																																			
Nitrous Oxide	0.075	12.94	6.47E-03		2.20E-04																																																																																																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Large Wall-Fired Boilers (=&gt;100 mmBtu/hr)</b></td> <td style="width: 70%;"></td> </tr> <tr> <td>1 = Uncontrolled (Pre-NSPS)</td> <td></td> </tr> <tr> <td>2 = Uncontrolled (Post-NSPS)</td> <td></td> </tr> <tr> <td>3 = Controlled - Low NOx burners</td> <td></td> </tr> <tr> <td>4 = Controlled - Flue gas recirculation (FGR)</td> <td></td> </tr> </table>	<b>Large Wall-Fired Boilers (=&gt;100 mmBtu/hr)</b>		1 = Uncontrolled (Pre-NSPS)		2 = Uncontrolled (Post-NSPS)		3 = Controlled - Low NOx burners		4 = Controlled - Flue gas recirculation (FGR)		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Small Boilers (&lt;100 mmBtu/hr)</b></td> <td style="width: 70%;"></td> </tr> <tr> <td>5 = Uncontrolled</td> <td></td> </tr> <tr> <td>6 = Controlled - Low NOx burners</td> <td></td> </tr> <tr> <td>7 = Controlled - Low NOx burners/FGR</td> <td></td> </tr> </table>	<b>Small Boilers (&lt;100 mmBtu/hr)</b>		5 = Uncontrolled		6 = Controlled - Low NOx burners		7 = Controlled - Low NOx burners/FGR																																																																																						
<b>Large Wall-Fired Boilers (=&gt;100 mmBtu/hr)</b>																																																																																																								
1 = Uncontrolled (Pre-NSPS)																																																																																																								
2 = Uncontrolled (Post-NSPS)																																																																																																								
3 = Controlled - Low NOx burners																																																																																																								
4 = Controlled - Flue gas recirculation (FGR)																																																																																																								
<b>Small Boilers (&lt;100 mmBtu/hr)</b>																																																																																																								
5 = Uncontrolled																																																																																																								
6 = Controlled - Low NOx burners																																																																																																								
7 = Controlled - Low NOx burners/FGR																																																																																																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Tangential-Fired Boilers (All Sizes)</b></td> <td style="width: 70%;"></td> </tr> <tr> <td>8 = Uncontrolled</td> <td></td> </tr> <tr> <td>9 = Controlled - FGR</td> <td></td> </tr> </table>	<b>Tangential-Fired Boilers (All Sizes)</b>		8 = Uncontrolled		9 = Controlled - FGR		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;"><b>Residential Furnaces (&lt;0.3 mmBtu/hr)</b></td> <td style="width: 70%;"></td> </tr> <tr> <td>10 = Uncontrolled</td> <td></td> </tr> </table>	<b>Residential Furnaces (&lt;0.3 mmBtu/hr)</b>		10 = Uncontrolled																																																																																														
<b>Tangential-Fired Boilers (All Sizes)</b>																																																																																																								
8 = Uncontrolled																																																																																																								
9 = Controlled - FGR																																																																																																								
<b>Residential Furnaces (&lt;0.3 mmBtu/hr)</b>																																																																																																								
10 = Uncontrolled																																																																																																								

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**

**Boiler #8**

**2010 Annual Emissions Inventory**

**(ES-003-Boiler #8)**

**Facility ID # 6800043**

**Permit # 03069T28**

**Operating Scenario #2**

<b>User Input</b>	
Company Name:	<b>University of North Carolina at Chapel Hill</b>
Plant County:	<b>Orange County</b>
Plant City:	<b>Chapel Hill</b>
Permit Number:	<b>03069T28</b>
User:	<b>RST Engineering</b>
Heat Input Capacity (mmBtu/hr):	<b>338</b>
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	<b>118.78</b>
Maximum fuel sulfur content (%):	<b>0.1</b>
Latest Construction/Modification Date:	<b>N/A</b>

<b>Enter the boiler type below ▾</b>	
	<b>17</b>

<p><b>Boilers =&gt;100 mmBtu/hr</b></p> <p>1 = No. 6 oil fired, normal firing (U)                  2 = No. 6 oil fired, normal firing (I)                  3 = No. 6 oil fired, normal firing (C)                  4 = No. 6 oil fired, normal firing, low NOx burner (U)                  5 = No. 6 oil fired, normal firing, low NOx burner (I)                  6 = No. 6 oil fired, normal firing, low NOx burner (C)                  7 = No. 6 oil fired, tangential firing (U)                  8 = No. 6 oil fired, tangential firing, low NOx burner (U)                  9 = No. 5 oil fired, normal firing (U)                  10 = No. 5 oil fired, normal firing (I)                  11 = No. 5 oil fired, tangential firing (U)                  12 = No. 4 oil fired, normal firing (U)                  13 = No. 4 oil fired, normal firing (I)                  14 = No. 4 oil fired, tangential firing (U)                  15 = No. 2 oil fired (U,I)</p>	<p><b>Boilers =&gt;100 mmBtu/hr (cont'd)</b></p> <p>16 = No. 2 oil fired (C)  <b>17 = No. 2 oil fired, LNB/FGR (U,I)</b>                  18 = No. 2 oil fired, LNB/FGR (C)</p> <hr/> <p>19 = Vertical fired utility boiler</p> <hr/> <p><b>Small Boilers (&lt;100 mmBtu/hr)</b></p> <p>20 = No. 6 oil fired (I)                  21 = No. 6 oil fired (C)                  22 = No. 5 oil fired (C)                  23 = No. 4 oil fired (C)                  24 = No. 2 oil fired (I)                  25 = No. 2 oil fired (C)</p> <hr/> <p>26 = Residential Furnace</p>
--	--

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**

**Boiler #8**

**2010 Annual Emissions Inventory**

**(ES-003-Boiler #8)**

**Facility ID # 6800043**

**Permit # 03069T28**

**Operating Scenario #2**

<b>User Input</b>	
Company Name:	<b>University of North Carolina at Chapel Hill</b>
Plant County:	<b>Orange County</b>
Plant City:	<b>Chapel Hill</b>
Permit Number:	<b>03069T28</b>
User:	<b>RST Engineering</b>
Heat Input Capacity (mmBtu/hr):	<b>338</b>
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	<b>118.78</b>
Maximum fuel sulfur content (%):	<b>0.1</b>
Latest Construction/Modification Date:	<b>N/A</b>

**Emission Controls**

Particulate controls

<b>Enter the control type below</b> ▾	Message Area	Or enter a PM control efficiency below to override built in values.
<b>0</b>		
<u>Control Device</u> 0 = None/other 1 = ESP 2 = Scrubber 3 = Bagfilter 4 = Multiple cyclone	<u>Avg. Cont. Effic.</u> 0.0  0.0	<u>User Input PM Cont. Effic.</u> <b>0.0</b>
		Message Area

Postcombustion SO<sub>2</sub> controls

<b>Enter the control type below</b> ▾	Message Area	Or enter an SO <sub>2</sub> control efficiency below to override built in values.
<b>0</b>		
<u>Control Technology/Process</u> 0 = None/other 1 = Wet scrubber, Lime/limestone 2 = Wet scrubber, Sodium carbonate 3 = Wet scrubber, Magnesium oxide/hydroxide 4 = Wet scrubber, Dual alkali 5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel 6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity 7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray	<u>Avg. Cont. Effic.</u> 0.0  0.0	<u>User Input SO<sub>2</sub> Cont. Effic.</u> <b>0.0</b>
		Message Area
		<u>Remarks</u> NA

NO<sub>x</sub> controls

<b>Enter the control type below</b> ▾		Or enter a NO <sub>x</sub> control efficiency below to override built in values.
<b>5 + 6</b>		
<u>Control Technology/Process</u> 0 = None/other 1 = Low excess air (LEA) 2 = Staged combustion (SC) 3 = Burners out of service (BOOS) 4 = Flue gas recirculation (FGR) 5 = Flue gas recirculation plus staged combustion 6 = Low NO <sub>x</sub> burners (LNB) 7 = Reduced air preheat (RAP) 8 = Selective noncatalytic reduction (SNCR) 9 = Conventional selective catalytic reduction (SCR)	<u>Avg. Cont. Effic.</u> 0.0	<u>User Input NO<sub>x</sub> Cont. Effic.</u> <b>0.0</b>
		Message Area
		<u>Remarks</u> NA

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**

**Boiler #8**

**2010 Annual Emissions Inventory**

**(ES-003-Boiler #8)**

**Facility ID # 6800043**

**Permit # 03069T28**

**Operating Scenario #2**

<b>User Input</b>	
Company Name:	<b>University of North Carolina at Chapel Hill</b>
Plant County:	<b>Orange County</b>
Plant City:	<b>Chapel Hill</b>
Permit Number:	<b>03069T28</b>
User:	<b>RST Engineering</b>
Heat Input Capacity (mmBtu/hr):	<b>338</b>
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	<b>118.78</b>
Maximum fuel sulfur content (%):	<b>0.1</b>
Latest Construction/Modification Date:	<b>N/A</b>

**Emissions Output**

**Criteria Pollutants**

Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	Emission Factor <sup>1</sup> (lb/10 <sup>3</sup> gal)
Total PM (FPM + CPM)	8.0	0.1960	392	3.30E+00
Filterable PM (FPM) rates uncontrolled	4.8	0.1188	238	2.00E+00
Condensable PM (CPM) <sup>4</sup>	3.1	0.0772	154	1.30E+00
Filterable PM-10 <sup>5</sup>	2.4	0.0594	119	1.00E+00
Filterable PM-2.5 <sup>5</sup>	0.6	0.0148	30	2.50E-01
NOx rates uncontrolled	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.0119	24	2.00E-01
CO	12	0.2969	594	5.00E+00
SO2 rates uncontrolled	59.2	1.4550	2,910	2.45E+01
Total HAP <sup>6</sup>	4.36E-01	0.0107	21	1.81E-01
Largest HAP <sup>6</sup>	1.92E-01	0.0047	9	7.97E-02

*\*\*NOx emissions based on CEMs data.*

**Toxic/Hazardous Air Pollutants.**

Pollutant	lb/hr <sup>2</sup>	lb/day <sup>7</sup>	lb/yr <sup>3</sup>	Emission Factor <sup>1</sup> (lb/10 <sup>3</sup> gal)
<b>Antimony rates uncontrolled</b>	<b>0.00E+00</b>	<b>NA</b>	<b>0.00E+00</b>	0.00E+00
Arsenic rates uncontrolled	1.35E-03	NA	6.65E-02	5.60E-04
Benzene	6.64E-03	NA	3.27E-01	2.75E-03
Beryllium rates uncontrolled	1.01E-03	NA	4.99E-02	4.20E-04
Cadmium rates uncontrolled	1.01E-03	NA	4.99E-02	4.20E-04
<b>Chromium rates uncontrolled</b>	<b>1.01E-03</b>	<b>NA</b>	<b>4.99E-02</b>	4.20E-04
Chromium VI rates uncontrolled	2.98E-04	NA	1.46E-02	1.23E-04
<b>Cobalt rates uncontrolled</b>	<b>0.00E+00</b>	<b>NA</b>	<b>0.00E+00</b>	0.00E+00
<b>Ethylbenzene</b>	<b>1.97E-03</b>	<b>NA</b>	<b>9.71E-02</b>	8.17E-04
Fluoride	9.01E-02	2.16E+00	4.43E+00	3.73E-02
Formaldehyde	1.16E-01	2.78E+00	5.70E+00	4.80E-02
<b>Lead rates uncontrolled</b>	<b>3.04E-03</b>	<b>NA</b>	<b>1.50E-01</b>	1.26E-03
Manganese rates uncontrolled	2.03E-03	4.87E-02	9.98E-02	8.40E-04
Mercury	1.01E-03	2.43E-02	4.99E-02	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.70E-04	1.37E-02	2.80E-02	2.36E-04
<b>Naphthalene</b>	<b>8.04E-04</b>	<b>NA</b>	<b>3.96E-02</b>	3.33E-04
Nickel rates uncontrolled	1.01E-03	2.43E-02	4.99E-02	4.20E-04
<b>POM rates uncontrolled</b>	<b>7.97E-03</b>	<b>NA</b>	<b>3.92E-01</b>	3.30E-03
<b>Selenium rates uncontrolled</b>	<b>5.07E-03</b>	<b>NA</b>	<b>2.49E-01</b>	2.10E-03
Toluene	1.92E-01	4.62E+00	9.46E+00	7.97E-02
Xylene	3.38E-03	8.12E-02	1.66E-01	1.40E-03

**Greenhouse Gases**

Pollutant	lb/hr <sup>2</sup>	tpy	lb/yr <sup>3</sup>	Emission Factor (lb/10 <sup>3</sup> gal)
-----------	--------------------	-----	--------------------	---



**Fuel Oil Combustion Emissions Calculator FO2000 Revision A**

**Boiler #8**

**2010 Annual Emissions Inventory**

**(ES-003-Boiler #8)**

**Facility ID # 6800043**

**Permit # 03069T28**

**Operating Scenario #2**

<b>User Input</b>	
Company Name:	<b>University of North Carolina at Chapel Hill</b>
Plant County:	<b>Orange County</b>
Plant City:	<b>Chapel Hill</b>
Permit Number:	<b>03069T28</b>
User:	<b>RST Engineering</b>
Heat Input Capacity (mmBtu/hr):	<b>338</b>
Fuel Input Capacity (10 <sup>3</sup> gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	<b>118.78</b>
Maximum fuel sulfur content (%):	<b>0.1</b>
Latest Construction/Modification Date:	<b>N/A</b>

Carbon dioxide	see attached CEMs-based calculations			22687.74
Methane	2.22E+00	5.47E-02	1.09E+02	0.920
Nitrous Oxide	4.44E-01	1.09E-02	2.19E+01	0.18

<sup>1</sup>Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

<sup>2</sup>Hourly emission rates for all pollutants are based on hourly rated capacity.

<sup>3</sup>Annual emission rates for all pollutants are based on maximum annual fuel throughput.

<sup>4</sup>Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

<sup>5</sup>AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

<sup>6</sup>Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

<sup>7</sup>Daily emission rates are based on operation 24 hours per day at rated capacity.

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Nitrogen Dioxide Emissions from Boiler #8 (ES-003-Boiler #8)

The exhaust duct at Boiler #8 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2010 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2010	0.07
February 2010	0.07
March 2010	0.08
April 2010	0.08
May 2010	0.08
June 2010	0.08
July 2010	0.08
August 2010	0.08
September 2010	0.08
October 2010	0.07
November 2010	0.07
December 2010	0.08
<b>Annual Average</b>	<b>0.08</b>

This average includes NOx emissions from fuel oil and natural gas from Boiler #8 over the entire year, representing a composite average for all fuels combusted.

### Fuel Inputs to Boiler #8 for 2010

Boiler #8	
Gas 1,000cf/yr	Oil Gallons/yr
56,975	118,778
Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)
MMBtu/yr	
5.87E+04	1.65E+04

Total for Boiler #8 (MMBtu/yr)	7.52E+04
--------------------------------	----------

NOx Emissions from Boiler #8 (lb/yr)	5,766
<b>NOx Emissions from Boiler #8 (ton/yr)</b>	<b>2.88</b>

NOx Emissions Associated with Fuel Oil Combustion (ton/yr)	0.634
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	2.250

# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### CO<sub>2</sub> Emissions from Boiler No.8

(ES-3)

The exhaust system on Boiler #8 is equipped with a continuous emissions monitor (CEMs) for CO<sub>2</sub> concentrations. The natural gas and oil flow rates to the boiler are monitored. Mass CO<sub>2</sub> emissions are calculated by the DAHS for GHG reporting. For the 2010 calendar year, the monthly CO<sub>2</sub> emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2010	824	908
February 2010	373	411
March 2010	618	681
April 2010	10	11
May 2010	47	52
June 2010	114	125
July 2010	21	23
August 2010	104	114
September 2010	142	157
October 2010	314	346
November 2010	1,259	1,388
December 2010	417	460
<b>Annual Total</b>	<b>4,242</b>	<b>4,676</b>

This total includes CO<sub>2</sub> emissions from No.2 fuel oil and natural gas from Boiler #8 over the entire year, representing a composite average for all fuels combusted.

#### Fuel Inputs to Boiler #8 for 2010

Boiler #8	
Gas 1,000cf/yr	No. 2 Oil Gallons/yr
<b>56,975</b>	<b>118,778</b>
Nat. Gas (1,030 btu/cf)	Oil (139,144 btu/gal)
MMBtu/yr	
5.87E+04	1.65E+04
Total for Boiler #7 (MMBtu/yr)	
7.52E+04	

<b>CO<sub>2</sub> Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)</b>	<b>1318.93</b>
<b>CO<sub>2</sub> Emissions Associated with Natural Gas Combustion (ton/yr)</b>	<b>3,357.24</b>

#### CO<sub>2</sub> Emission Rate Ratios

	<u>kg/MMBtu</u>	<u>Ratio</u>
n.gas	53.02	1
No.2 oil	73.96	1.3949

8.17E+04 Dist. Factor

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**Coal Crusher/Conveyor Building  
(ES-010A)**

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2	<b>Facility ID #:</b> 6800043
<b>Coal Crusher/Conveyor Building</b>	<b>Permit #:</b> 03069T28
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	<b>County:</b> Orange
<b>Facility Name:</b> University of North Carolina at Chapel Hill	<b>DAQ Region:</b> Raleigh

**North Carolina Department of Environment and Natural Resources**  
**Division of Air Quality**  
**Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-010A</b>
<b>2. Emission Source Description</b>	<b>Coal Crusher / Conveyor Building</b>	
<b>3. Operating Scenario Description</b>	N/A	
<b>4. Maximum Permitted Operating Rate</b> With Units (Ex. gal/hr, mmBtu/hr)	<b>60 tons/hr</b>	
<b>5. Throughput in CY</b> (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)	<b>104,788</b>	<b>tons/yr</b>
<b>6. Fuel Information</b> (if fuel used)	% Sulfur	N/A
	% Ash	N/A
	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)	<b>100%</b>
---	-------------

**8. Control Device Information**, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
<i>i. (nearest stack)</i>	<b>CD-013</b>	<b>Bagfilter</b>
<i>ii.</i>	N/A	N/A
<i>iii.</i>	N/A	N/A
<i>iv.</i>	N/A	N/A

**9. Stack Information** (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature  (F)	Velocity  (feet/sec)	Volume Flow Rate  (acfm)	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
EP-12-053	47	1.8	Ambient	44	6,500	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

**10. Operating Schedule** (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	<b>6</b>	Days/Week	<b>7</b>	Weeks/Year	<b>52</b>	Hours/Year	<b>1,746</b>
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

**11. Seasonal Periods Percent Annual Throughput** (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------



# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Emissions from the Conveyor/Crusher Building

(ES-010A)

Assume that the total amount of coal conveyed to the crusher is equal to the total amount of coal combusted in 2010.

Boiler #6	58,836	Tons/yr
Boiler #7	45,952	Tons/yr
Total	104,788	Tons/yr

The conveyor transfer points and crushers in the Coal Crusher Building are controlled by a vacuum dust pick-up system ducted to a baghouse. The air flow rate through the baghouse is 6,650 acfm. Emissions from the baghouse are conservatively estimated at 0.015 gr/acfm.

60 ton/hr, conveying rate  
1,746.5 hrs/yr, conveying time

$\text{lb/yr} = (6,650 \text{ acfm}) (60 \text{ min/hr}) (\text{hr/yr}) (0.015 \text{ gr/acfm}) (1/7000 \text{ lb/gr})$

<b>Total Emissions from the Crusher</b>	<b>10,452,593</b>	<b>gr/yr</b>
	<b>1,493</b>	<b>lb/yr</b>
	<b>0.75</b>	<b>ton/yr</b>

100% of these emissions are PM-10

95% of these emissions are PM-2.5

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**Ash Silo with Loadout  
(ES-030)**



**Ash Silo with Loadout**

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T28

County: Orange

DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-030</b>					
2. Emission Source Description		<b>Ash Silo with Loadout</b>					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		<b>16 tons/hr</b>					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		<b>28,839</b>			<b>tons/yr</b>		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	<b>100%</b>
--	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	<b>CD-031</b>	<b>Bagfilter</b>
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
<b>Fugitive</b>						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	<b>10</b>	Days/Week	<b>7</b>	Weeks/Year	<b>52</b>	Hours/Year	<b>5,389</b>
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------



# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Ash Silo with Loadout

(ES-030)

Ash is conveyed to the silo and loaded into trucks for off-site transport. The ash is pneumatically conveyed to the silo with the conveying air filtered through a baghouse (CD-031) prior to discharge. The ash loadout to the transfer trucks is via a pipe within a pipe configuration. The annular space between the internal and external pipes is under a vacuum. This vacuum system collects the dust generated during truck loading and ducts it to the baghouse (CD-031). Ash is composed of coal flyash and  $\text{CaCO}_3$  /  $\text{CaSO}_3$  from desulfurization. Ash is similar to flyash used in concrete batching operations.

28,838.86 ton/yr, ash loaded in 2010

#### 1. Uncaptured Truck Loading Fugitives

Truck loading operations are in an enclosure with discharge into an enclosed truck bed. The vacuum at the ash discharge point and enclosures should insure a minimum of 95% capture. Uncontrolled emissions are based on a conservatively high estimated 0.5 lb/ton emission factor (0.02 lb/ton AP-42 for batch truck loading at concrete plants).

28,839	ton/yr, Ash Generated
0.5	lb/ton, Emission Factor
95%	Capture Efficiency
721.0	lb/yr, Emissions
0.36	ton/yr, Emissions

Fugitives from the Enclosure:

0.019	ton/yr, Emissions
-------	-------------------

#### 2. Baghouse Emissions

The air flow rate through the baghouse is 4,490 acfm. Emissions from the baghouse are conservatively estimated at 0.015 gr/acfm.

$$\text{lb/yr} = (4,490 \text{ acfm}) (60 \text{ min/hr}) (\text{hr/yr}) (0.015 \text{ gr/acfm}) (1/7000 \text{ lb/gr})$$

4,490	acfm, Baghouse Flow Rate
5,389	hrs/yr, Operating Hours
0.015	gr/acfm, Emission Factor from Baghouse
3,111	lb/yr, Emissions
1.56	ton/yr, Emissions

#### 3. Total Emissions

0.36	ton/yr, Emissions Truck Loading
0.019	ton/yr, Emissions, Truck Fugitives
1.56	ton/yr, Emissions, Baghouse
1.94	ton/yr, Total Emissions PM
1.94	ton/yr, Total Emissions PM-10
1.84	ton/yr, Total Emissions PM-2.5

100% as PM-10

95% as PM-2.5

**The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

**2010 Annual Emissions Inventory**

**Wet Ash Loadout  
(ES-030A)**

*(This unit was not in operation during CY 2010)*

**Wet Ash Loadout**

If Emission Source has multiple Operating Scenarios, complete one form for each.  
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**Permit #: **03069T28**County: **Orange**DAQ Region: **Raleigh**Facility Name: **University of North Carolina at Chapel Hill**

**North Carolina Department of Environment and Natural Resources  
Division of Air Quality  
Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		<b>ES-030A</b>					
2. Emission Source Description		<b>Wet Ash Loadout</b>					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		N/A					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		<b>0 ton/yr</b>					
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	<b>N/A</b>
--	------------

## 8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	<b>None</b>	<b>None</b>
ii.	<b>None</b>	<b>None</b>
iii.	<b>None</b>	<b>None</b>
iv.	<b>None</b>	<b>None</b>

## 9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

## 10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	N/A	Days/Week	N/A	Weeks/Year	N/A	Hours/Year	N/A
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

## 11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>0%</b>	Mar-May	<b>0%</b>	June-Aug	<b>0%</b>	Sept-Nov	<b>0%</b>
------------------------------	-----------	---------	-----------	----------	-----------	----------	-----------

**This Unit Was Not in Operation During CY 2008.**

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

# **The University of North Carolina at Chapel Hill**

Chapel Hill, North Carolina

*Orange County*

Facility ID # 6800043

Permit # 03069T28

## **2010 Annual Emissions Inventory**

### **Enclosed Sorbent Railcar Dump Pit (Insignificant Source)**

**IS-53**

19,802 tons of sorbent delivered by rail in 2010. There are no emission sources associated with truck delivery.

<b>Emission Source/Operating Scenario Data</b> Page 1 of 2	<b>Facility ID #:</b> 6800043
<b>Enclosed Sorbent Railcar Dump Pit</b>	<b>Permit #:</b> 03069T28
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	<b>County:</b> Orange
<b>Facility Name:</b> University of North Carolina at Chapel Hill	<b>DAQ Region:</b> Raleigh

**North Carolina Department of Environment and Natural Resources**  
**Division of Air Quality**  
**Air Pollutant Point Source Emissions Inventory - Calendar Year 2010**

<b>1. Emission Source ID No.</b> (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)	<b>"I" Insignificant - ID No. 020</b>						
<b>2. Emission Source Description</b>	<b>Enclosed Sorbent Railcar Dump Pit</b>						
<b>3. Operating Scenario Description</b>	N/A						
<b>4. Maximum Permitted Operating Rate</b> <small>With Units (Ex. gal/hr, mmBtu/hr)</small>	<b>50 ton/hr</b>						
<b>5. Throughput in CY</b> (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>	<b>19,802 tons/yr</b>						
<b>6. Fuel Information</b> (if fuel used)	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;"><small>% Sulfur</small></td> <td style="width:15%; text-align:center;">N/A</td> <td style="width:15%;"><small>% Ash</small></td> <td style="width:15%; text-align:center;">N/A</td> <td style="width:30%;"><small>Heat Content (Btu/lb or mmCF)</small></td> <td style="width:15%; text-align:center;">N/A</td> </tr> </table>	<small>% Sulfur</small>	N/A	<small>% Ash</small>	N/A	<small>Heat Content (Btu/lb or mmCF)</small>	N/A
<small>% Sulfur</small>	N/A	<small>% Ash</small>	N/A	<small>Heat Content (Btu/lb or mmCF)</small>	N/A		

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

<b>7. Capture Efficiency</b> (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
---	-----

**8. Control Device Information**, if none, write "none"

	<b>Control Device ID #</b> <small>(as listed in permit)</small>	<b>Control Device Description</b>
<i>i. (nearest stack)</i>	None	None
<i>ii.</i>	None	None
<i>iii.</i>	None	None
<i>iv.</i>	None	None

**9. Stack Information** (sources vented to more than one stack use additional entry lines)

<b>Stack ID #</b>	<b>Height</b> <small>(in whole feet)</small>	<b>Diameter (feet)</b> <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	<b>Temperature</b> <small>(F)</small>	<b>Velocity</b> <small>(feet/sec)</small>	<b>Volume Flow Rate</b> <small>(acfm)</small>	<b>Release Point Description</b> <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
<b>Fugitive</b>						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

**10. Operating Schedule** (Source/Operating Scenario that best characterizes calendar year)

<b>Hours/Day</b>	<b>1</b>	<b>Days/Week</b>	<b>3</b>	<b>Weeks/Year</b>	<b>52</b>	<b>Hours/Year</b>	<b>156</b>
<b>Typical Start &amp; End Times in CY:</b>				<b>Start:</b>	N/A	<b>End:</b>	N/A

**11. Seasonal Periods Percent Annual Throughput** (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	<b>35.31%</b>	Mar-May	<b>17.41%</b>	June-Aug	<b>25.74%</b>	Sept-Nov	<b>21.54%</b>
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------





# University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T28

## 2010 Annual Emissions Inventory

### Enclosed Sorbent (Lime) Railcar Dump Pit

(Insignificant Source - ID No. 020)

Sorbent is transported from the railcar dump pit in enclosed conveyors to the storage area. Emissions can be best estimated using the drop equation.

From section 13.2.4 of the AP-42: The following equation represents the particulate emissions generated by the dropping of sorbent into the dump pit.

$$E = k (0.0032) \frac{(u/5)^{1.3}}{(m/2)^{1.4}}$$

E = Emission Factor (lb/ton)

k = Particle Size Multiplier

u = Mean Wind Speed (mph)

m = Material Moisture Content (%)

k Value	Particulate Size	Emission Factor (lb/ton)
0.74	PM	1.787E-03
0.35	PM-10	8.45E-04
0.11	PM-2.5	2.66E-04

Average moisture content of sorbent is 0.7%

The dump area is fully enclosed, therefore the minimum wind speed of 1.3 mph was used.

**Total Sorbent            19,802 tons/yr**

*Emissions from the unloading of sorbent into the dump pit:*

	Emission Factor (lb/ton)	Emissions (lb/yr)	Emissions (ton/yr)
PM	1.79E-03	35.39	1.77E-02
PM-10	8.45E-04	16.74	8.37E-03
PM-2.5	2.66E-04	5.26	2.63E-03