

Cogeneration Facility 2014 Annual Air Emissions Inventory

**The University of North Carolina at Chapel Hill
Chapel Hill, North Carolina**

**Facility ID # 6800043
Permit # 03069T32**

Prepared for:

The University of North Carolina at Chapel Hill
Department of Environment, Health, and Safety
1120 Estes Drive Extension
Chapel Hill, North Carolina 27599-1650

Prepared by:

RST Engineering
5416 Orchard Oriole Trail
Wake Forest, North Carolina 27587-6770

June 2015

Cogeneration Facility 2014 Annual Air Emissions Inventory

**The University of North Carolina at Chapel Hill
Chapel Hill, North Carolina**

Facility ID # 6800043

Permit # 03069T32

Prepared for:

The University of North Carolina at Chapel Hill

Department of Environment, Health, and Safety

1120 Estes Drive Extension

Chapel Hill, North Carolina 27599-1650

Prepared by:

RST Engineering

5416 Orchard Oriole Trail

Wake Forest, North Carolina 27587-6770

June 2015

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Cogeneration Emissions Inventory

Table of Contents

Supporting Documentation

Cogeneration Facility Boiler Fuel Usage

Cogeneration Facility Boiler Coal Usage

Blackstart Generator Fuel Usage

Emissions Calculations

<u>ES ID</u>	<u>Source/Operating Scenario Description</u>
ES-001	Boiler #6 <ul style="list-style-type: none">- No. 2 Fuel Oil Firing- Wood Pellet Firing- Coal Firing- Natural Gas Firing- No. 6 Fuel Oil Firing
ES-002	Boiler #7 <ul style="list-style-type: none">- Wood Pellet Firing- No. 2 Fuel Oil Firing- Coal Firing- Natural Gas Firing- No. 6 Fuel Oil Firing
ES-003	Boiler #8 <ul style="list-style-type: none">- Natural Gas Firing- No. 2 Fuel Oil Firing
ES-007-ES-008	Two Blackstart Generators at the Cogeneration Facility
ES-010	Enclosed Railcar Dump Pits
ES-1, ES-2	Coal Storage Silos
ES-3.1 - ES-3.5	Silo Conveyors
T-001	Fuel Oil Storage Tank
T-002	Fuel Oil Storage Tank
ES-010A	Coal Crusher/Conveyor Building
ES-030	Ash Silo with Loadout
ES-030A	Wet Ash Loadout
IS-53	Enclosed Sorbent Railcar Dump Pit

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina
 Orange County
 Facility ID # 6800043
 Permit # 03069T32

2014 Annual Emissions Inventory

Cogeneration Boilers

Seasonal Fuel Usage Breakdown

Month	Boiler #6				Boiler #7				Boiler #8	
	Coal (tons)	Wood(tons)	Gas (1,000cf)	Oil (gallons)	Coal (tons)	Wood(tons)	Gas (1,000cf)	Oil (gallons)	Gas (1,000cf)	Oil (gallons)
December 2014	4,417	0	8,946	0	5,007	0	318	0	3,587	0
January 2014	6,396	0	8,202	133	7,156	0	0	28	3,778	3,222
February 2014	6,145	0	10	3,237	4,840	0	460	2,507	661	0
<i>1st Quarter Total</i>	<i>16,957</i>	<i>0</i>	<i>17,158</i>	<i>3,370</i>	<i>17,003</i>	<i>0</i>	<i>778</i>	<i>2,535</i>	<i>8,026</i>	<i>3,222</i>
March 2014	6,081	0	0	0	3,303	0	150	0	1,120	0
April 2014	4,461	0	1,379	0	1,729	0	1,801	0	300	0
May 2014	3,542	0	10	0	3,031	0	7,940	0	1,350	0
<i>2nd Quarter Total</i>	<i>14,083</i>	<i>0</i>	<i>1,389</i>	<i>0</i>	<i>8,062</i>	<i>0</i>	<i>9,891</i>	<i>0</i>	<i>2,770</i>	<i>0</i>
June 2014	3,622	0	52	0	3,195	0	6,902	0	1,266	0
July 2014	3,565	0	64	0	3,518	0	107	0	15,630	0
August 2014	732	0	337	0	2,785	0	1,508	0	35,641	0
<i>3rd Quarter Total</i>	<i>7,918</i>	<i>0</i>	<i>453</i>	<i>0</i>	<i>9,498</i>	<i>0</i>	<i>8,517</i>	<i>0</i>	<i>52,537</i>	<i>0</i>
September 2014	0	0	600	0	4,063	0	12,931	0	4,601	0
October 2014	140	0	47,360	0	3,575	0	120	0	0	0
November 2014	2,606	0	15,336	0	3,528	0	739	0	8,715	92
<i>4th Quarter Total</i>	<i>2,746</i>	<i>0</i>	<i>63,297</i>	<i>0</i>	<i>11,167</i>	<i>0</i>	<i>13,789</i>	<i>0</i>	<i>13,316</i>	<i>92</i>
2014 TOTAL	41,704	0	82,296	3,370	45,730	0	32,975	2,535	76,649	3,314

Seasonal Btu Breakdown

Coal (btu/lb)	12,450	Wood (btu/lb)	8,185	Natural Gas (btu/ft ³)	1,030	Fuel Oil (btu/gal)	137,204
---------------	--------	---------------	-------	------------------------------------	-------	--------------------	---------

Month	Boiler #6				Boiler #7				Boiler #8	
	Coal	Wood	Gas	Oil	Coal	Wood	Gas	Oil	Gas	Oil
December 2014	1.10E+11	0.00E+00	9.21E+09	0.00E+00	1.25E+11	0.00E+00	3.27E+08	0.00E+00	3.69E+09	0.00E+00
January 2014	1.59E+11	0.00E+00	8.45E+09	1.83E+07	1.78E+11	0.00E+00	0.00E+00	3.83E+06	3.89E+09	4.42E+08
February 2014	1.53E+11	0.00E+00	1.03E+07	4.44E+08	1.21E+11	0.00E+00	4.74E+08	3.44E+08	6.81E+08	0.00E+00
<i>1st Quarter Total</i>	<i>4.22E+11</i>	<i>0.00E+00</i>	<i>1.77E+10</i>	<i>4.62E+08</i>	<i>4.23E+11</i>	<i>0.00E+00</i>	<i>8.01E+08</i>	<i>3.48E+08</i>	<i>8.27E+09</i>	<i>4.42E+08</i>
March 2014	1.51E+11	0.00E+00	0.00E+00	0.00E+00	8.22E+10	0.00E+00	1.55E+08	0.00E+00	1.15E+09	0.00E+00
April 2014	1.11E+11	0.00E+00	1.42E+09	0.00E+00	4.30E+10	0.00E+00	1.86E+09	0.00E+00	3.09E+08	0.00E+00
May 2014	8.82E+10	0.00E+00	1.03E+07	0.00E+00	7.55E+10	0.00E+00	8.18E+09	0.00E+00	1.39E+09	0.00E+00
<i>2nd Quarter Total</i>	<i>3.51E+11</i>	<i>0.00E+00</i>	<i>1.43E+09</i>	<i>0.00E+00</i>	<i>2.01E+11</i>	<i>0.00E+00</i>	<i>1.02E+10</i>	<i>0.00E+00</i>	<i>2.85E+09</i>	<i>0.00E+00</i>
June 2014	9.02E+10	0.00E+00	5.38E+07	0.00E+00	7.96E+10	0.00E+00	7.11E+09	0.00E+00	1.30E+09	0.00E+00
July 2014	8.88E+10	0.00E+00	6.59E+07	0.00E+00	8.76E+10	0.00E+00	1.10E+08	0.00E+00	1.61E+10	0.00E+00
August 2014	1.82E+10	0.00E+00	3.47E+08	0.00E+00	6.93E+10	0.00E+00	1.55E+09	0.00E+00	3.67E+10	0.00E+00
<i>3rd Quarter Total</i>	<i>1.97E+11</i>	<i>0.00E+00</i>	<i>4.66E+08</i>	<i>0.00E+00</i>	<i>2.37E+11</i>	<i>0.00E+00</i>	<i>8.77E+09</i>	<i>0.00E+00</i>	<i>5.41E+10</i>	<i>0.00E+00</i>
September 2014	0.00E+00	0.00E+00	6.18E+08	0.00E+00	1.01E+11	0.00E+00	1.33E+10	0.00E+00	4.74E+09	0.00E+00
October 2014	3.48E+09	0.00E+00	4.88E+10	0.00E+00	8.90E+10	0.00E+00	1.24E+08	0.00E+00	0.00E+00	0.00E+00
November 2014	6.49E+10	0.00E+00	1.58E+10	0.00E+00	8.79E+10	0.00E+00	7.61E+08	0.00E+00	8.98E+09	1.26E+07
<i>4th Quarter Total</i>	<i>6.84E+10</i>	<i>0.00E+00</i>	<i>6.52E+10</i>	<i>0.00E+00</i>	<i>2.78E+11</i>	<i>0.00E+00</i>	<i>1.42E+10</i>	<i>0.00E+00</i>	<i>1.37E+10</i>	<i>1.26E+07</i>
2014 TOTAL	1.04E+12	0.00E+00	8.48E+10	4.62E+08	1.14E+12	0.00E+00	3.40E+10	3.48E+08	7.89E+10	4.55E+08

Total

2.38E+12

2.30E+12 B6&B7

Seasonal Total Fuel Usage (%)

	B6&7 % Total HI	Cogen Only % Total HI	Cogen&MDSP % Total HI
Coal	94.80%	91.63%	#REF!
Gas	5.17%	8.32%	#REF!
Oil	0.04%	0.05%	#REF!
	100.0%	100.0%	#REF!

	Boiler #6	Boiler #7	Boiler #8
Dec., Jan., Feb.	39.19	36.19	10.97
Mar., Apr., May	31.34	17.98	4
June, July, Aug.	17.59	20.91	68.15
Sept., Oct., Nov.	11.89	24.92	17.29
	100	100	100

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Coal Usage Breakdown

Month	Boiler #6 Coal (tons)	Boiler #7 Coal (tons)
December 2014	4,417	5,007
January 2014	6,396	7,156
February 2014	6,145	4,840
<i>1st Quarter Total</i>	16,957	17,003
March 2014	6,081	3,303
April 2014	4,461	1,729
May 2014	3,542	3,031
<i>2nd Quarter Total</i>	14,083	8,062
June 2014	3,622	3,195
July 2014	3,565	3,518
August 2014	732	2,785
<i>3rd Quarter Total</i>	7,918	9,498
September 2014	0	4,063
October 2014	140	3,575
November 2014	2,606	3,528
<i>4th Quarter Total</i>	2,746	11,167
2014 TOTAL	41,704	45,730

Facility-Wide Coal Usage 87,434 Tons/year

Seasonal Coal Usage (%)

	Boiler #6	Boiler #7	Average (%)
Dec., Jan., Feb.	40.66%	37.18%	38.92%
Mar., Apr., May	33.77%	17.63%	25.70%
June, July, Aug.	18.99%	20.77%	19.88%
Sept., Oct., Nov.	6.58%	24.42%	15.50%
	100%	100%	100%

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Blackstart Generator Fuel Usage Breakdown

Month	DG1 & DG2 #2 Oil (gallons)
December 2014	151
January 2014	9014
February 2014	0
<i>1st Quarter Total</i>	9,164
March 2014	870
April 2014	461
May 2014	269
<i>2nd Quarter Total</i>	1,600
June 2014	2
July 2014	202
August 2014	236
<i>3rd Quarter Total</i>	440
September 2014	0
October 2014	102
November 2014	245
<i>4th Quarter Total</i>	347
2014 TOTAL	11,551

Seasonal Oil Usage (%)

	DG1 & DG2
Dec., Jan., Feb.	79.34%
Mar., Apr., May	13.85%
June, July, Aug.	3.81%
Sept., Oct., Nov.	3.00%
	100%

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Supporting Documentation

Facility Summary Forms

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler #6 (ES-001-Boiler #6)

Operating Scenarios

#1 - Coal Firing

#2 - Natural Gas Firing

#4 - No.2 Fuel Oil Firing

#5 - Wood Pellet Firing

(#3 - No.6 Fuel Oil Firing is no longer permitted)

Boilers #6 and #7 are equipped with Continuous Emission Monitoring (CEMs) devices to measure SO₂, NO_x, and CO₂ emissions from each of the boilers. The monthly averages presented in the attached spreadsheets are for the total emissions from firing all types of fuel. The 2014 Annual Emission Inventory forms require that the emissions be divided among the four possible operating scenarios.

NO_x and CO₂ emissions have been divided between the four operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

SO₂ emissions from natural gas and wood pellet combustion are insignificant, therefore, SO₂ emissions have been divided between the fuel oil and coal operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

Emissions Calculations

SO₂, NO_x, and CO₂ Emissions are taken from CEMs data
Other emission factors are from stack test or DAQ spreadsheets

Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #1 - Coal					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		41,704				tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	1.71%	% Ash	10.65%	Heat Content (Btu/lb or mmCF)	12,473 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	40.66%	Mar-May	33.77%	June-Aug	18.99%	Sept-Nov	6.58%
------------------------------	--------	---------	--------	----------	--------	----------	-------

Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	17.74	8	N/A
NOx	NOx	113.57	1	N/A
PM Total	PM	4.40	8	99.80%
PM-2.5	PM-2.5	2.54	8	97.90%
PM-10	PM-10	4.40	8	99.60%
SO2	SO2	85.79	1	90.00%
VOC	VOC	0.24	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	23.77	8	N/A
Acetophenone	98-86-2	0.63	8	N/A
Acrolein	107-02-8	12.09	8	N/A
Arsenic*	ARSENICPDS	0.31	8	99.60%
Benzene	71-43-2	54.22	8	N/A
Benzo(a)pyrene	50-32-8	1.58E-03	8	N/A
Benzyl chloride	100-44-7	29.19	8	N/A
Beryllium*	BERYLCPDS	0.05	8	N/A
Biphenyl	92-52-4	7.09E-02	8	N/A
Bis(2-ethylhexyl)phthalate (DEHP)	117-81-7	3.04	8	N/A
Bromine	7726-95-6	8.53	8	99.60%
Bromoform	75-25-2	1.63	8	N/A
Cadmium*	CADMIUMCPDS	1.45E-01	8	99.60%
Carbon disulfide	75-10-0	5.42	8	N/A
2-Chloroacetophenone	532-27-4	0.29	8	N/A
Chlorobenzene	108-90-7	0.92	8	N/A
Chloroform	67-66-3	2.46	8	N/A
Chromium*	CROMCPDS	4.99	8	99.60%
Chromium (VI)	CHROM6CPDS	0.01	8	99.60%
Cumene	98-82-8	0.22	8	N/A
Cyanide	CNC	104.26	8	N/A
Dibenzofurans	132-64-9	8.38E-03	8	N/A
Dimethyl sulfate	77-78-1	2.00	8	N/A
2,4-Dinitrotoluene	121-14-2	1.17E-02	8	N/A
Ethyl benzene	100-41-4	3.92	8	N/A
Ethyl chloride	75-00-3	1.75	8	N/A
Ethylene dibromide	106-93-4	5.00E-02	8	N/A
Ethylene dichloride	107-06-2	1.67	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Formaldehyde*	50-0-00	68.46	8	N/A
Hexane	HEXANEISO	2.79	8	N/A
Hydrogen Chloride *	7647-01-0	13316.52	8	N/A
Hydrogen Fluoride *	7664-39-3	239.28	8	90% Control with CaCO ₃
Isophorone	78-59-1	24.19	8	N/A
Lead*	LEADCPDS	1.83	8	99.60%
Manganese*	MANGCPDS	12.48	8	99.60%
Mercury*	MERCCPDS	0.87	8	N/A
Methyl bromide	74-83-9	6.67	8	N/A
Methyl chloride	74-87-3	22.10	8	N/A
Methyl ethyl ketone	78-93-3	16.26	8	N/A
Methyl hydrazine	60-34-4	7.09	8	N/A
Methyl methacrylate	80-62-6	0.83	8	N/A
Methyl tert butyl ether	1634-04-4	1.46	8	N/A
Methylene chloride	75-09-2	12.09	8	N/A
Naphthalene	91-20-3	0.54	8	N/A
Nickel	NICKCPDS	10.16	8	99.60%
Phenol	108-95-2	0.67	8	N/A
POM	POM	2.33	8	N/A
Propionaldehyde	123-38-6	15.85	8	N/A
Styrene	100-42-5	1.04	8	N/A
2,3,7,8-TCDD	1746-01-6	5.96E-07	8	N/A
Tetrachloroethylene	79-34-5	1.79	8	N/A
Toluene	108-88-3	10.01	8	N/A
1,1,1-Trichloroethane	79-00-5	0.83	8	N/A
Vinyl acetate	108-05-4	0.32	8	N/A
Xylenes	1330-20-7	1.54	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	132,222.55	8	N/A
Methane	CH ₄	0.20	8	N/A
Nitrous oxide	N ₂ O	1.83	8	N/A

Boiler #6 - Operating Scenario #3 - Natural Gas

If Emission Source has multiple Operating Scenarios, complete one form for each.

(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #2 - Natural Gas					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		82,296			1,000 ft ³ /yr		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	1,030 Btu/ft ³

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8059 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	20.85%	Mar-May	1.69%	June-Aug	0.55%	Sept-Nov	76.91%
------------------------------	--------	---------	-------	----------	-------	----------	--------

Boiler #6 - Operating Scenario #3 - Natural Gas

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	3.46	8	N/A
NOx	NOx	9.25	1	N/A
PM Total	PM	0.31	8	N/A
PM-2.5	PM-2.5	0.31	8	N/A
PM-10	PM-10	0.31	8	N/A
SO2	SO2	0.00	1	N/A
VOC	VOC	0.23	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	1.65E-02	8	N/A
Benzene	71-43-2	0.17	8	N/A
Cadmium	CADMIUMCPDS	9.05E-02	8	N/A
Chromium	CROMCPDS	1.15E-01	8	N/A
Chromium VI	CHROM6CPDS	1.15E-01	8	N/A
Dichlorobenzene	106-46-7	9.88E-02	8	N/A
Formaldehyde	50-00-0	6.17	8	N/A
Hexane	HEXANEISO	148.13	8	N/A
Lead	LEADCPDS	4.11E-02	8	N/A
Manganese	MANGCPDS	3.13E-02	8	N/A
Mercury	MERCPDS	2.14E-02	8	N/A
Napthalene	91-20-3	5.02E-02	8	N/A
Nickel	NICKCPDS	0.17	8	N/A
POM	POM	5.45E-02	8	N/A
Toluene	108-88-3	0.28	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	6,128.03	8	N/A
Methane	CH ₄	9.344E-02	8	N/A
Nitrous oxide	N ₂ O	9.344E-03	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #6 - Operating Scenario #4 - No. 2 Fuel Oil

If Emission Source has multiple Operating Scenarios, complete one form for each.

(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #4 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		3,370				gallons/yr	
6. Fuel Information (if fuel used)		% Sulfur	0.002%	% Ash		Heat Content (Btu/lb or mmCF)	137,204 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8,057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	100.00%	Mar-May	0.00%	June-Aug	0.00%	Sept-Nov	0.00%
------------------------------	---------	---------	-------	----------	-------	----------	-------

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	8.43E-03	8	N/A
NOx	NOx	5.05E-02	1	N/A
PM Total	PM	2.22E-03	8	99.0%
PM-2.5	PM-2.5	5.56E-04	8	99.0%
PM-10	PM-10	2.22E-03	8	99.0%
SO2	SO2	3.81E-02	1	90.0%
VOC	VOC	3.37E-04	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Antimony	ANTIMONYPDS	0.00E+00	8	99.0%
Arsenic	ARSENICPDS	1.89E-05	8	99.0%
Benzene	71-43-2	9.27E-03	8	N/A
Beryllium	BERYLCPDS	1.42E-05	8	99.0%
Cadmium	CADMIUMCPDS	1.42E-05	8	99.0%
Chromium	CROMCPDS	1.42E-05	8	99.0%
Chromium VI	CHROM6CPDS	4.15E-06	8	99.0%
Cobalt	COBALTCPDS	0.00E+00	8	99.0%
Ethylbenzene	100-41-4	2.75E-03	8	N/A
Fluoride	16984-48-8	0.13	8	N/A
Formaldehyde	50-00-0	0.16	8	N/A
Lead	LEADCPDS	4.25E-05	8	99.0%
Manganese	MANGCPDS	2.83E-05	8	99.0%
Mercury	MERCPDS	1.42E-03	8	99.0%
Methyl chloroform	71-55-6	7.95E-04	8	N/A
Napthalene	91-20-3	1.12E-05	8	N/A
Nickel	NICKCPDS	1.42E-05	8	99.0%
POM	POM	1.11E-04	8	99.0%
Selenium	SEC	7.08E-05	8	99.0%
Toluene	108-88-3	0.27	8	N/A
Xylene	1330-20-7	4.72E-03	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	46.60	8	N/A
Methane	CH ₄	1.53E-03	8	N/A
Nitrous oxide	N ₂ O	3.06E-04	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #6 - Operating Scenario #5 - Wood Pellets
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043
 Permit #: 03069T32
 County: Orange
 DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-001-Boiler #6					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #5 - Wood Pellets					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		64.63 MMBtu/hr (20% HI from wood pellets)					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			0.0			tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	NA	% Ash	NA	Heat Content (Btu/lb or mmCF)	8,125 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	#DIV/0!	Mar-May	#DIV/0!	June-Aug	#DIV/0!	Sept-Nov	#DIV/0!
------------------------------	---------	---------	---------	----------	---------	----------	---------

Boiler #6 - Operating Scenario #5 - Wood Pellets
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.000	8	N/A
NOx	NOx	0.000	1	N/A
PM Total	PM	0.00000	8	99.80%
PM-2.5	PM-2.5	0.00000	8	97.90%
PM-10	PM-10	0.00000	8	99.60%
SO2	SO2	CEM w/coal	1	90.00%
VOC	VOC	0.0000	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	0.00E+00	8	N/A
Acetophenone	98-86-2	0.00E+00	8	N/A
Acrolein	107-02-8	0.00E+00	8	N/A
Antimony	7440-36-0	0.00E+00	8	99.60%
Arsenic	ARSENICPDS	0.00E+00	8	99.60%
Benzene	71-43-2	0.00E+00	8	N/A
Benzo(a)pyrene	50-32-8	0.00E+00	8	N/A
Beryllium	BERYLCPDS	0.00E+00	8	99.60%
Cadmium	CADMIUMCPDS	0.00E+00	8	99.60%
Carbon tetrachloride	56-23-5	0.00E+00	8	N/A
Chlorine	7782-50-5	0.00E+00	8	N/A
Chlorobenzene	108-90-7	0.00E+00	8	N/A
Chloroform	67-66-3	0.00E+00	8	N/A
Chromium	CROMCPDS	0.00E+00	8	99.60%
Cobalt	7440-48-4	0.00E+00	8	99.60%
Di(2-ethylhexy)phthalate	117-81-7	0.00E+00	8	N/A
Dinitrophenol, 2,4-	51-28-5	0.00E+00	8	N/A
Ethyl benzene	100-41-4	0.00E+00	8	N/A
Ethylene dichloride	107-06-2	0.00E+00	8	N/A
Formaldehyde*	50-0-00	0.00E+00	8	N/A
Hexachlorodib-dioxin	57653-85-7	0.00E+00	8	N/A
Hydrogen Chloride *	7647-01-0	0.00E+00	8	68% Control with CaCO ₃
Lead*	LEADCPDS	0.00E+00	8	99.60%
Manganese*	MANGCPDS	0.00E+00	8	99.60%
Mercury*	MERCCPDS	0.00E+00	8	92%
Methyl bromide	74-83-9	0.00E+00	8	N/A
Methyl chloride	74-87-3	0.00E+00	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #6 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-001-Boiler #6

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Methyl chloroform	71-55-6	0.00E+00	8	N/A
Methyl ethyl ketone	78-93-3	0.00E+00	8	N/A
Methylene chloride	75-09-2	0.00E+00	8	N/A
Naphthalene	91-20-3	0.00E+00	8	N/A
Nickel	NICKCPDS	0.00E+00	8	99.60%
Nitrophenol, 4-	100-02-07	0.00E+00	8	N/A
Pentachlorophenol	87-86-5	0.00E+00	8	N/A
Perchloroethylene	127-18-4	0.00E+00	8	N/A
Phenol	108-95-2	0.00E+00	8	N/A
Phosphorus	7723-14-0	0.00E+00	8	99.60%
Polychlorinated biphenyls	1336-36-3	0.00E+00	8	N/A
POM	POM	0.00E+00	8	N/A
Propionaldehyde	123-38-6	0.00E+00	8	N/A
Propylene dichloride	78-87-5	0.00E+00	8	N/A
Selenium	7782-49-2	0.00E+00	8	99.60%
Styrene	100-42-5	0.00E+00	8	N/A
2,3,7,8-TCDD	1746-01-6	0.00E+00	8	N/A
Toluene	108-88-3	0.00E+00	8	N/A
Trichloroethylene	79-01-6	0.00E+00	8	N/A
Trichlorofluoromethane	75-69-4	0.00E+00	8	N/A
Trichlorophenol	95-95-4	0.00E+00	8	N/A
Vinyl chloride	75-01-4	0.00E+00	8	N/A
Xylenes	1330-20-7	0.00E+00	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	0.00	8	N/A
Methane	CH ₄	0.0000	8	N/A
Nitrous oxide	N ₂ O	0.0000	8	N/A

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler #6

(ES-001-Boiler #6)

Emissions Calculations

SO₂, NO_x, and CO₂ Emissions are Taken from CEMs Data
Other emission factors are from stack test or DAQ spreadsheets

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #6**
 (ES-001-Boiler #6)

Operating Scenario #1

Data Input

Maximum Heat Input	<input style="width: 90%;" type="text" value="323.17"/>	mmBtu/hr	Boiler Type:	<input style="width: 60%;" type="text" value="7"/>
Boiler Size/Type	Large Industrial		1) Pulverized/Dry Bottom	6) Underfeed Stoker
Actual Fuel Usage	<input style="width: 90%;" type="text" value="41,704"/>	ton/yr	2) Pulverized/Wet Bottom	7) Fluidized Bed Cir.
or	or		3) Cyclone Furnace	8) Fluidized Bed Bub.
Hours of Operation	<input style="width: 90%;" type="text"/>	hr/yr	4) Spreader Stoker	9) Hand Fed
and	and		5) Overfeed Stoker	
Heating Value	<input style="width: 90%;" type="text" value="12,473"/>	Btu/lb	Control Device Efficiencies:	
		ton/yr	PM	<input style="width: 60%;" type="text" value="99.80"/> %
Sulfur Content	<input style="width: 90%;" type="text" value="1.71"/>	%	PM-10	<input style="width: 60%;" type="text" value="98.00"/> %
Ash Content :	<input style="width: 90%;" type="text" value="10.65"/>	%	PM-2.5	<input style="width: 60%;" type="text" value="97.90"/> %
(B)ituminous or (S)ubbituminous?	<input style="width: 90%;" type="text" value="B"/>	(B/S)	SOx*	<input style="width: 60%;" type="text" value="90.00"/> %
Calcium to Sulfur Ratio	<input style="width: 90%;" type="text" value="2.22"/>		NOx*	<input style="width: 60%;" type="text" value="0.00"/> %

***SOx and NOx emission estimates were calculated using CEMS data. Please refer to the SOx and NOx emissions data presented in the following CEMs spreadsheets.
 HCl, HF, and Hg emissions based on stack test data.**

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #6**
 (ES-001-Boiler #6)

Operating Scenario #1

ACTUAL CRITERIA EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
PM*	0.21	2.73	8,796	4.40
PM-10*	0.21	2.73	8,796	4.40
PM-2.5*	0.12	1.58	5,072	2.54
SO2	14.88	**	**	**
SO3	0.10	**	**	**
NOx	3.90	**	**	**
VOC*	0.01	0.15	479	0.24
CO*	0.85	11.02	35,476	17.74

ACTUAL TOXIC EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Acetaldehyde	5.70E-04	7.38E-03	2.38E+01	1.19E-02
Acetophenone	1.50E-05	1.94E-04	6.26E-01	3.13E-04
Acrolein	2.90E-04	3.76E-03	1.21E+01	6.05E-03
Antimony*	8.06E-06	1.04E-04	3.36E-01	1.68E-04
Arsenic*	7.51E-06	9.73E-05	3.13E-01	1.57E-04
Benzene	1.30E-03	1.68E-02	5.42E+01	2.71E-02
Benzo(a)pyrene	3.80E-08	4.92E-07	1.58E-03	7.92E-07
Benzyl chloride	7.00E-04	9.07E-03	2.92E+01	1.46E-02
Beryllium*	1.32E-06	1.71E-05	5.49E-02	2.75E-05
Biphenyl	1.70E-06	2.20E-05	7.09E-02	3.54E-05
Bis(2-ethylhexyl)phthalate (DEHP)	7.30E-05	9.46E-04	3.04E+00	1.52E-03
Bromine	1.02E-01	2.65E-03	8.53E+00	4.27E-03
Bromoform	3.90E-05	5.05E-04	1.63E+00	8.13E-04
Cadmium*	3.47E-06	4.49E-05	1.45E-01	7.23E-05
Carbon disulfide	1.30E-04	1.68E-03	5.42E+00	2.71E-03
2-Chloroacetophenone	7.00E-06	9.07E-05	2.92E-01	1.46E-04
Chlorobenzene	2.20E-05	2.85E-04	9.17E-01	4.59E-04
Chlorine*	2.69E-03	3.49E-02	1.12E+02	5.62E-02
Chloroform	5.90E-05	7.64E-04	2.46E+00	1.23E-03
Chromium*	1.20E-04	1.55E-03	4.99E+00	2.50E-03
Chromium (VI)	1.20E-04	3.10E-06	9.99E-03	4.99E-06
Cobalt*	6.89E-06	8.92E-05	2.87E-01	1.44E-04
Cumene	5.30E-06	6.87E-05	2.21E-01	1.11E-04
Cyanide	2.50E-03	3.24E-02	1.04E+02	5.21E-02
Dibenzofurans	2.01E-07	2.60E-06	8.38E-03	4.19E-06
Dimethyl sulfate	4.80E-05	6.22E-04	2.00E+00	1.00E-03
2,4-Dinitrotoluene	2.80E-07	3.63E-06	1.17E-02	5.84E-06
Ethyl benzene	9.40E-05	1.22E-03	3.92E+00	1.96E-03
Ethyl chloride	4.20E-05	5.44E-04	1.75E+00	8.76E-04
Ethylene dibromide	1.20E-06	1.55E-05	5.00E-02	2.50E-05
Ethylene dichloride	4.00E-05	5.18E-04	1.67E+00	8.34E-04
Formaldehyde*	1.64E-03	2.13E-02	6.85E+01	3.42E-02
Hexane	6.70E-05	8.68E-04	2.79E+00	1.40E-03
Hydrogen Chloride *	3.19E-01	4.14E+00	1.33E+04	6.66E+00
Hydrogen Fluoride *	5.74E-03	7.43E-02	2.39E+02	1.20E-01
Isophorone	5.80E-04	7.51E-03	2.42E+01	1.21E-02
Lead*	4.39E-05	5.69E-04	1.83E+00	9.16E-04

**SO₂ and NO_x emissions were estimated using CEMS data, please refer to the attached data sheets entitled "Sulfur Dioxide Emissions from Boiler #6" and Nitrogen Dioxide Emissions from Boiler #6".

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #6**
 (ES-001-Boiler #6)

Operating Scenario #1

ACTUAL TOXIC EMISSIONS (continued)

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
<i>Manganese*</i>	2.99E-04	3.88E-03	1.25E+01	6.24E-03
<i>Mercury*</i>	2.09E-05	2.70E-04	8.71E-01	4.35E-04
Methyl bromide	1.60E-04	2.07E-03	6.67E+00	3.34E-03
Methyl chloride	5.30E-04	6.87E-03	2.21E+01	1.11E-02
Methyl ethyl ketone	3.90E-04	5.05E-03	1.63E+01	8.13E-03
Methyl hydrazine	1.70E-04	2.20E-03	7.09E+00	3.54E-03
Methyl methacrylate	2.00E-05	2.59E-04	8.34E-01	4.17E-04
Methyl tert butyl ether	3.50E-05	4.53E-04	1.46E+00	7.30E-04
Methylene chloride	2.90E-04	3.76E-03	1.21E+01	6.05E-03
Naphthalene	1.30E-05	1.68E-04	5.42E-01	2.71E-04
<i>Nickel*</i>	2.44E-04	3.16E-03	1.02E+01	5.08E-03
Phenol	1.60E-05	2.07E-04	6.67E-01	3.34E-04
<i>Phosphorus*</i>	3.64E-05	4.72E-04	1.52E+00	7.59E-04
POM	5.59E-05	7.24E-04	2.33E+00	1.17E-03
Propionaldehyde	3.80E-04	4.92E-03	1.58E+01	7.92E-03
<i>Selenium*</i>	5.36E-06	6.95E-05	2.24E-01	1.12E-04
Styrene	2.50E-05	3.24E-04	1.04E+00	5.21E-04
2,3,7,8-TCDD	1.43E-11	1.85E-10	5.96E-07	2.98E-10
Tetrachloroethylene	4.30E-05	5.57E-04	1.79E+00	8.97E-04
Toluene	2.40E-04	3.11E-03	1.00E+01	5.00E-03
1,1,1-Trichloroethane	2.00E-05	2.59E-04	8.34E-01	4.17E-04
Vinyl acetate	7.60E-06	9.85E-05	3.17E-01	1.58E-04
Xylenes	3.70E-05	4.79E-04	1.54E+00	7.72E-04
Total HAPs		4.39	14,145.89	7.07

Greenhouse Gases

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Carbon dioxide			see attached CEMs-based calculations	
<i>Methane*</i>	0.009	0.12	395.33	0.20
Nitrous Oxide	0.09	1.14	3,670	1.83

*Emission rates for pollutants in italics from August 2009 Section 114 test of Boiler #6.

Notes :

- 1) Emission factors are from Supplement B to the 5th edition of AP-42, unless otherwise noted
- 2) Emission calculations will be based on the hours of operation only when actual fuel usage is not supplied
- 3) Particulate controls affect PM, PM-10, PM-2.5, and all toxics that are regulated as particulates except Mercury
- 4) VOC = NMTOC = TOC * (1-%METHANE)
- 5) PM-2.5 and SO3 do not currently need to be reported
- 6) Dibenzofurans = Polychlorinated dibenzo-p-furans
- 7) The Br emission factor is based on a mass balance generated from a 3 year coal analysis for Duke Power (1990-1992, 7 samples per year). The average concentration of bromine was 55.33 ppm (wet basis) and a heating value of 13,500 Btu/lb was assumed
- 8) For fluidized bed combustion the emission factor for underfeed stokers is utilized whenever the calcium-to-sulfur ratio is outside of the acceptable range of 1.5 to 7

**Natural Gas Combustion Emissions Calculator NG2000 Revision C
2014 Annual Emissions Inventory**

Boiler #6

(ES-001-Boiler #6)

Facility ID # 6800043

Permit # 03069T32

Operating Scenario #2

User Input		Emissions Output				
Company Name:	University of North Carolina at Chapel Hill	Criteria Pollutants			Emission Factor (lb/mmscf)	
Plant County:	Orange County	Pollutant	lb/hr	lb/yr	tpy	
Plant City:	Chapel Hill	PM	2.4E+00	6.3E+02	3.1E-01	7.6E+00
Permit Number:	03069T32	PM-10	2.4E+00	6.3E+02	3.1E-01	7.6E+00
User:	RST Engineering	PM-2.5	2.4E+00	6.3E+02	3.1E-01	7.6E+00
Heat Input Capacity (mmBtu/hr):	323.17	NOx	see attached CEMs-based calculations			1.9E+02
Fuel Input Capacity (10 ⁶ scf/hr):	0.32	VOC	1.7E+00	4.5E+02	2.3E-01	5.5E+00
Annual Fuel Throughput (10 ⁶ scf):	82.30	CO	2.7E+01	6.9E+03	3.5E+00	8.4E+01
Latest Construction/Modification Date:	N/A	SO2	see attached CEMs-based calculations			6.0E-01
Enter the boiler type below ▾		Total HAP	6.0E-01	1.6E+02	7.8E-02	1.9E+00
2		Largest HAP	5.7E-01	1.5E+02	7.4E-02	1.8E+00
Other NOx Control		Toxic/Hazardous Air Pollutants				
4		Pollutant	lb/hr	lb/day	lb/yr	
Large Wall-Fired Boilers (=>100 mmBtu/hr)		Arsenic	6.3E-05	NA	1.6E-02	2.0E-04
1 = Uncontrolled (Pre-NSPS)		Benzene	6.7E-04	NA	1.7E-01	2.1E-03
2 = Uncontrolled (Post-NSPS)		Cadmium	3.5E-04	NA	9.1E-02	1.1E-03
3 = Controlled - Low NOx burners		Chromium	4.4E-04	NA	1.2E-01	1.4E-03
4 = Controlled - Flue gas recirculation (FGR)		Chromium VI	4.4E-04	NA	1.2E-01	1.4E-03
Small Boilers (<100 mmBtu/hr)		Dichlorobenzene	3.8E-04	NA	9.9E-02	1.2E-03
5 = Uncontrolled		Formaldehyde	2.4E-02	NA	6.2E+00	7.5E-02
6 = Controlled - Low NOx burners		Hexane	5.7E-01	1.4E+01	1.5E+02	1.8E+00
7 = Controlled - Low NOx burners/FGR		Lead	1.6E-04	NA	4.1E-02	5.0E-04
Tangential-Fired Boilers (All Sizes)		Manganese	1.2E-04	2.9E-03	3.1E-02	3.8E-04
8 = Uncontrolled		Mercury	8.2E-05	2.0E-03	2.1E-02	2.6E-04
9 = Controlled - FGR		Naphthalene	1.9E-04	NA	5.0E-02	6.1E-04
Residential Furnaces (<0.3 mmBtu/hr)		Nickel	6.7E-04	1.6E-02	1.7E-01	2.1E-03
10 = Uncontrolled		POM	2.1E-04	NA	5.4E-02	6.6E-04
		Toluene	1.1E-03	2.6E-02	2.8E-01	3.4E-03
		Greenhouse Gas Pollutants				
		Pollutant	lb/hr	lb/yr	tpy	Em. Factor (lb/mmBtu)
		Carbon dioxide	see attached CEMs-based calculations			116.98
		Methane	0.71	186.87	9.34E-02	2.20E-03
		Nitrous Oxide	0.071	18.69	9.34E-03	2.20E-04

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2014 Annual Emissions Inventory**

**Boiler #6
(ES-001-Boiler #6)
Facility ID # 6800043
Permit # 03069T32**

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	3.370
Maximum fuel sulfur content (%):	0.08
Latest Construction/Modification Date:	N/A
Enter the boiler type below ↘	
15	

Boilers =>100 mmBtu/hr 1 = No. 6 oil fired, normal firing (U) 2 = No. 6 oil fired, normal firing (I) 3 = No. 6 oil fired, normal firing (C) 4 = No. 6 oil fired, normal firing, low NOx burner (U) 5 = No. 6 oil fired, normal firing, low NOx burner (I) 6 = No. 6 oil fired, normal firing, low NOx burner (C) 7 = No. 6 oil fired, tangential firing (U) 8 = No. 6 oil fired, tangential firing, low NOx burner (U) 9 = No. 5 oil fired, normal firing (U) 10 = No. 5 oil fired, normal firing (I) 11 = No. 5 oil fired, tangential firing (U) 12 = No. 4 oil fired, normal firing (U) 13 = No. 4 oil fired, normal firing (I) 14 = No. 4 oil fired, tangential firing (U) 15 = No. 2 oil fired (U,I)	Boilers =>100 mmBtu/hr (cont'd) 16 = No. 2 oil fired (C) 17 = No. 2 oil fired, LNB/FGR (U,I) 18 = No. 2 oil fired, LNB/FGR (C)
	19 = Vertical fired utility boiler
	Small Boilers (<100 mmBtu/hr) 20 = No. 6 oil fired (I) 21 = No. 6 oil fired (C) 22 = No. 5 oil fired (C) 23 = No. 4 oil fired (C) 24 = No. 2 oil fired (I) 25 = No. 2 oil fired (C)
	26 = Residential Furnace

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2014 Annual Emissions Inventory**

**Boiler #6
(ES-001-Boiler #6)
Facility ID # 6800043
Permit # 03069T32**

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	3.370
Maximum fuel sulfur content (%):	0.08
Latest Construction/Modification Date:	N/A

Emission Controls

Particulate controls

Enter the control type below ▾	Message Area	Or enter a PM control efficiency below to override built in values.
3		
<u>Control Device</u> 0 = None/other 1 = ESP 2 = Scrubber 3 = Bagfilter 4 = Multiple cyclone	<u>Avg. Cont. Effic.</u> 99.0	<u>User Input PM Cont. Effic.</u> Message Area

Postcombustion SO₂ controls

Enter the control type below ▾	Message Area	Or enter an SO ₂ control efficiency below to override built in values.
0		
<u>Control Technology/Process</u> 0 = None/other 1 = Wet scrubber, Lime/limestone 2 = Wet scrubber, Sodium carbonate 3 = Wet scrubber, Magnesium oxide/hydroxide 4 = Wet scrubber, Dual alkali 5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel 6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity 7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray	<u>Avg. Cont. Effic.</u> 0.0 <u>Remarks</u> NA	<u>User Input SO₂ Cont. Effic.</u> 90.0 User entered control efficiency may be overestimated and should be documented.

NO_x controls

Enter the control type below ▾	Message Area	Or enter a NO _x control efficiency below to override built in values.
5		
<u>Control Technology/Process</u> 0 = None/other 1 = Low excess air (LEA) 2 = Staged combustion (SC) 3 = Burners out of service (BOOS) 4 = Flue gas recirculation (FGR) 5 = Flue gas recirculation plus staged combustion 6 = Low NO _x burners (LNB) 7 = Reduced air preheat (RAP) 8 = Selective noncatalytic reduction (SNCR) 9 = Conventional selective catalytic reduction (SCR)	<u>Avg. Cont. Effic.</u> 39.0 <u>Remarks</u> Available for boilers with sufficient operational flexibility	<u>User Input NO_x Cont. Effic.</u> 0.0 Message Area

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2014 Annual Emissions Inventory**

**Boiler #6
(ES-001-Boiler #6)
Facility ID # 6800043
Permit # 03069T32**

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	3.370
Maximum fuel sulfur content (%):	0.08
Latest Construction/Modification Date:	N/A

Emissions Output (for operation 3.42 hr/yr)

Criteria Pollutants				Emission Factor ¹
Pollutant	lb/hr ²	tpy	lb/yr ³	(lb/10 ³ gal)
Total PM (FPM + CPM)	3.0	0.002	4	3.30E+00
Filterable PM (FPM) rates @ 99% control	0.0	0.000	0	2.00E+00
Condensable PM (CPM) ⁴	3.0	0.002	4	1.30E+00
Filterable PM-10 ⁵	0.0	0.000	0	1.00E+00
Filterable PM-2.5 ⁵	0.0	0.000	0	2.50E-01
NOx rates @ 39% control	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.000	1	2.00E-01
CO	12	0.008	17	5.00E+00
SO2 rates @ 90% control	see attached CEMs-based calculations			2.98E+02
Total HAP ⁶	4.17E-01	0.000	1	1.81E-01
Largest HAP ⁶	1.84E-01	0.000	0	7.97E-02

Toxic/Hazardous Air Pollutants

Toxic/Hazardous Air Pollutants				Emission Factor ¹
Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	(lb/10 ³ gal)
Antimony rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates @ 99% control	1.29E-05	NA	1.89E-05	5.60E-04
Benzene	6.35E-03	NA	9.27E-03	2.75E-03
Beryllium rates @ 99% control	9.70E-06	NA	1.42E-05	4.20E-04
Cadmium rates @ 99% control	9.70E-06	NA	1.42E-05	4.20E-04
Chromium rates @ 99% control	9.70E-06	NA	1.42E-05	4.20E-04
Chromium VI rates @ 99% control	2.85E-06	NA	4.15E-06	1.23E-04
Cobalt rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.89E-03	NA	2.75E-03	8.17E-04
Fluoride	8.61E-02	2.07E+00	1.26E-01	3.73E-02
Formaldehyde	1.11E-01	2.66E+00	1.62E-01	4.80E-02
Lead rates @ 99% control	2.91E-05	NA	4.25E-05	1.26E-03
Manganese rates @ 99% control	1.94E-05	4.65E-04	2.83E-05	8.40E-04
Mercury	9.70E-04	2.33E-02	1.42E-03	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.45E-04	1.31E-02	7.95E-04	2.36E-04
Naphthalene	7.69E-04	NA	1.12E-05	3.33E-04
Nickel rates @ 99% control	9.70E-06	2.33E-04	1.42E-05	4.20E-04
POM rates @ 99% control	7.62E-05	NA	1.11E-04	3.30E-03
Selenium rates @ 99% control	4.85E-05	NA	7.08E-05	2.10E-03
Toluene	1.84E-01	4.41E+00	2.69E-01	7.97E-02
Xylene	3.23E-03	7.76E-02	4.72E-03	1.40E-03

Greenhouse Gases

Greenhouse Gases				Emission Factor
Pollutant	lb/hr ²	tpy	lb/yr ³	(lb/10 ³ gal)
Carbon dioxide	see attached CEMs-based calculations			22371.42
Methane	2.09E+00	1.53E-03	3.06E+00	0.907
Nitrous Oxide	4.19E-01	3.06E-04	6.12E-01	0.18

¹Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

²Hourly emission rates for all pollutants are based on hourly rated capacity.

³Annual emission rates for all pollutants are based on maximum annual fuel throughput.

⁴Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

⁵AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

⁶Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2014 Annual Emissions Inventory

Boiler #6
(ES-001-Boiler #6)
Facility ID # 6800043
Permit # 03069T32

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	3.370
Maximum fuel sulfur content (%):	0.08
Latest Construction/Modification Date:	N/A

⁷Daily emission rates are based on operation 24 hours per day at rated capacity.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler # 6 Wood Pellet Combustion

0.0 ton/yr, wood pellets burned
 64.63 MMBtu/hr, HI from wood
 8,125 Btu/lb, wood heating value
 3.98 ton/hr, max. wood firing rate
 8,760 hr/yr

0.00E+00 MMBtu/yr
 99.8% PM control
 67.8% HCl efficiency*
 92.3% Hg efficiency*

99.6% Metals control

*Calculated from August 2009 EPA Tests

Pollutant	Emission Factor (lb/MMBtu) ¹	Emissions (lb/hr)	Emissions (lb/yr)	Emissions (ton/yr)
NOx	see attached CEMs-based calculations			
CO	0.17	10.99	0.0	0.00
SO₂	see attached CEMs-based calculations			
PM	0.417	0.054	0.00	0.00000
PM ₁₀	0.377	0.049	0.00	0.00000
PM _{2.5}	0.327	0.042	0.00	0.00000
VOC	0.017	1.10	0.0	0.000
	lb/MMBtu			
Acetaldehyde	8.30E-04	5.36E-02	0.00E+00	0.00E+00
Acetophenone	3.20E-09	2.07E-07	0.00E+00	0.00E+00
Acrolein	4.00E-03	2.59E-01	0.00E+00	0.00E+00
Antimony	7.90E-06	2.04E-06	0.00E+00	0.00E+00
Arsenic	2.20E-05	5.69E-06	0.00E+00	0.00E+00
Benzene	4.20E-03	2.71E-01	0.00E+00	0.00E+00
Benzo(a)pyrene	2.60E-06	1.68E-04	0.00E+00	0.00E+00
Beryllium	1.10E-06	2.84E-07	0.00E+00	0.00E+00
Cadmium	4.10E-06	1.06E-06	0.00E+00	0.00E+00
Carbon tetrachloride	4.50E-05	2.91E-03	0.00E+00	0.00E+00
Chlorine	7.90E-04	5.11E-02	0.00E+00	0.00E+00
Chlorobenzene	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Chloroform	2.80E-05	1.81E-03	0.00E+00	0.00E+00
Chromium	1.75E-05	4.52E-06	0.00E+00	0.00E+00
Cobalt	6.50E-06	1.68E-06	0.00E+00	0.00E+00
Di(2-ethylhexyl)phthalate	4.70E-08	3.04E-06	0.00E+00	0.00E+00
Dinitrophenol, 2,4-	1.80E-07	1.16E-05	0.00E+00	0.00E+00
Ethyl Benzene	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Ethylene dichloride	2.90E-05	1.87E-03	0.00E+00	0.00E+00
Formaldehyde	4.40E-03	2.84E-01	0.00E+00	0.00E+00
Hexachlorodibenzo-p-dioxin	1.60E-06	1.03E-04	0.00E+00	0.00E+00
Hydrogen Chloride	1.90E-02	3.95E-01	0.00E+00	0.00E+00
Lead	4.80E-05	1.24E-05	0.00E+00	0.00E+00
Manganese	1.60E-03	4.14E-04	0.00E+00	0.00E+00
Mercury	3.50E-06	1.74E-05	0.00E+00	0.00E+00
Methyl bromide	1.50E-05	9.70E-04	0.00E+00	0.00E+00
Methyl chloride	2.30E-05	1.49E-03	0.00E+00	0.00E+00
Methyl chloroform	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Methyl ethyl ketone	5.40E-06	3.49E-04	0.00E+00	0.00E+00
Methylene chloride	2.90E-04	1.87E-02	0.00E+00	0.00E+00
Naphthalene	9.70E-05	6.27E-03	0.00E+00	0.00E+00
Nickel	3.30E-05	8.53E-06	0.00E+00	0.00E+00
Nitrophenol, 4-	1.10E-07	7.11E-06	0.00E+00	0.00E+00
Pentachlorophenol	5.10E-08	3.30E-06	0.00E+00	0.00E+00
Perchloroethylene	3.80E-05	2.46E-03	0.00E+00	0.00E+00
Phenol	5.10E-05	3.30E-03	0.00E+00	0.00E+00
Phosphorus	2.70E-05	6.98E-06	0.00E+00	0.00E+00
Polychlorinated biphenyls	8.15E-09	5.27E-07	0.00E+00	0.00E+00
POM	1.25E-04	8.08E-03	0.00E+00	0.00E+00
Propionaldehyde	6.10E-05	3.94E-03	0.00E+00	0.00E+00
Propylene dichloride	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Selenium	2.80E-06	7.24E-07	0.00E+00	0.00E+00
Styrene	1.90E-03	1.23E-01	0.00E+00	0.00E+00
2,3,7,8-TCDD	8.60E-12	5.56E-10	0.00E+00	0.00E+00
Toluene	9.20E-04	5.95E-02	0.00E+00	0.00E+00
Trichloroethylene	3.00E-05	1.94E-03	0.00E+00	0.00E+00
Trichlorofluoromethane	4.10E-05	2.65E-03	0.00E+00	0.00E+00
Trichlorophenol	2.20E-08	1.42E-06	0.00E+00	0.00E+00
Vinyl chloride	1.80E-05	1.16E-03	0.00E+00	0.00E+00
Xylenes	2.50E-05	1.62E-03	0.00E+00	0.00E+00
Carbon Dioxide	see attached CEMs-based calculations			
Methane	0.0159	1.026	0.0	0.0000
N ₂ O	0.00794	0.51	0.0	0.0000

1-Emission factors based on DAQ wood combustion spreadsheet

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Sulfur Dioxide Emissions from Boiler #6

(ES-001-Boiler #6)

The exhaust duct at Boiler #6 is equipped with a continuous emissions monitor (CEMs) for SO₂ emissions.

For the 2014 calendar year, 30 day facility averages for the SO₂ emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2014	0.18
February 2014	0.12
March 2014	0.12
April 2014	0.12
May 2014	0.18
June 2014	0.16
July 2014	0.16
August 2014	0.16
September 2014	0.16
October 2014	0.15
November 2014	0.16
December 2014	0.16
Annual Average	0.153

This average includes SO₂ emissions from coal, wood, fuel oil, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #6 for 2014

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
41,704	82,296	3,370	0.0
Coal (12,473 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.04E+06	8.48E+04	4.62E+02	0

Total for Boiler #6 (MMBtu/yr)	1.13E+06
--------------------------------	----------

Total SO ₂ Emissions from Boiler #6 (lb/yr)	171,651
Total SO₂ Emissions from Boiler #6 (ton/yr)	85.83

SO ₂ Emissions Associated with Coal Combustion (ton/yr)	85.79
SO ₂ Emissions Associated with No. 2 Fuel Oil Combustion (ton/yr)	0.04
SO ₂ Emissions Associated with Natural Gas Combustion (ton/yr)	0*
SO ₂ Emissions Associated with Wood Pellet Combustion (ton/yr)	0*

*All SO₂ measured by CEMS allocated to coal and No.2 fuel oil.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Nitrogen Dioxide Emissions from Boiler #6 (ES-001-Boiler #6)

The exhaust duct at Boiler #6 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2014 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2014	0.33
February 2014	0.32
March 2014	0.30
April 2014	0.28
May 2014	0.17
June 2014	0.18
July 2014	0.16
August 2014	0.14
September 2014	0.14
October 2014	0.11
November 2014	0.21
December 2014	0.28
Annual Average	0.22

This average includes NOx emissions from coal, fuel oil, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #6 for 2014

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
41,704	82,296	3,370	0.0
Coal (12,473 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.04E+06	8.48E+04	4.62E+02	0

Total for Boiler #6 (MMBtu/yr)	1.13E+06
--------------------------------	----------

Total NOx Emissions from Boiler #6 (lb/yr)	245,752
Total NOx Emissions from Boiler #6 (ton/yr)	122.88

NOx Emissions Associated with Coal Combustion (ton/yr)	113.57
NOx Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	0.0505
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	9.25
NOx Emissions Associated with Wood Pellet Combustion (ton/yr)	0.000

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

CO₂ Emissions from Boiler No.6 (ES-3)

The exhaust system on Boiler #6 is equipped with a continuous emissions monitor (CEMs) for CO₂ concentrations. The exhaust also includes a flow monitor. Mass CO₂ emissions are calculated by the DAHS for GHG reporting. For the 2014 calendar year, the monthly CO₂ emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2014	19,387	21,370
February 2014	17,561	19,358
March 2014	17,466	19,253
April 2014	13,207	14,558
May 2014	10,111	11,146
June 2014	10,306	11,360
July 2014	10,265	11,315
August 2014	2,232	2,460
September 2014	44	48
October 2014	3,456	3,809
November 2014	8,442	9,306
December 2014	13,078	14,416
Annual Total	125,553.1	138,397.2

This total includes CO₂ emissions from coal, fuel oil, wood pellets, and natural gas from Boiler #6 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #6 for 2014

Boiler #6			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
41,704	82,296	3,370	0.0
Coal (12,473 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.04E+06	8.48E+04	4.62E+02	0

Total for Boiler #6 (MMBtu/yr)	1.13E+06
-----------------------------------	----------

CO₂ Emission Rate Ratios

	kg/MMBtu	Ratio
coal	93.28	1
n.gas	53.06	0.56883
No.2 oil	73.96	0.79288
wood	93.80	1.00557

CO₂ Emissions Associated with Coal Combustion (ton/yr)	132,222.6
CO₂ Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	46.60
CO₂ Emissions Associated with Natural Gas Combustion (ton/yr)	6128.0
CO₂ Emissions Associated with Wood Pellet Combustion (ton/yr)	0.00

1.09E+06 Dist. Factor

138,397.2

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler #7 (ES-002-Boiler #7)

Operating Scenarios

#1 - Coal Firing

#2 - Natural Gas Firing

#4 - No.2 Fuel Oil Firing

#5 - Wood Pellet Firing

(#3 - No.6 Fuel Oil Firing is no longer permitted)

Boilers #6 and #7 are equipped with Continuous Emission Monitoring (CEMs) devices to measure SO₂, NO_x, and CO₂ emissions from each of the boilers. The monthly averages presented in the attached spreadsheets are for the total emissions from firing all types of fuel. The 2014 Annual Emission Inventory forms require that the emissions be divided among the four possible operating scenarios.

NO_x and CO₂ emissions have been divided between the four operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

SO₂ emissions from natural gas and wood pellet combustion are insignificant, therefore, SO₂ emissions have been divided between the fuel oil and coal operating scenarios based on the percentage of total heat input by each fuel. These calculations are detailed in the attached spreadsheets.

Emissions Calculations

SO₂, NO_x, and CO₂ Emissions are taken from CEMs data
Other emission factors are from stack test or DAQ spreadsheets

Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043
 Permit #: 03069T32
 County: Orange
 DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-002-Boiler #7					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #1 - Coal					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		45,730				tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	1.71%	% Ash	10.65%	Heat Content (Btu/lb or mmCF)	12,426 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8,154 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	37.18%	Mar-May	17.63%	June-Aug	20.77%	Sept-Nov	24.42%
------------------------------	--------	---------	--------	----------	--------	----------	--------

Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	19.38	8	N/A
NOx	NOx	158.16	1	N/A
PM Total	PM	4.82	8	99.80%
PM-2.5	PM-2.5	2.78	8	97.90%
PM-10	PM-10	4.82	8	99.60%
SO2	SO2	90.71	1	90.00%
VOC	VOC	0.26	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	26.07	8	N/A
Acetophenone	98-86-2	0.69	8	N/A
Acrolein	107-02-8	13.26	8	N/A
Arsenic*	ARSENICPDS	0.34	8	99.60%
Benzene	71-43-2	59.45	8	N/A
Benzo(a)pyrene	50-32-8	1.74E-03	8	N/A
Benzyl chloride	100-44-7	32.01	8	N/A
Beryllium*	BERYLCPDS	0.06	8	N/A
Biphenyl	92-52-4	7.77E-02	8	N/A
Bis(2-ethylhexyl)phthalate (DEHP)	117-81-7	3.34	8	N/A
Bromine	7726-95-6	9.32	8	99.60%
Bromoform	75-25-2	1.78	8	N/A
Cadmium*	CADMIUMCPDS	1.58E-01	8	99.60%
Carbon disulfide	75-10-0	5.94	8	N/A
2-Chloroacetophenone	532-27-4	0.32	8	N/A
Chlorobenzene	108-90-7	1.01	8	N/A
Chloroform	67-66-3	2.70	8	N/A
Chromium*	CROMCPDS	5.46	8	99.60%
Chromium (VI)	CHROM6CPDS	0.01	8	99.60%
Cumene	98-82-8	0.24	8	N/A
Cyanide	CNC	114.32	8	N/A
Dibenzofurans	132-64-9	9.19E-03	8	N/A
Dimethyl sulfate	77-78-1	2.20	8	N/A
2,4-Dinitrotoluene	121-14-2	1.28E-02	8	N/A
Ethyl benzene	100-41-4	4.30	8	N/A
Ethyl chloride	75-00-3	1.92	8	N/A
Ethylene dibromide	106-93-4	5.49E-02	8	N/A
Ethylene dichloride	107-06-2	1.83	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Formaldehyde*	50-0-00	74.78	8	N/A
Hexane	HEXANEISO	3.06	8	N/A
Hydrogen Chloride *	7647-01-0	14546.92	8	N/A
Hydrogen Fluoride *	7664-39-3	261.39	8	90% Control with CaCO ₃
Isophorone	78-59-1	26.52	8	N/A
Lead*	LEADCPDS	2.00	8	99.60%
Manganese*	MANGCPDS	13.64	8	99.60%
Mercury*	MERCCPDS	0.95	8	N/A
Methyl bromide	74-83-9	7.32	8	N/A
Methyl chloride	74-87-3	24.24	8	N/A
Methyl ethyl ketone	78-93-3	17.83	8	N/A
Methyl hydrazine	60-34-4	7.77	8	N/A
Methyl methacrylate	80-62-6	0.91	8	N/A
Methyl tert butyl ether	1634-04-4	1.60	8	N/A
Methylene chloride	75-09-2	13.26	8	N/A
Naphthalene	91-20-3	0.59	8	N/A
Nickel	NICKCPDS	11.10	8	99.60%
Phenol	108-95-2	0.73	8	N/A
POM	POM	2.55	8	N/A
Propionaldehyde	123-38-6	17.38	8	N/A
Styrene	100-42-5	1.14	8	N/A
2,3,7,8-TCDD	1746-01-6	6.54E-07	8	N/A
Tetrachloroethylene	79-34-5	1.97	8	N/A
Toluene	108-88-3	10.98	8	N/A
1,1,1-Trichloroethane	79-00-5	0.91	8	N/A
Vinyl acetate	108-05-4	0.35	8	N/A
Xylenes	1330-20-7	1.69	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	127,590.17	8	N/A
Methane	CH ₄	0.22	8	N/A
Nitrous oxide	N ₂ O	2.00	8	N/A

Emission Source/Operating Scenario Data Page 1 of 2		Facility ID #: 6800043					
Boiler #7 - Operating Scenario #2 - Natural Gas <small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>		Permit #: 03069T32					
Facility Name: University of North Carolina at Chapel Hill		County: Orange					
		DAQ Region: Raleigh					
North Carolina Department of Environment and Natural Resources Division of Air Quality Air Pollutant Point Source Emissions Inventory - Calendar Year 2014							
1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "T" for insignificant)			ES-002-Boiler #7				
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #2 - Natural Gas					
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>		32,975	1,000 ft³/yr				
6. Fuel Information (if fuel used)		% Sulfur N/A	% Ash N/A				
		Heat Content (Btu/lb or mmCF)	1,030 Btu/ft³				
<small>If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.</small>							
7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)			100%				
8. Control Device Information , if none, write "none"							
	Control Device ID # <small>(as listed in permit)</small>	Control Device Description					
<i>i. (nearest stack)</i>	CD-004	Bagfilter with Calcium Carbonate (CaCO₃) Sorbent Injection					
<i>ii.</i>	N/A	N/A					
<i>iii.</i>	N/A	N/A					
<i>iv.</i>	N/A	N/A					
9. Stack Information (sources vented to more than one stack use additional entry lines)							
Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature <small>(F)</small>	Velocity <small>(feet/sec)</small>	Volume Flow Rate <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>	
EP-14-136	220	9	305	56.1	214,000	Vertical	
--	--	--	--	--	--	--	
--	--	--	--	--	--	--	
10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	7,848 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	2.36%	Mar-May	30.00%	June-Aug	25.83%	Sept-Nov	41.82%

Emission Source/Operating Scenario Data Page 2 of 2 <i>Boiler #7 - Operating Scenario #2 - Natural Gas</i> <small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>	Facility ID #: <u>6800043</u> Permit #: <u>03069T32</u> County: <u>Orange</u> DAQ Region: <u>Raleigh</u>
Facility Name: <u>University of North Carolina at Chapel Hill</u>	

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	1.38	8	N/A
NOx	NOx	4.73	1	N/A
PM Total	PM	0.13	8	N/A
PM-2.5	PM-2.5	0.13	8	N/A
PM-10	PM-10	0.13	8	N/A
SO2	SO2	0.00	1	N/A
VOC	VOC	0.09	8	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	6.59E-03	8	N/A
Benzene	71-43-2	0.07	8	N/A
Cadmium	CADMIUMCPDS	3.63E-02	8	N/A
Chromium	CROMCPDS	4.62E-02	8	N/A
Chromium VI	CHROM6CPDS	4.62E-02	8	N/A
Dichlorobenzene	106-46-7	3.96E-02	8	N/A
Formaldehyde	50-00-0	2.47	8	N/A
Hexane	HEXANEISO	5.94E+01	8	N/A
Lead	LEADCPDS	1.65E-02	8	N/A
Manganese	MANGCPDS	1.25E-02	8	N/A
Mercury	MERCPDS	8.57E-03	8	N/A
Napthalene	91-20-3	2.01E-02	8	N/A
Nickel	NICKCPDS	0.07	8	N/A
POM	POM	2.18E-02	8	N/A
Toluene	108-88-3	0.11	8	N/A

Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	2,168.97	8	N/A
Methane	CH ₄	3.74E-02	8	N/A
Nitrous oxide	N ₂ O	3.74E-03	8	N/A

Emission Source/Operating Scenario Data Page 1 of 2		Facility ID #: 6800043					
<i>Boiler #7 - Operating Scenario #4 - No. 2 Fuel Oil</i>		Permit #: 03069T32					
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)		County: Orange					
Facility Name: University of North Carolina at Chapel Hill		DAQ Region: Raleigh					
North Carolina Department of Environment and Natural Resources Division of Air Quality Air Pollutant Point Source Emissions Inventory - Calendar Year 2014							
1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)			ES-002-Boiler #7				
2. Emission Source Description		Coal / Natural Gas / No. 6 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #4 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		2,535	gallons/yr				
6. Fuel Information (if fuel used)		% Sulfur	0.002%				
		% Ash					
		Heat Content (Btu/lb or mmCF)	137,204 Btu/gal				
If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.							
7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)			100%				
8. Control Device Information , if none, write "none"							
	Control Device ID # (as listed in permit)	Control Device Description					
<i>i. (nearest stack)</i>	CD-004	Bagfilter with Calcium Carbonate (CaCO₃) Sorbent Injection					
<i>ii.</i>	N/A	N/A					
<i>iii.</i>	N/A	N/A					
<i>iv.</i>	N/A	N/A					
9. Stack Information (sources vented to more than one stack use additional entry lines)							
Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)	
EP-14-136	220	9	305	56.1	214,000	Vertical	
--	--	--	--	--	--	--	
--	--	--	--	--	--	--	
10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	7,848 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	100.00%	Mar-May	0.00%	June-Aug	0%	Sept-Nov	0.00%

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

Boiler #7 - Operating Scenario #4 - No. 2 Fuel Oil

If Emission Source has multiple Operating Scenarios, complete one form for each.

(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**Permit #: **03069T32**County: **Orange**DAQ Region: **Raleigh**Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.01	8	N/A
NOx	NOx	0.05	1	N/A
PM Total	PM	0.00	8	99.0%
PM-2.5	PM-2.5	0.00	8	99.0%
PM-10	PM-10	0.00	8	99.0%
SO2	SO2	0.03	1	90.00%
VOC	VOC	0.00	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Antimony	ANTIMONYPDS	0.00E+00	8	99.0%
Arsenic	ARSENICPDS	1.42E-05	8	99.0%
Benzene	71-43-2	6.97E-03	8	N/A
Beryllium	BERYLCPDS	1.06E-05	8	99.0%
Cadmium	CADMIUMCPDS	1.06E-05	8	99.0%
Chromium	CROMCPDS	1.06E-05	8	99.0%
Chromium VI	CHROM6CPDS	3.12E-06	8	99.0%
Cobalt	COBALTCPDS	0.00E+00	8	99.0%
Ethylbenzene	100-41-4	2.07E-03	8	N/A
Fluoride	16984-48-8	0.09	8	N/A
Formaldehyde	50-00-0	0.12	8	N/A
Lead	LEADCPDS	3.19E-05	8	99.0%
Manganese	MANGCPDS	2.13E-05	8	99.0%
Mercury	MERCPDS	1.06E-03	8	99.0%
Methyl chloroform	71-55-6	5.98E-04	8	N/A
Napthalene	91-20-3	0.001	8	N/A
Nickel	NICKCPDS	1.06E-05	8	99.0%
POM	POM	8.37E-05	8	99.0%
Selenium	SEC	5.32E-05	8	99.0%
Toluene	108-88-3	0.20	8	N/A
Xylene	1330-20-7	3.55E-03	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	30.96	8	N/A
Methane	CH ₄	1.15E-03	8	N/A
Nitrous oxide	N ₂ O	2.30E-04	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #7 - Operating Scenario #5 - Wood Pellets
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**
 Permit #: **03069T32**
 County: **Orange**
 DAQ Region: **Raleigh**

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-002-Boiler #7					
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil/Wood Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #5 - Wood Pellets					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		64.63 MMBtu/hr (20% HI from wood pellets)					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		0.0 tons/yr					
6. Fuel Information (if fuel used)		% Sulfur	NA	% Ash	NA	Heat Content (Btu/lb or mmCF)	8,185 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8057 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	#DIV/0!	Mar-May	#DIV/0!	June-Aug	#DIV/0!	Sept-Nov	#DIV/0!
------------------------------	----------------	---------	----------------	----------	----------------	----------	----------------

Boiler #7 - Operating Scenario #5 - Wood Pellets
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.000	8	N/A
NOx	NOx	0.000	1	N/A
PM Total	PM	0.00000	8	99.80%
PM-2.5	PM-2.5	0.00000	8	97.90%
PM-10	PM-10	0.00000	8	99.60%
SO2	SO2	CEM w/coal	1	90.00%
VOC	VOC	0.0000	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	0.00E+00	8	N/A
Acetophenone	98-86-2	0.00E+00	8	N/A
Acrolein	107-02-8	0.00E+00	8	N/A
Antimony	7440-36-0	0.00E+00	8	99.60%
Arsenic	ARSENICPDS	0.00E+00	8	99.60%
Benzene	71-43-2	0.00E+00	8	N/A
Benzo(a)pyrene	50-32-8	0.00E+00	8	N/A
Beryllium	BERYLCPDS	0.00E+00	8	99.60%
Cadmium	CADMIUMCPDS	0.00E+00	8	99.60%
Carbon tetrachloride	56-23-5	0.00E+00	8	N/A
Chlorine	7782-50-5	0.00E+00	8	N/A
Chlorobenzene	108-90-7	0.00E+00	8	N/A
Chloroform	67-66-3	0.00E+00	8	N/A
Chromium	CROMCPDS	0.00E+00	8	99.60%
Cobalt	7440-48-4	0.00E+00	8	99.60%
Di(2-ethylhexy)phthalate		0.00E+00	8	N/A
Dinitrophenol, 2,4-	51-28-5	0.00E+00	8	N/A
Ethyl benzene	100-41-4	0.00E+00	8	N/A
Ethylene dichloride	107-06-2	0.00E+00	8	N/A
Formaldehyde*	50-0-00	0.00E+00	8	N/A
Hexachlorodib-dioxin	57653-85-7	0.00E+00	8	N/A
Hydrogen Chloride *	7647-01-0	0.00E+00	8	68% Control with CaCO ₃
Lead*	LEADCPDS	0.00E+00	8	99.60%
Manganese*	MANGCPDS	0.00E+00	8	99.60%
Mercury*	MERCCPDS	0.00E+00	8	92%
Methyl bromide	74-83-9	0.00E+00	8	N/A
Methyl chloride	74-87-3	0.00E+00	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #7 - Operating Scenario #5 - Wood Pellets

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Methyl chloroform	71-55-6	0.00E+00	8	N/A
Methyl ethyl ketone	78-93-3	0.00E+00	8	N/A
Methylene chloride	75-09-2	0.00E+00	8	N/A
Naphthalene	91-20-3	0.00E+00	8	N/A
Nickel	NICKCPDS	0.00E+00	8	99.60%
Nitrophenol, 4-	100-02-07	0.00E+00	8	N/A
Pentachlorophenol	87-86-5	0.00E+00	8	N/A
Perchloroethylene	127-18-4	0.00E+00	8	N/A
Phenol	108-95-2	0.00E+00	8	N/A
Phosphorus	7723-14-0	0.00E+00	8	99.60%
Polychlorinated biphenyls	1336-36-3	0.00E+00	8	N/A
POM	POM	0.00E+00	8	N/A
Propionaldehyde	123-38-6	0.00E+00	8	N/A
Propylene dichloride	78-87-5	0.00E+00	8	N/A
Selenium	7782-49-2	0.00E+00	8	99.60%
Styrene	100-42-5	0.00E+00	8	N/A
2,3,7,8-TCDD	1746-01-6	0.00E+00	8	N/A
Toluene	108-88-3	0.00E+00	8	N/A
Trichloroethylene	79-01-6	0.00E+00	8	N/A
Trichlorofluoromethane	75-69-4	0.00E+00	8	N/A
Trichlorophenol		0.00E+00	8	N/A
Vinyl chloride	75-01-4	0.00E+00	8	N/A
Xylenes	1330-20-7	0.00E+00	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	0.00	8	N/A
Methane	CH ₄	0.0000	8	N/A
Nitrous oxide	N ₂ O	0.0000	8	N/A

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler #7

(ES-002-Boiler #7)

Emissions Calculations

SO₂, NO_x, and CO₂ Emissions are Taken from CEMs Data
Other emission factors are from stack test or DAQ spreadsheets

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

Data Input

Maximum Heat Input	<input type="text" value="323.17"/>	mmBtu/hr	Boiler Type:	<input type="text" value="7"/>
Boiler Size/Type	Large Industrial		1) Pulverized/Dry Bottom	6) Underfeed Stoker
Actual Fuel Usage	<input type="text" value="45,730"/>	ton/yr	2) Pulverized/Wet Bottom	7) Fluidized Bed Cir.
or	or		3) Cyclone Furnace	8) Fluidized Bed Bub.
Hours of Operation	<input type="text"/>	hr/yr	4) Spreader Stoker	9) Hand Fed
and	and		Control Device Efficiencies:	
Heating Value	<input type="text" value="12,426"/>	Btu/lb	PM	<input type="text" value="99.80"/> %
		ton/yr	PM-10	<input type="text" value="98.00"/> %
Sulfur Content	<input type="text" value="1.71"/>	%	PM-2.5	<input type="text" value="97.90"/> %
Ash Content :	<input type="text" value="10.65"/>	%	SOx*	<input type="text" value="90.00"/> %
(B)ituminous or (S)ubbituminous?	<input type="text" value="B"/>	(B/S)	NOx*	<input type="text" value="0.00"/> %
Calcium to Sulfur Ratio	<input type="text" value="2.22"/>		<p><i>*SOx and NOx emission estimates were calculated using CEMS data. Please refer to the SOx and NOX emissions data presented in the following CEMs spreadsheets. HCl, HF, and Hg emissions based on stack test data.</i></p>	

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

ACTUAL CRITERIA EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
PM*	0.21	2.73	9,645	4.82
PM-10*	0.21	2.73	9,645	4.82
PM-2.5*	0.12	1.58	5,561	2.78
SO2	14.88	**	**	**
SO3	0.10	**	**	**
NOx	3.90	**	**	**
VOC*	0.01	0.15	523	0.26
CO*	0.85	11.02	38,754	19.38

ACTUAL TOXIC EMISSIONS

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Acetaldehyde	5.70E-04	7.41E-03	2.61E+01	1.30E-02
Acetophenone	1.50E-05	1.95E-04	6.86E-01	3.43E-04
Acrolein	2.90E-04	3.77E-03	1.33E+01	6.63E-03
Antimony*	8.03E-06	1.04E-04	3.67E-01	1.84E-04
Arsenic*	7.48E-06	9.73E-05	3.42E-01	1.71E-04
Benzene	1.30E-03	1.69E-02	5.94E+01	2.97E-02
Benzo(a)pyrene	3.80E-08	4.94E-07	1.74E-03	8.69E-07
Benzyl chloride	7.00E-04	9.10E-03	3.20E+01	1.60E-02
Beryllium*	1.31E-06	1.71E-05	6.00E-02	3.00E-05
Biphenyl	1.70E-06	2.21E-05	7.77E-02	3.89E-05
Bis(2-ethylhexyl)phthalate (DEHP)	7.30E-05	9.49E-04	3.34E+00	1.67E-03
Bromine	1.02E-01	2.65E-03	9.32E+00	4.66E-03
Bromoforn	3.90E-05	5.07E-04	1.78E+00	8.92E-04
Cadmium*	3.45E-06	4.49E-05	1.58E-01	7.90E-05
Carbon disulfide	1.30E-04	1.69E-03	5.94E+00	2.97E-03
2-Chloroacetophenone	7.00E-06	9.10E-05	3.20E-01	1.60E-04
Chlorobenzene	2.20E-05	2.86E-04	1.01E+00	5.03E-04
Chlorine*	2.68E-03	3.49E-02	1.23E+02	6.14E-02
Chloroform	5.90E-05	7.67E-04	2.70E+00	1.35E-03
Chromium*	1.19E-04	1.55E-03	5.46E+00	2.73E-03
Chromium (VI)	1.19E-04	3.10E-06	1.09E-02	5.46E-06
Cobalt*	6.86E-06	8.92E-05	3.14E-01	1.57E-04
Cumene	5.30E-06	6.89E-05	2.42E-01	1.21E-04
Cyanide	2.50E-03	3.25E-02	1.14E+02	5.72E-02
Dibenzofurans	2.01E-07	2.61E-06	9.19E-03	4.60E-06
Dimethyl sulfate	4.80E-05	6.24E-04	2.20E+00	1.10E-03
2,4-Dinitrotoluene	2.80E-07	3.64E-06	1.28E-02	6.40E-06
Ethyl benzene	9.40E-05	1.22E-03	4.30E+00	2.15E-03
Ethyl chloride	4.20E-05	5.46E-04	1.92E+00	9.60E-04
Ethylene dibromide	1.20E-06	1.56E-05	5.49E-02	2.74E-05
Ethylene dichloride	4.00E-05	5.20E-04	1.83E+00	9.15E-04
Formaldehyde*	1.64E-03	2.13E-02	7.48E+01	3.74E-02
Hexane	6.70E-05	8.71E-04	3.06E+00	1.53E-03
Hydrogen Chloride *	3.18E-01	4.14E+00	1.45E+04	7.27E+00
Hydrogen Fluoride *	5.72E-03	7.43E-02	2.61E+02	1.31E-01
Isophorone	5.80E-04	7.54E-03	2.65E+01	1.33E-02
Lead*	4.37E-05	5.69E-04	2.00E+00	1.00E-03

**SO₂ and NO_x emissions were estimated using CEMS data, please refer to the attached data sheets entitled "Sulfur Dioxide Emissions from Boiler #7" and Nitrogen Dioxide Emissions from Boiler #7".

Bituminous Coal Combustion

2014 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
 City **Chapel Hill**
 County **Orange County**

APP #/Fac ID **6800043**
 Input By **RST Engineering**
 Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

ACTUAL TOXIC EMISSIONS (continued)

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
<i>Manganese*</i>	<i>2.98E-04</i>	<i>3.88E-03</i>	<i>1.36E+01</i>	<i>6.82E-03</i>
<i>Mercury*</i>	<i>2.08E-05</i>	<i>2.70E-04</i>	<i>9.51E-01</i>	<i>4.76E-04</i>
Methyl bromide	1.60E-04	2.08E-03	7.32E+00	3.66E-03
Methyl chloride	5.30E-04	6.89E-03	2.42E+01	1.21E-02
Methyl ethyl ketone	3.90E-04	5.07E-03	1.78E+01	8.92E-03
Methyl hydrazine	1.70E-04	2.21E-03	7.77E+00	3.89E-03
Methyl methacrylate	2.00E-05	2.60E-04	9.15E-01	4.57E-04
Methyl tert butyl ether	3.50E-05	4.55E-04	1.60E+00	8.00E-04
Methylene chloride	2.90E-04	3.77E-03	1.33E+01	6.63E-03
Naphthalene	1.30E-05	1.69E-04	5.94E-01	2.97E-04
<i>Nickel*</i>	<i>2.43E-04</i>	<i>3.16E-03</i>	<i>1.11E+01</i>	<i>5.55E-03</i>
Phenol	1.60E-05	2.08E-04	7.32E-01	3.66E-04
<i>Phosphorus*</i>	<i>3.63E-05</i>	<i>4.72E-04</i>	<i>1.66E+00</i>	<i>8.30E-04</i>
POM	5.57E-05	7.24E-04	2.55E+00	1.27E-03
Propionaldehyde	3.80E-04	4.94E-03	1.74E+01	8.69E-03
<i>Selenium*</i>	<i>5.34E-06</i>	<i>6.95E-05</i>	<i>2.44E-01</i>	<i>1.22E-04</i>
Styrene	2.50E-05	3.25E-04	1.14E+00	5.72E-04
2,3,7,8-TCDD	1.43E-11	1.86E-10	6.54E-07	3.27E-10
Tetrachloroethylene	4.30E-05	5.59E-04	1.97E+00	9.83E-04
Toluene	2.40E-04	3.12E-03	1.10E+01	5.49E-03
1,1,1-Trichloroethane	2.00E-05	2.60E-04	9.15E-01	4.57E-04
Vinyl acetate	7.60E-06	9.88E-05	3.48E-01	1.74E-04
Xylenes	3.70E-05	4.81E-04	1.69E+00	8.46E-04
Total HAPs		4.39	15,454.47	7.73

Greenhouse Gases

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Carbon dioxide			see attached CEMs-based calculations	
<i>Methane*</i>	<i>0.009</i>	<i>0.12</i>	<i>431.86</i>	<i>0.22</i>
Nitrous Oxide	0.09	1.14	4,009	2.00

***Emission rates for pollutants in italics from August 2009 Section 114 test of Boiler #6.**

Notes :

- 1) Emission factors are from Supplement B to the 5th edition of AP-42, unless otherwise noted
- 2) Emission calculations will be based on the hours of operation only when actual fuel usage is not supplied
- 3) Particulate controls affect PM, PM-10, PM-2.5, and all toxics that are regulated as particulates except Mercury
- 4) VOC = NMTOC = TOC * (1-%METHANE)
- 5) PM-2.5 and SO3 do not currently need to be reported
- 6) Dibenzofurans = Polychlorinated dibenzo-p-furans
- 7) The Br emission factor is based on a mass balance generated from a 3 year coal analysis for Duke Power (1990-1992, 7 samples per year). The average concentration of bromine was 55.33 ppm (wet basis) and a heating value of 13,500 Btu/lb was assumed
- 8) For fluidized bed combustion the emission factor for underfeed stokers is utilized whenever the calcium-to-sulfur ratio is outside of the acceptable range of 1.5 to 7

Natural Gas Combustion Emissions Calculator NG2000 Revision C
2014 Annual Emissions Inventory
Boiler #7
(ES-002-Boiler #7)

Facility ID # 6800043
 Permit # 03069T32

Operating Scenario #2

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left; padding: 5px;">User Input</th> </tr> <tr> <td style="width: 35%; padding: 5px;">Company Name:</td> <td style="padding: 5px;">University of North Carolina at Chapel Hill</td> </tr> <tr> <td style="padding: 5px;">Plant County:</td> <td style="padding: 5px;">Orange County</td> </tr> <tr> <td style="padding: 5px;">Plant City:</td> <td style="padding: 5px;">Chapel Hill</td> </tr> <tr> <td style="padding: 5px;">Permit Number:</td> <td style="padding: 5px;">03069T32</td> </tr> <tr> <td style="padding: 5px;">User:</td> <td style="padding: 5px;">RST Engineering</td> </tr> <tr> <td style="padding: 5px;">Heat Input Capacity (mmBtu/hr):</td> <td style="padding: 5px;">323.17</td> </tr> <tr> <td style="padding: 5px;">Fuel Input Capacity (10⁶ scf/hr):</td> <td style="padding: 5px;">0.32</td> </tr> <tr> <td style="padding: 5px;">Annual Fuel Throughput (10⁶ scf):</td> <td style="padding: 5px;">32.97</td> </tr> <tr> <td style="padding: 5px;">Latest Construction/Modification Date:</td> <td style="padding: 5px;">N/A</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Enter the boiler type below ▾</td> <td style="width: 50px;"></td> </tr> <tr> <td style="padding: 5px;"></td> <td style="text-align: center; padding: 5px;">2</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Other NOx Control</td> <td style="width: 50px;"></td> </tr> <tr> <td style="padding: 5px;"></td> <td style="text-align: center; padding: 5px;">4</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Large Wall-Fired Boilers (=>100 mmBtu/hr)</td> </tr> <tr> <td style="padding: 5px;">1 = Uncontrolled (Pre-NSPS)</td> </tr> <tr> <td style="padding: 5px;">2 = Uncontrolled (Post-NSPS)</td> </tr> <tr> <td style="padding: 5px;">3 = Controlled - Low NOx burners</td> </tr> <tr> <td style="padding: 5px;">4 = Controlled - Flue gas recirculation (FGR)</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Small Boilers (<100 mmBtu/hr)</td> </tr> <tr> <td style="padding: 5px;">5 = Uncontrolled</td> </tr> <tr> <td style="padding: 5px;">6 = Controlled - Low NOx burners</td> </tr> <tr> <td style="padding: 5px;">7 = Controlled - Low NOx burners/FGR</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Tangential-Fired Boilers (All Sizes)</td> </tr> <tr> <td style="padding: 5px;">8 = Uncontrolled</td> </tr> <tr> <td style="padding: 5px;">9 = Controlled - FGR</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Residential Furnaces (<0.3 mmBtu/hr)</td> </tr> <tr> <td style="padding: 5px;">10 = Uncontrolled</td> </tr> </table>	User Input		Company Name:	University of North Carolina at Chapel Hill	Plant County:	Orange County	Plant City:	Chapel Hill	Permit Number:	03069T32	User:	RST Engineering	Heat Input Capacity (mmBtu/hr):	323.17	Fuel Input Capacity (10 ⁶ scf/hr):	0.32	Annual Fuel Throughput (10 ⁶ scf):	32.97	Latest Construction/Modification Date:	N/A	Enter the boiler type below ▾			2	Other NOx Control			4	Large Wall-Fired Boilers (=>100 mmBtu/hr)	1 = Uncontrolled (Pre-NSPS)	2 = Uncontrolled (Post-NSPS)	3 = Controlled - Low NOx burners	4 = Controlled - Flue gas recirculation (FGR)	Small Boilers (<100 mmBtu/hr)	5 = Uncontrolled	6 = Controlled - Low NOx burners	7 = Controlled - Low NOx burners/FGR	Tangential-Fired Boilers (All Sizes)	8 = Uncontrolled	9 = Controlled - FGR	Residential Furnaces (<0.3 mmBtu/hr)	10 = Uncontrolled	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4" style="text-align: left; padding: 5px;">Emissions Output (for operation 19.22 hr/yr)</th> <th style="text-align: center; padding: 5px;">Emission</th> </tr> <tr> <th colspan="4" style="text-align: left; padding: 5px;">Criteria Pollutants</th> <th style="text-align: center; padding: 5px;">Factor</th> </tr> <tr> <th style="text-align: left; padding: 5px;">Pollutant</th> <th style="text-align: center; padding: 5px;">lb/hr</th> <th style="text-align: center; padding: 5px;">lb/yr</th> <th style="text-align: center; padding: 5px;">tpy</th> <th style="text-align: center; padding: 5px;">(lb/mmscf)</th> </tr> <tr> <td style="padding: 5px;">PM</td> <td style="text-align: center; padding: 5px;">2.4E+00</td> <td style="text-align: center; padding: 5px;">2.5E+02</td> <td style="text-align: center; padding: 5px;">1.3E-01</td> <td style="text-align: center; padding: 5px;">7.6E+00</td> </tr> <tr> <td style="padding: 5px;">PM-10</td> <td style="text-align: center; padding: 5px;">2.4E+00</td> <td style="text-align: center; padding: 5px;">2.5E+02</td> <td style="text-align: center; padding: 5px;">1.3E-01</td> <td style="text-align: center; padding: 5px;">7.6E+00</td> </tr> <tr> <td style="padding: 5px;">PM-2.5</td> <td style="text-align: center; padding: 5px;">2.4E+00</td> <td style="text-align: center; padding: 5px;">2.5E+02</td> <td style="text-align: center; padding: 5px;">1.3E-01</td> <td style="text-align: center; padding: 5px;">7.6E+00</td> </tr> <tr> <td style="padding: 5px;">NOx</td> <td colspan="3" style="padding: 5px;">see attached CEMs-based calculations</td> <td style="text-align: center; padding: 5px;">1.9E+02</td> </tr> <tr> <td style="padding: 5px;">VOC</td> <td style="text-align: center; padding: 5px;">1.7E+00</td> <td style="text-align: center; padding: 5px;">1.8E+02</td> <td style="text-align: center; padding: 5px;">9.1E-02</td> <td style="text-align: center; padding: 5px;">5.5E+00</td> </tr> <tr> <td style="padding: 5px;">CO</td> <td style="text-align: center; padding: 5px;">2.7E+01</td> <td style="text-align: center; padding: 5px;">2.8E+03</td> <td style="text-align: center; padding: 5px;">1.4E+00</td> <td style="text-align: center; padding: 5px;">8.4E+01</td> </tr> <tr> <td style="padding: 5px;">SO2</td> <td colspan="3" style="padding: 5px;">see attached CEMs-based calculations</td> <td style="text-align: center; padding: 5px;">6.0E-01</td> </tr> <tr> <td style="padding: 5px;">Total HAP</td> <td style="text-align: center; padding: 5px;">6.0E-01</td> <td style="text-align: center; padding: 5px;">6.2E+01</td> <td style="text-align: center; padding: 5px;">3.1E-02</td> <td style="text-align: center; padding: 5px;">1.9E+00</td> </tr> <tr> <td style="padding: 5px;">Largest HAP</td> <td style="text-align: center; padding: 5px;">5.7E-01</td> <td style="text-align: center; padding: 5px;">5.9E+01</td> <td style="text-align: center; padding: 5px;">3.0E-02</td> <td style="text-align: center; padding: 5px;">1.8E+00</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: left; padding: 5px;">Toxic/Hazardous Air Pollutants</th> </tr> <tr> <th style="text-align: left; padding: 5px;">Pollutant</th> <th style="text-align: center; padding: 5px;">lb/hr</th> <th style="text-align: center; padding: 5px;">lb/day</th> <th style="text-align: center; padding: 5px;">lb/yr</th> <th style="text-align: center; padding: 5px;"></th> </tr> <tr> <td style="padding: 5px;">Arsenic</td> <td style="text-align: center; padding: 5px;">6.3E-05</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">6.6E-03</td> <td style="text-align: center; padding: 5px;">2.0E-04</td> </tr> <tr> <td style="padding: 5px;">Benzene</td> <td style="text-align: center; padding: 5px;">6.7E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">6.9E-02</td> <td style="text-align: center; padding: 5px;">2.1E-03</td> </tr> <tr> <td style="padding: 5px;">Cadmium</td> <td style="text-align: center; padding: 5px;">3.5E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">3.6E-02</td> <td style="text-align: center; padding: 5px;">1.1E-03</td> </tr> <tr> <td style="padding: 5px;">Chromium</td> <td style="text-align: center; padding: 5px;">4.4E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">4.6E-02</td> <td style="text-align: center; padding: 5px;">1.4E-03</td> </tr> <tr> <td style="padding: 5px;">Chromium VI</td> <td style="text-align: center; padding: 5px;">4.4E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">4.6E-02</td> <td style="text-align: center; padding: 5px;">1.4E-03</td> </tr> <tr> <td style="padding: 5px;">Dichlorobenzene</td> <td style="text-align: center; padding: 5px;">3.8E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">4.0E-02</td> <td style="text-align: center; padding: 5px;">1.2E-03</td> </tr> <tr> <td style="padding: 5px;">Formaldehyde</td> <td style="text-align: center; padding: 5px;">2.4E-02</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">2.5E+00</td> <td style="text-align: center; padding: 5px;">7.5E-02</td> </tr> <tr> <td style="padding: 5px;">Hexane</td> <td style="text-align: center; padding: 5px;">5.7E-01</td> <td style="text-align: center; padding: 5px;">1.4E+01</td> <td style="text-align: center; padding: 5px;">5.9E+01</td> <td style="text-align: center; padding: 5px;">1.8E+00</td> </tr> <tr> <td style="padding: 5px;">Lead</td> <td style="text-align: center; padding: 5px;">1.6E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">1.6E-02</td> <td style="text-align: center; padding: 5px;">5.0E-04</td> </tr> <tr> <td style="padding: 5px;">Manganese</td> <td style="text-align: center; padding: 5px;">1.2E-04</td> <td style="text-align: center; padding: 5px;">2.9E-03</td> <td style="text-align: center; padding: 5px;">1.3E-02</td> <td style="text-align: center; padding: 5px;">3.8E-04</td> </tr> <tr> <td style="padding: 5px;">Mercury</td> <td style="text-align: center; padding: 5px;">8.2E-05</td> <td style="text-align: center; padding: 5px;">2.0E-03</td> <td style="text-align: center; padding: 5px;">8.6E-03</td> <td style="text-align: center; padding: 5px;">2.6E-04</td> </tr> <tr> <td style="padding: 5px;">Naphthalene</td> <td style="text-align: center; padding: 5px;">1.9E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">2.0E-02</td> <td style="text-align: center; padding: 5px;">6.1E-04</td> </tr> <tr> <td style="padding: 5px;">Nickel</td> <td style="text-align: center; padding: 5px;">6.7E-04</td> <td style="text-align: center; padding: 5px;">1.6E-02</td> <td style="text-align: center; padding: 5px;">6.9E-02</td> <td style="text-align: center; padding: 5px;">2.1E-03</td> </tr> <tr> <td style="padding: 5px;">POM</td> <td style="text-align: center; padding: 5px;">2.1E-04</td> <td style="text-align: center; padding: 5px;">NA</td> <td style="text-align: center; padding: 5px;">2.2E-02</td> <td style="text-align: center; padding: 5px;">6.6E-04</td> </tr> <tr> <td style="padding: 5px;">Toluene</td> <td style="text-align: center; padding: 5px;">1.1E-03</td> <td style="text-align: center; padding: 5px;">2.6E-02</td> <td style="text-align: center; padding: 5px;">1.1E-01</td> <td style="text-align: center; padding: 5px;">3.4E-03</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4" style="text-align: left; padding: 5px;">Greenhouse Gas Pollutants</th> <th style="text-align: center; padding: 5px;">Em. Factor</th> </tr> <tr> <th style="text-align: left; padding: 5px;">Pollutant</th> <th style="text-align: center; padding: 5px;">lb/hr</th> <th style="text-align: center; padding: 5px;">lb/yr</th> <th style="text-align: center; padding: 5px;">tpy</th> <th style="text-align: center; padding: 5px;">(lb/mmBtu)</th> </tr> <tr> <td style="padding: 5px;">Carbon dioxide</td> <td colspan="3" style="padding: 5px;">see attached CEMs-based calculations</td> <td style="text-align: center; padding: 5px;">116.98</td> </tr> <tr> <td style="padding: 5px;">Methane</td> <td style="text-align: center; padding: 5px;">0.71</td> <td style="text-align: center; padding: 5px;">74.88</td> <td style="text-align: center; padding: 5px;">3.74E-02</td> <td style="text-align: center; padding: 5px;">2.20E-03</td> </tr> <tr> <td style="padding: 5px;">Nitrous Oxide</td> <td style="text-align: center; padding: 5px;">0.071</td> <td style="text-align: center; padding: 5px;">7.49</td> <td style="text-align: center; padding: 5px;">3.74E-03</td> <td style="text-align: center; padding: 5px;">2.20E-04</td> </tr> </table>	Emissions Output (for operation 19.22 hr/yr)				Emission	Criteria Pollutants				Factor	Pollutant	lb/hr	lb/yr	tpy	(lb/mmscf)	PM	2.4E+00	2.5E+02	1.3E-01	7.6E+00	PM-10	2.4E+00	2.5E+02	1.3E-01	7.6E+00	PM-2.5	2.4E+00	2.5E+02	1.3E-01	7.6E+00	NOx	see attached CEMs-based calculations			1.9E+02	VOC	1.7E+00	1.8E+02	9.1E-02	5.5E+00	CO	2.7E+01	2.8E+03	1.4E+00	8.4E+01	SO2	see attached CEMs-based calculations			6.0E-01	Total HAP	6.0E-01	6.2E+01	3.1E-02	1.9E+00	Largest HAP	5.7E-01	5.9E+01	3.0E-02	1.8E+00	Toxic/Hazardous Air Pollutants					Pollutant	lb/hr	lb/day	lb/yr		Arsenic	6.3E-05	NA	6.6E-03	2.0E-04	Benzene	6.7E-04	NA	6.9E-02	2.1E-03	Cadmium	3.5E-04	NA	3.6E-02	1.1E-03	Chromium	4.4E-04	NA	4.6E-02	1.4E-03	Chromium VI	4.4E-04	NA	4.6E-02	1.4E-03	Dichlorobenzene	3.8E-04	NA	4.0E-02	1.2E-03	Formaldehyde	2.4E-02	NA	2.5E+00	7.5E-02	Hexane	5.7E-01	1.4E+01	5.9E+01	1.8E+00	Lead	1.6E-04	NA	1.6E-02	5.0E-04	Manganese	1.2E-04	2.9E-03	1.3E-02	3.8E-04	Mercury	8.2E-05	2.0E-03	8.6E-03	2.6E-04	Naphthalene	1.9E-04	NA	2.0E-02	6.1E-04	Nickel	6.7E-04	1.6E-02	6.9E-02	2.1E-03	POM	2.1E-04	NA	2.2E-02	6.6E-04	Toluene	1.1E-03	2.6E-02	1.1E-01	3.4E-03	Greenhouse Gas Pollutants				Em. Factor	Pollutant	lb/hr	lb/yr	tpy	(lb/mmBtu)	Carbon dioxide	see attached CEMs-based calculations			116.98	Methane	0.71	74.88	3.74E-02	2.20E-03	Nitrous Oxide	0.071	7.49	3.74E-03	2.20E-04
User Input																																																																																																																																																																																																																					
Company Name:	University of North Carolina at Chapel Hill																																																																																																																																																																																																																				
Plant County:	Orange County																																																																																																																																																																																																																				
Plant City:	Chapel Hill																																																																																																																																																																																																																				
Permit Number:	03069T32																																																																																																																																																																																																																				
User:	RST Engineering																																																																																																																																																																																																																				
Heat Input Capacity (mmBtu/hr):	323.17																																																																																																																																																																																																																				
Fuel Input Capacity (10 ⁶ scf/hr):	0.32																																																																																																																																																																																																																				
Annual Fuel Throughput (10 ⁶ scf):	32.97																																																																																																																																																																																																																				
Latest Construction/Modification Date:	N/A																																																																																																																																																																																																																				
Enter the boiler type below ▾																																																																																																																																																																																																																					
	2																																																																																																																																																																																																																				
Other NOx Control																																																																																																																																																																																																																					
	4																																																																																																																																																																																																																				
Large Wall-Fired Boilers (=>100 mmBtu/hr)																																																																																																																																																																																																																					
1 = Uncontrolled (Pre-NSPS)																																																																																																																																																																																																																					
2 = Uncontrolled (Post-NSPS)																																																																																																																																																																																																																					
3 = Controlled - Low NOx burners																																																																																																																																																																																																																					
4 = Controlled - Flue gas recirculation (FGR)																																																																																																																																																																																																																					
Small Boilers (<100 mmBtu/hr)																																																																																																																																																																																																																					
5 = Uncontrolled																																																																																																																																																																																																																					
6 = Controlled - Low NOx burners																																																																																																																																																																																																																					
7 = Controlled - Low NOx burners/FGR																																																																																																																																																																																																																					
Tangential-Fired Boilers (All Sizes)																																																																																																																																																																																																																					
8 = Uncontrolled																																																																																																																																																																																																																					
9 = Controlled - FGR																																																																																																																																																																																																																					
Residential Furnaces (<0.3 mmBtu/hr)																																																																																																																																																																																																																					
10 = Uncontrolled																																																																																																																																																																																																																					
Emissions Output (for operation 19.22 hr/yr)				Emission																																																																																																																																																																																																																	
Criteria Pollutants				Factor																																																																																																																																																																																																																	
Pollutant	lb/hr	lb/yr	tpy	(lb/mmscf)																																																																																																																																																																																																																	
PM	2.4E+00	2.5E+02	1.3E-01	7.6E+00																																																																																																																																																																																																																	
PM-10	2.4E+00	2.5E+02	1.3E-01	7.6E+00																																																																																																																																																																																																																	
PM-2.5	2.4E+00	2.5E+02	1.3E-01	7.6E+00																																																																																																																																																																																																																	
NOx	see attached CEMs-based calculations			1.9E+02																																																																																																																																																																																																																	
VOC	1.7E+00	1.8E+02	9.1E-02	5.5E+00																																																																																																																																																																																																																	
CO	2.7E+01	2.8E+03	1.4E+00	8.4E+01																																																																																																																																																																																																																	
SO2	see attached CEMs-based calculations			6.0E-01																																																																																																																																																																																																																	
Total HAP	6.0E-01	6.2E+01	3.1E-02	1.9E+00																																																																																																																																																																																																																	
Largest HAP	5.7E-01	5.9E+01	3.0E-02	1.8E+00																																																																																																																																																																																																																	
Toxic/Hazardous Air Pollutants																																																																																																																																																																																																																					
Pollutant	lb/hr	lb/day	lb/yr																																																																																																																																																																																																																		
Arsenic	6.3E-05	NA	6.6E-03	2.0E-04																																																																																																																																																																																																																	
Benzene	6.7E-04	NA	6.9E-02	2.1E-03																																																																																																																																																																																																																	
Cadmium	3.5E-04	NA	3.6E-02	1.1E-03																																																																																																																																																																																																																	
Chromium	4.4E-04	NA	4.6E-02	1.4E-03																																																																																																																																																																																																																	
Chromium VI	4.4E-04	NA	4.6E-02	1.4E-03																																																																																																																																																																																																																	
Dichlorobenzene	3.8E-04	NA	4.0E-02	1.2E-03																																																																																																																																																																																																																	
Formaldehyde	2.4E-02	NA	2.5E+00	7.5E-02																																																																																																																																																																																																																	
Hexane	5.7E-01	1.4E+01	5.9E+01	1.8E+00																																																																																																																																																																																																																	
Lead	1.6E-04	NA	1.6E-02	5.0E-04																																																																																																																																																																																																																	
Manganese	1.2E-04	2.9E-03	1.3E-02	3.8E-04																																																																																																																																																																																																																	
Mercury	8.2E-05	2.0E-03	8.6E-03	2.6E-04																																																																																																																																																																																																																	
Naphthalene	1.9E-04	NA	2.0E-02	6.1E-04																																																																																																																																																																																																																	
Nickel	6.7E-04	1.6E-02	6.9E-02	2.1E-03																																																																																																																																																																																																																	
POM	2.1E-04	NA	2.2E-02	6.6E-04																																																																																																																																																																																																																	
Toluene	1.1E-03	2.6E-02	1.1E-01	3.4E-03																																																																																																																																																																																																																	
Greenhouse Gas Pollutants				Em. Factor																																																																																																																																																																																																																	
Pollutant	lb/hr	lb/yr	tpy	(lb/mmBtu)																																																																																																																																																																																																																	
Carbon dioxide	see attached CEMs-based calculations			116.98																																																																																																																																																																																																																	
Methane	0.71	74.88	3.74E-02	2.20E-03																																																																																																																																																																																																																	
Nitrous Oxide	0.071	7.49	3.74E-03	2.20E-04																																																																																																																																																																																																																	

Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2014 Annual Emissions Inventory
Boiler #7
(ES-002-Boiler #7)
Facility ID # 6800043
Permit # 03069T32

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	2.535
Maximum fuel sulfur content (%):	0.002
Latest Construction/Modification Date:	N/A
Enter the boiler type below ▾	
15	

Boilers =>100 mmBtu/hr 1 = No. 6 oil fired, normal firing (U) 2 = No. 6 oil fired, normal firing (I) 3 = No. 6 oil fired, normal firing (C) 4 = No. 6 oil fired, normal firing, low NOx burner (U) 5 = No. 6 oil fired, normal firing, low NOx burner (I) 6 = No. 6 oil fired, normal firing, low NOx burner (C) 7 = No. 6 oil fired, tangential firing (U) 8 = No. 6 oil fired, tangential firing, low NOx burner (U) 9 = No. 5 oil fired, normal firing (U) 10 = No. 5 oil fired, normal firing (I) 11 = No. 5 oil fired, tangential firing (U) 12 = No. 4 oil fired, normal firing (U) 13 = No. 4 oil fired, normal firing (I) 14 = No. 4 oil fired, tangential firing (U) 15 = No. 2 oil fired (U,I)	Boilers =>100 mmBtu/hr (cont'd) 16 = No. 2 oil fired (C) 17 = No. 2 oil fired, LNB/FGR (U,I) 18 = No. 2 oil fired, LNB/FGR (C)
	19 = Vertical fired utility boiler
	Small Boilers (<100 mmBtu/hr)
	20 = No. 6 oil fired (I) 21 = No. 6 oil fired (C) 22 = No. 5 oil fired (C) 23 = No. 4 oil fired (C) 24 = No. 2 oil fired (I) 25 = No. 2 oil fired (C)
	26 = Residential Furnace

Emission Controls

Particulate controls

Enter the control type below ▾	Message Area	Or enter a PM control efficiency below to override built in values.												
3														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 80%;">Control Device</th> <th style="width: 20%;">Avg. Cont. Effic.</th> </tr> </thead> <tbody> <tr> <td>0 = None/other</td> <td></td> </tr> <tr> <td>1 = ESP</td> <td></td> </tr> <tr> <td>2 = Scrubber</td> <td></td> </tr> <tr> <td>3 = Bagfilter</td> <td style="text-align: center;">99.0</td> </tr> <tr> <td>4 = Multiple cyclone</td> <td></td> </tr> </tbody> </table>	Control Device	Avg. Cont. Effic.	0 = None/other		1 = ESP		2 = Scrubber		3 = Bagfilter	99.0	4 = Multiple cyclone			User Input PM Cont. Effic.
Control Device	Avg. Cont. Effic.													
0 = None/other														
1 = ESP														
2 = Scrubber														
3 = Bagfilter	99.0													
4 = Multiple cyclone														
		Message Area												

Postcombustion SO₂ controls

Enter the control type below ▾	Message Area	Or enter an SO ₂ control efficiency
---------------------------------------	--------------	--

0	below to override built in values.
Control Technology/Process	User Input SO₂ Cont. Effic.
0 = None/other	90.0
1 = Wet scrubber, Lime/limestone	User entered control efficiency may be overestimated and should be documented.
2 = Wet scrubber, Sodium carbonate	
3 = Wet scrubber, Magnesium oxide/hydroxide	Avg. Cont. Effic.
4 = Wet scrubber, Dual alkali	0.0
5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel	Remarks
6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity	NA
7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray	

NO_x controls

Enter the control type below ▾	Message Area	Or enter a NO _x control efficiency below to override built in values.
0		
Control Technology/Process		User Input NO_x Cont. Effic.
0 = None/other		0.0
1 = Low excess air (LEA)	Avg. Cont. Effic.	Message Area
2 = Staged combustion (SC)	0.0	
3 = Burners out of service (BOOS)	Remarks	
4 = Flue gas recirculation (FGR)	NA	
5 = Flue gas recirculation plus staged combustion		
6 = Low NO _x burners (LNB)		
7 = Reduced air preheat (RAP)		
8 = Selective noncatalytic reduction (SNCR)		
9 = Conventional selective catalytic reduction (SCR)		

Emissions Output (for operation 6.79 hr/yr)

Criteria Pollutants				Emission Factor ¹
Pollutant	lb/hr ²	tpy	lb/yr ³	(lb/10 ³ gal)
Total PM (FPM + CPM)	3.0	0.0017	3	3.30E+00
Filterable PM (FPM) rates @ 99% control	0.0	0.0000	0	2.00E+00
Condensable PM (CPM) ⁴	3.0	0.0016	3	1.30E+00
Filterable PM-10 ⁵	0.0	0.0000	0	1.00E+00
Filterable PM-2.5 ⁵	0.0	0.0000	0	2.50E-01
NO _x rates uncontrolled	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.0003	1	2.00E-01
CO	12	0.0063	13	5.00E+00
SO ₂ rates @ 90% control	see attached CEMs-based calculations			2.98E+02
Total HAP ⁶	4.17E-01	0.0002	0	1.81E-01
Largest HAP ⁶	1.84E-01	0.0001	0	7.97E-02

Toxic/Hazardous Air Pollutants.				Emission Factor ¹
Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	(lb/10 ³ gal)
Antimony rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates @ 99% control	1.29E-05	NA	1.42E-05	5.60E-04
Benzene	6.35E-03	NA	6.97E-03	2.75E-03
Beryllium rates @ 99% control	9.70E-06	NA	1.06E-05	4.20E-04
Cadmium rates @ 99% control	9.70E-06	NA	1.06E-05	4.20E-04
Chromium rates @ 99% control	9.70E-06	NA	1.06E-05	4.20E-04
Chromium VI rates @ 99% control	2.85E-06	NA	3.12E-06	1.23E-04
Cobalt rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.89E-03	NA	2.07E-03	8.17E-04
Fluoride	8.61E-02	2.07E+00	9.46E-02	3.73E-02
Formaldehyde	1.11E-01	2.66E+00	1.22E-01	4.80E-02
Lead rates @ 99% control	2.91E-05	NA	3.19E-05	1.26E-03
Manganese rates @ 99% control	1.94E-05	4.65E-04	2.13E-05	8.40E-04
Mercury	9.70E-04	2.33E-02	1.06E-03	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.45E-04	1.31E-02	5.98E-04	2.36E-04
Napthalene	7.69E-04	NA	8.44E-04	3.33E-04
Nickel rates @ 99% control	9.70E-06	2.33E-04	1.06E-05	4.20E-04
POM rates @ 99% control	7.62E-05	NA	8.37E-05	3.30E-03
Selenium rates @ 99% control	4.85E-05	NA	5.32E-05	2.10E-03

Toluene	1.84E-01	4.41E+00	2.02E-01	7.97E-02
Xylene	3.23E-03	7.76E-02	3.55E-03	1.40E-03

Greenhouse Gases				Emission Factor (lb/10 ³ gal)
Pollutant	lb/hr ²	tpy	lb/yr ³	
Carbon dioxide	see attached CEMs-based calculations			22371.42
Methane	2.09E+00	1.15E-03	2.30E+00	0.907
Nitrous Oxide	4.19E-01	2.30E-04	4.60E-01	0.18

¹Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

²Hourly emission rates for all pollutants are based on hourly rated capacity.

³Annual emission rates for all pollutants are based on maximum annual fuel throughput.

⁴Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

⁵AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

⁶Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

⁷Daily emission rates are based on operation 24 hours per day at rated capacity.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Revise per Stk Test

Boiler # 7 Wood Pellet Combustion

0.0 ton/yr, wood pellets burned 0.00E+00 MMBtu/yr
 64.63 MMBtu/hr, HI from wood 99.8% PM control 99.6% Metals control
 8,125 Btu/lb, wood heating value 67.8% HCl efficiency*
 3.98 ton/hr, max. wood firing rate 92.3% Hg efficiency*
 8,760 hr/yr *Calculated from August 2009 EPA Tests

Pollutant	Emission Factor (lb/MMBtu) ¹	Emissions (lb/hr)	Emissions (lb/yr)	Emissions (ton/yr)
NOx	see attached CEMs-based calculations			
CO	0.17	10.99	0.0	0.00
SO₂	see attached CEMs-based calculations			
PM	0.417	0.054	0.00	0.00000
PM ₁₀	0.377	0.049	0.00	0.00000
PM _{2.5}	0.327	0.042	0.00	0.00000
VOC	0.017	1.10	0.0	0.000
	lb/MMBtu			
Acetaldehyde	8.30E-04	5.36E-02	0.00E+00	0.00E+00
Acetophenone	3.20E-09	2.07E-07	0.00E+00	0.00E+00
Acrolein	4.00E-03	2.59E-01	0.00E+00	0.00E+00
Antimony	7.90E-06	2.04E-06	0.00E+00	0.00E+00
Arsenic	2.20E-05	5.69E-06	0.00E+00	0.00E+00
Benzene	4.20E-03	2.71E-01	0.00E+00	0.00E+00
Benzo(a)pyrene	2.60E-06	1.68E-04	0.00E+00	0.00E+00
Beryllium	1.10E-06	2.84E-07	0.00E+00	0.00E+00
Cadmium	4.10E-06	1.06E-06	0.00E+00	0.00E+00
Carbon tetrachloride	4.50E-05	2.91E-03	0.00E+00	0.00E+00
Chlorine	7.90E-04	5.11E-02	0.00E+00	0.00E+00
Chlorobenzene	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Chloroform	2.80E-05	1.81E-03	0.00E+00	0.00E+00
Chromium	1.75E-05	4.52E-06	0.00E+00	0.00E+00
Cobalt	6.50E-06	1.68E-06	0.00E+00	0.00E+00
Di(2-ethylhexyl)phthalate	4.70E-08	3.04E-06	0.00E+00	0.00E+00
Dinitrophenol, 2,4-	1.80E-07	1.16E-05	0.00E+00	0.00E+00
Ethyl Benzene	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Ethylene dichloride	2.90E-05	1.87E-03	0.00E+00	0.00E+00
Formaldehyde	4.40E-03	2.84E-01	0.00E+00	0.00E+00
Hexachlorodibenzo-p-dioxin	1.60E-06	1.03E-04	0.00E+00	0.00E+00
Hydrogen Chloride	1.90E-02	3.95E-01	0.00E+00	0.00E+00
Lead	4.80E-05	1.24E-05	0.00E+00	0.00E+00
Manganese	1.60E-03	4.14E-04	0.00E+00	0.00E+00
Mercury	3.50E-06	1.74E-05	0.00E+00	0.00E+00
Methyl bromide	1.50E-05	9.70E-04	0.00E+00	0.00E+00
Methyl chloride	2.30E-05	1.49E-03	0.00E+00	0.00E+00
Methyl chloroform	3.10E-05	2.00E-03	0.00E+00	0.00E+00
Methyl ethyl ketone	5.40E-06	3.49E-04	0.00E+00	0.00E+00
Methylene chloride	2.90E-04	1.87E-02	0.00E+00	0.00E+00
Naphthalene	9.70E-05	6.27E-03	0.00E+00	0.00E+00
Nickel	3.30E-05	8.53E-06	0.00E+00	0.00E+00
Nitrophenol, 4-	1.10E-07	7.11E-06	0.00E+00	0.00E+00
Pentachlorophenol	5.10E-08	3.30E-06	0.00E+00	0.00E+00
Perchloroethylene	3.80E-05	2.46E-03	0.00E+00	0.00E+00
Phenol	5.10E-05	3.30E-03	0.00E+00	0.00E+00
Phosphorus	2.70E-05	6.98E-06	0.00E+00	0.00E+00
Polychlorinated biphenyls	8.15E-09	5.27E-07	0.00E+00	0.00E+00
POM	1.25E-04	8.08E-03	0.00E+00	0.00E+00
Propionaldehyde	6.10E-05	3.94E-03	0.00E+00	0.00E+00
Propylene dichloride	3.30E-05	2.13E-03	0.00E+00	0.00E+00
Selenium	2.80E-06	7.24E-07	0.00E+00	0.00E+00
Styrene	1.90E-03	1.23E-01	0.00E+00	0.00E+00
2,3,7,8-TCDD	8.60E-12	5.56E-10	0.00E+00	0.00E+00
Toluene	9.20E-04	5.95E-02	0.00E+00	0.00E+00
Trichloroethylene	3.00E-05	1.94E-03	0.00E+00	0.00E+00
Trichlorofluoromethane	4.10E-05	2.65E-03	0.00E+00	0.00E+00
Trichlorophenol	2.20E-08	1.42E-06	0.00E+00	0.00E+00
Vinyl chloride	1.80E-05	1.16E-03	0.00E+00	0.00E+00
Xylenes	2.50E-05	1.62E-03	0.00E+00	0.00E+00
Carbon Dioxide	see attached CEMs-based calculations			
Methane	0.0159	1.026	0.0	0.0000
N ₂ O	0.00794	0.51	0.0	0.0000

1-Emission factors based on DAQ wood combustion spreadsheet

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Sulfur Dioxide Emissions from Boiler #7 (ES-002-Boiler #7)

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for SO₂ emissions.

For the 2014 calendar year, 30 day facility averages for the SO₂ emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2014	0.17
February 2014	0.14
March 2014	0.14
April 2014	0.14
May 2014	0.17
June 2014	0.16
July 2014	0.15
August 2014	0.15
September 2014	0.16
October 2014	0.16
November 2014	0.16
December 2014	0.16
Annual Average	0.155

This average includes SO₂ emissions from coal, fuel oil, wood, and natural gas from Boiler #7 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #7 for 2014

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
45,730	32,975	2,535	0.0
Coal (12,426 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.14E+06	3.40E+04	3.48E+02	0

Total for Boiler #7 (MMBtu/yr)	1.17E+06
--------------------------------	----------

Total SO ₂ Emissions from Boiler #7 (lb/yr)	181,472
Total SO₂ Emissions from Boiler #7 (ton/yr)	90.736

SO ₂ Emissions Associated with Coal Combustion (ton/yr)	90.71
SO ₂ Emissions Associated with No. 2 Fuel Oil Combustion (ton/yr)	0.028
SO ₂ Emissions Associated with Natural Gas Combustion (ton/yr)	0*
SO ₂ Emissions Associated with Wood Pellet Combustion (ton/yr)	0*

*All SO₂ measured by CEMS allocated to coal and No.2 fuel oil.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Nitrogen Dioxide Emissions from Boiler #7

(ES-002-Boiler #7)

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2014 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2014	0.35
February 2014	0.36
March 2014	0.34
April 2014	0.28
May 2014	0.20
June 2014	0.22
July 2014	0.24
August 2014	0.22
September 2014	0.23
October 2014	0.26
November 2014	0.31
December 2014	0.33
Annual Average	0.28

This average includes NOx emissions from coal, fuel oil, wood, and natural gas within Boiler #7 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #7 for 2014

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
45,730	32,975	2,535	0.0
Coal (12,426 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.14E+06	3.40E+04	3.48E+02	0

Total for Boiler #7 (MMBtu/yr)	1.17E+06
--------------------------------	----------

NOx Emissions from Boiler #7 (lb/yr)	325,870
NOx Emissions from Boiler #7 (ton/yr)	162.93

NOx Emissions Associated with Coal Combustion (ton/yr)	158.16
NOx Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	0.05
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	4.73
NOx Emissions Associated with Wood Pellet Combustion (ton/yr)	0.0

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

CO₂ Emissions from Boiler No.7 (ES-3)

The exhaust system on Boiler #7 is equipped with a continuous emissions monitor (CEMs) for CO₂ concentrations. The exhaust also includes a flow monitor. Mass CO₂ emissions are calculated by the DAHS for GHG reporting. For the 2014 calendar year, the monthly CO₂ emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2014	16,865	18,591
February 2014	12,423	13,694
March 2014	8,633	9,516
April 2014	4,577	5,045
May 2014	8,162	8,997
June 2014	8,481	9,349
July 2014	9,106	10,037
August 2014	7,289	8,035
September 2014	11,139	12,279
October 2014	9,185	10,125
November 2014	9,185	10,125
December 2014	12,700	13,999
Annual Total	117,745	129,790

This total includes CO₂ emissions from coal, fuel oil, wood pellets, and natural gas from Boiler #7 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #7 for 2014

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 2 Oil Gallons/yr	Wood Pellets, Tons/yr
45,730	32,975	2,535	0.0
Coal (12,426 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)	Wood (8,185 btu/lb)
MMBtu/yr			
1.14E+06	3.40E+04	3.48E+02	0

Total for Boiler #7 (MMBtu/yr)	1.17E+06
-----------------------------------	----------

CO₂ Emission Rate Ratios

	kg/MMBtu	Ratio
coal	93.28	1
n.gas	53.06	0.56883
No.2 oil	73.96	0.79288
wood	93.80	1.00557

CO₂ Emissions Associated with Coal Combustion (ton/yr)	127,590.2
CO₂ Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	30.96
CO₂ Emissions Associated with Natural Gas Combustion (ton/yr)	2,169.0
CO₂ Emissions Associated with Wood Pellet Combustion (ton/yr)	0.0

1.16E+06 Dist. Factor

129,790.1

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Boiler #8

(ES-003-Boiler #8)

Operating Scenario #1 - Natural Gas Firing
Operating Scenario #2 - No. 2 Fuel Oil Firing

Boiler #8 - Operating Scenario #1 - Natural GasIf Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)Facility ID #: **6800043**Permit #: **03069T32**County: **Orange**DAQ Region: **Raleigh**Facility Name: **University of North Carolina at Chapel Hill**

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-003-Boiler #8					
2. Emission Source Description		Natural Gas / No. 2 Fuel Oil Fired Boiler					
3. Operating Scenario Description		Operating Scenario #1 - Natural Gas					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		338.0 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		76,649			1,000 ft ³ /yr		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	1,030 Btu/ft ³

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	None	None
ii.	None	None
iii.	None	None
iv.	None	None

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	Standby	Days/Week	Standby	Weeks/Year	Standby	Hours/Year	1,833 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	10%	Mar-May	4%	June-Aug	69%	Sept-Nov	17%
------------------------------	-----	---------	----	----------	-----	----------	-----

Boiler #8 - Operating Scenario #1 - Natural Gas

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-003-Boiler #8

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	3.22	8	N/A
NOx	NOx	2.04	8	N/A
PM Total	PM	0.29	8	N/A
PM-2.5	PM-2.5	0.29	8	N/A
PM-10	PM-10	0.29	8	N/A
SO2	SO2	0.02	8	N/A
VOC	VOC	0.21	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	1.53E-02	8	N/A
Benzene	71-43-2	0.16	8	N/A
Cadmium	CADMIUMCPDS	8.43E-02	8	N/A
Chromium	CROMCPDS	1.07E-01	8	N/A
Chromium VI	CHROM6CPDS	1.07E-01	8	N/A
Dichlorobenzene	106-46-7	9.20E-02	8	N/A
Formaldehyde	50-00-0	5.75	8	N/A
Hexane	HEXANEISO	1.38E+02	8	N/A
Lead	LEADCPDS	3.83E-02	8	N/A
Manganese	MANGCPDS	2.91E-02	8	N/A
Mercury	MERCPDS	1.99E-02	8	N/A
Napthalene	91-20-3	4.68E-02	8	N/A
Nickel	NICKCPDS	0.16	8	N/A
POM	POM	5.07E-02	8	N/A
Toluene	108-88-3	0.26	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	4,754.30	8	N/A
Methane	CH ₄	8.70E-02	8	N/A
Nitrous oxide	N ₂ O	8.70E-03	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Boiler #8 - Operating Scenario #2 - No. 2 Fuel OilIf Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)Facility ID #: **6800043**Permit #: **03069T32**County: **Orange**DAQ Region: **Raleigh**Facility Name: **University of North Carolina at Chapel Hill**

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-003-Boiler #8					
2. Emission Source Description		Natural Gas / No. 2 Fuel Oil Fired Boiler					
3. Operating Scenario Description		Operating Scenario #2 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		338.0 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		3,314				gallons/year	
6. Fuel Information (if fuel used)		% Sulfur	0.002%	% Ash		Heat Content (Btu/lb or mmCF)	137,204 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	N/A	N/A
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	Standby	Days/Week	Standby	Weeks/Year	Standby	Hours/Year	1,833 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	97%	Mar-May	0%	June-Aug	0%	Sept-Nov	3%
------------------------------	-----	---------	----	----------	----	----------	----

Emission Source/Operating Scenario Data Page 2 of 2
Boiler #8 - Operating Scenario #2 - No. 2 Fuel Oil
If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043
 Permit #: 03069T32
 County: Orange
 DAQ Region: Raleigh

**North Carolina Department of Environment and Natural Resources
 Division of Air Quality
 Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-003-Boiler #8

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.01	8	N/A
NOx	NOx	0.01	8	N/A
PM Total	PM	0.01	8	N/A
PM-2.5	PM-2.5	0.00	8	N/A
PM-10	PM-10	0.00	8	N/A
SO2	SO2	0.00	8	N/A
VOC	VOC	0.00	8	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Arsenic	ARSENICPDS	1.86E-03	8	N/A
Benzene	71-43-2	9.11E-03	8	N/A
Beryllium	BERYLCPDS	1.39E-03	8	N/A
Cadmium	CADMIUMCPDS	1.39E-03	8	N/A
Chromium	CROMCPDS	1.39E-03	8	N/A
Chromium VI	CHROM6CPDS	4.09E-04	8	N/A
Ethylbenzene	100-41-4	2.71E-03	8	N/A
Fluoride	16984-48-8	0.12	8	N/A
Formaldehyde	50-00-0	0.16	8	N/A
Lead	LEADCPDS	4.18E-03	8	N/A
Manganese	MANGCPDS	2.78E-03	8	N/A
Mercury	MERCPDS	1.39E-03	8	N/A
Methyl chloroform	71-55-6	7.82E-04	8	N/A
Napthalene	91-20-3	0.0011	8	N/A
Nickel	NICKCPDS	1.39E-03	8	N/A
POM	POM	1.09E-02	8	N/A
Selenium	SEC	6.96E-03	8	N/A
Toluene	108-88-3	0.26	8	N/A
Xylene	1330-20-7	4.64E-03	8	N/A

Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	38.17	8	N/A
Methane	CH ₄	1.50E-03	8	N/A
Nitrous oxide	N ₂ O	3.01E-04	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Natural Gas Combustion Emissions Calculator NG2000 Revision C
2014 Annual Emissions Inventory
Boiler #8
(ES-003-Boiler #8)

Facility ID # 6800043
 Permit # 03069T32

Operating Scenario #1

User Input	Emissions Output																																																																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Company Name:</td> <td style="text-align: center;">University of North Carolina at Chapel Hill</td> </tr> <tr> <td>Plant County:</td> <td style="text-align: center;">Orange County</td> </tr> <tr> <td>Plant City:</td> <td style="text-align: center;">Chapel Hill</td> </tr> <tr> <td>Permit Number:</td> <td style="text-align: center;">03069T32</td> </tr> <tr> <td>User:</td> <td style="text-align: center;">RST Engineering</td> </tr> <tr> <td>Heat Input Capacity (mmBtu/hr):</td> <td style="text-align: center;">338</td> </tr> <tr> <td>Fuel Input Capacity (10⁶ scf/hr):</td> <td style="text-align: center;">0.33</td> </tr> <tr> <td>Annual Fuel Throughput (10⁶ scf):</td> <td style="text-align: center;">76.65</td> </tr> <tr> <td>Latest Construction/Modification Date:</td> <td style="text-align: center;">N/A</td> </tr> </table>	Company Name:	University of North Carolina at Chapel Hill	Plant County:	Orange County	Plant City:	Chapel Hill	Permit Number:	03069T32	User:	RST Engineering	Heat Input Capacity (mmBtu/hr):	338	Fuel Input Capacity (10⁶ scf/hr):	0.33	Annual Fuel Throughput (10⁶ scf):	76.65	Latest Construction/Modification Date:	N/A	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4">Criteria Pollutants</th> <th rowspan="2">Emission Factor (lb/mmscf)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> </tr> <tr> <td>PM</td> <td>2.5E+00</td> <td>5.8E+02</td> <td>2.9E-01</td> <td>7.6E+00</td> </tr> <tr> <td>PM-10</td> <td>2.5E+00</td> <td>5.8E+02</td> <td>2.9E-01</td> <td>7.6E+00</td> </tr> <tr> <td>PM-2.5</td> <td>2.5E+00</td> <td>5.8E+02</td> <td>2.9E-01</td> <td>7.6E+00</td> </tr> <tr> <td>NOx</td> <td colspan="3">see attached CEMs-based calculations</td> <td>1.9E+02</td> </tr> <tr> <td>VOC</td> <td>1.8E+00</td> <td>4.2E+02</td> <td>2.1E-01</td> <td>5.5E+00</td> </tr> <tr> <td>CO</td> <td>2.8E+01</td> <td>6.4E+03</td> <td>3.2E+00</td> <td>8.4E+01</td> </tr> <tr> <td>SO2</td> <td>2.0E-01</td> <td>4.6E+01</td> <td>2.3E-02</td> <td>6.0E-01</td> </tr> <tr> <td>Total HAP</td> <td>6.3E-01</td> <td>1.4E+02</td> <td>7.2E-02</td> <td>1.9E+00</td> </tr> <tr> <td>Largest HAP</td> <td>6.0E-01</td> <td>1.4E+02</td> <td>6.9E-02</td> <td>1.8E+00</td> </tr> </table>	Criteria Pollutants				Emission Factor (lb/mmscf)	Pollutant	lb/hr	lb/yr	tpy	PM	2.5E+00	5.8E+02	2.9E-01	7.6E+00	PM-10	2.5E+00	5.8E+02	2.9E-01	7.6E+00	PM-2.5	2.5E+00	5.8E+02	2.9E-01	7.6E+00	NOx	see attached CEMs-based calculations			1.9E+02	VOC	1.8E+00	4.2E+02	2.1E-01	5.5E+00	CO	2.8E+01	6.4E+03	3.2E+00	8.4E+01	SO2	2.0E-01	4.6E+01	2.3E-02	6.0E-01	Total HAP	6.3E-01	1.4E+02	7.2E-02	1.9E+00	Largest HAP	6.0E-01	1.4E+02	6.9E-02	1.8E+00													
Company Name:	University of North Carolina at Chapel Hill																																																																																					
Plant County:	Orange County																																																																																					
Plant City:	Chapel Hill																																																																																					
Permit Number:	03069T32																																																																																					
User:	RST Engineering																																																																																					
Heat Input Capacity (mmBtu/hr):	338																																																																																					
Fuel Input Capacity (10⁶ scf/hr):	0.33																																																																																					
Annual Fuel Throughput (10⁶ scf):	76.65																																																																																					
Latest Construction/Modification Date:	N/A																																																																																					
Criteria Pollutants				Emission Factor (lb/mmscf)																																																																																		
Pollutant	lb/hr	lb/yr	tpy																																																																																			
PM	2.5E+00	5.8E+02	2.9E-01	7.6E+00																																																																																		
PM-10	2.5E+00	5.8E+02	2.9E-01	7.6E+00																																																																																		
PM-2.5	2.5E+00	5.8E+02	2.9E-01	7.6E+00																																																																																		
NOx	see attached CEMs-based calculations			1.9E+02																																																																																		
VOC	1.8E+00	4.2E+02	2.1E-01	5.5E+00																																																																																		
CO	2.8E+01	6.4E+03	3.2E+00	8.4E+01																																																																																		
SO2	2.0E-01	4.6E+01	2.3E-02	6.0E-01																																																																																		
Total HAP	6.3E-01	1.4E+02	7.2E-02	1.9E+00																																																																																		
Largest HAP	6.0E-01	1.4E+02	6.9E-02	1.8E+00																																																																																		
<p style="color: red;">Enter the boiler type below ▾</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: right;">3 + 4</td> </tr> </table>	3 + 4	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4">Toxic/Hazardous Air Pollutants</th> <th rowspan="2">Emission Factor (lb/mmscf)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/day</th> <th>lb/yr</th> </tr> <tr> <td>Arsenic</td> <td>6.6E-05</td> <td>NA</td> <td>1.5E-02</td> <td>2.0E-04</td> </tr> <tr> <td>Benzene</td> <td>7.0E-04</td> <td>NA</td> <td>1.6E-01</td> <td>2.1E-03</td> </tr> <tr> <td>Cadmium</td> <td>3.6E-04</td> <td>NA</td> <td>8.4E-02</td> <td>1.1E-03</td> </tr> <tr> <td>Chromium</td> <td>4.6E-04</td> <td>NA</td> <td>1.1E-01</td> <td>1.4E-03</td> </tr> <tr> <td>Chromium VI</td> <td>4.6E-04</td> <td>NA</td> <td>1.1E-01</td> <td>1.4E-03</td> </tr> <tr> <td>Dichlorobenzene</td> <td>4.0E-04</td> <td>NA</td> <td>9.2E-02</td> <td>1.2E-03</td> </tr> <tr> <td>Formaldehyde</td> <td>2.5E-02</td> <td>NA</td> <td>5.7E+00</td> <td>7.5E-02</td> </tr> <tr> <td>Hexane</td> <td>6.0E-01</td> <td>1.4E+01</td> <td>1.4E+02</td> <td>1.8E+00</td> </tr> <tr> <td>Lead</td> <td>1.7E-04</td> <td>NA</td> <td>3.8E-02</td> <td>5.0E-04</td> </tr> <tr> <td>Manganese</td> <td>1.3E-04</td> <td>3.0E-03</td> <td>2.9E-02</td> <td>3.8E-04</td> </tr> <tr> <td>Mercury</td> <td>8.6E-05</td> <td>2.1E-03</td> <td>2.0E-02</td> <td>2.6E-04</td> </tr> <tr> <td>Naphthalene</td> <td>2.0E-04</td> <td>NA</td> <td>4.7E-02</td> <td>6.1E-04</td> </tr> <tr> <td>Nickel</td> <td>7.0E-04</td> <td>1.7E-02</td> <td>1.6E-01</td> <td>2.1E-03</td> </tr> <tr> <td>POM</td> <td>2.2E-04</td> <td>NA</td> <td>5.1E-02</td> <td>6.6E-04</td> </tr> <tr> <td>Toluene</td> <td>1.1E-03</td> <td>2.7E-02</td> <td>2.6E-01</td> <td>3.4E-03</td> </tr> </table>	Toxic/Hazardous Air Pollutants				Emission Factor (lb/mmscf)	Pollutant	lb/hr	lb/day	lb/yr	Arsenic	6.6E-05	NA	1.5E-02	2.0E-04	Benzene	7.0E-04	NA	1.6E-01	2.1E-03	Cadmium	3.6E-04	NA	8.4E-02	1.1E-03	Chromium	4.6E-04	NA	1.1E-01	1.4E-03	Chromium VI	4.6E-04	NA	1.1E-01	1.4E-03	Dichlorobenzene	4.0E-04	NA	9.2E-02	1.2E-03	Formaldehyde	2.5E-02	NA	5.7E+00	7.5E-02	Hexane	6.0E-01	1.4E+01	1.4E+02	1.8E+00	Lead	1.7E-04	NA	3.8E-02	5.0E-04	Manganese	1.3E-04	3.0E-03	2.9E-02	3.8E-04	Mercury	8.6E-05	2.1E-03	2.0E-02	2.6E-04	Naphthalene	2.0E-04	NA	4.7E-02	6.1E-04	Nickel	7.0E-04	1.7E-02	1.6E-01	2.1E-03	POM	2.2E-04	NA	5.1E-02	6.6E-04	Toluene	1.1E-03	2.7E-02	2.6E-01	3.4E-03
3 + 4																																																																																						
Toxic/Hazardous Air Pollutants				Emission Factor (lb/mmscf)																																																																																		
Pollutant	lb/hr	lb/day	lb/yr																																																																																			
Arsenic	6.6E-05	NA	1.5E-02	2.0E-04																																																																																		
Benzene	7.0E-04	NA	1.6E-01	2.1E-03																																																																																		
Cadmium	3.6E-04	NA	8.4E-02	1.1E-03																																																																																		
Chromium	4.6E-04	NA	1.1E-01	1.4E-03																																																																																		
Chromium VI	4.6E-04	NA	1.1E-01	1.4E-03																																																																																		
Dichlorobenzene	4.0E-04	NA	9.2E-02	1.2E-03																																																																																		
Formaldehyde	2.5E-02	NA	5.7E+00	7.5E-02																																																																																		
Hexane	6.0E-01	1.4E+01	1.4E+02	1.8E+00																																																																																		
Lead	1.7E-04	NA	3.8E-02	5.0E-04																																																																																		
Manganese	1.3E-04	3.0E-03	2.9E-02	3.8E-04																																																																																		
Mercury	8.6E-05	2.1E-03	2.0E-02	2.6E-04																																																																																		
Naphthalene	2.0E-04	NA	4.7E-02	6.1E-04																																																																																		
Nickel	7.0E-04	1.7E-02	1.6E-01	2.1E-03																																																																																		
POM	2.2E-04	NA	5.1E-02	6.6E-04																																																																																		
Toluene	1.1E-03	2.7E-02	2.6E-01	3.4E-03																																																																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Other NOx Control</td> </tr> <tr> <td>Enter 1 below if SNCR is applied to the boiler.</td> </tr> <tr> <td style="text-align: right;">0</td> </tr> </table>	Other NOx Control	Enter 1 below if SNCR is applied to the boiler.	0	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4">Greenhouse Gas Pollutants</th> <th rowspan="2">Em. Factor (lb/mmBtu)</th> </tr> <tr> <th>Pollutant</th> <th>lb/hr</th> <th>lb/yr</th> <th>tpy</th> </tr> <tr> <td>Carbon dioxide</td> <td colspan="3">see attached CEMs-based calculations</td> <td>116.98</td> </tr> <tr> <td>Methane</td> <td>0.75</td> <td>174.05</td> <td>8.70E-02</td> <td>2.20E-03</td> </tr> <tr> <td>Nitrous Oxide</td> <td>0.075</td> <td>17.40</td> <td>8.70E-03</td> <td>2.20E-04</td> </tr> </table>	Greenhouse Gas Pollutants				Em. Factor (lb/mmBtu)	Pollutant	lb/hr	lb/yr	tpy	Carbon dioxide	see attached CEMs-based calculations			116.98	Methane	0.75	174.05	8.70E-02	2.20E-03	Nitrous Oxide	0.075	17.40	8.70E-03	2.20E-04																																																										
Other NOx Control																																																																																						
Enter 1 below if SNCR is applied to the boiler.																																																																																						
0																																																																																						
Greenhouse Gas Pollutants				Em. Factor (lb/mmBtu)																																																																																		
Pollutant	lb/hr	lb/yr	tpy																																																																																			
Carbon dioxide	see attached CEMs-based calculations			116.98																																																																																		
Methane	0.75	174.05	8.70E-02	2.20E-03																																																																																		
Nitrous Oxide	0.075	17.40	8.70E-03	2.20E-04																																																																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Large Wall-Fired Boilers (=>100 mmBtu/hr)</td> </tr> <tr> <td>1 = Uncontrolled (Pre-NSPS)</td> </tr> <tr> <td>2 = Uncontrolled (Post-NSPS)</td> </tr> <tr> <td>3 = Controlled - Low NOx burners</td> </tr> <tr> <td>4 = Controlled - Flue gas recirculation (FGR)</td> </tr> </table>	Large Wall-Fired Boilers (=>100 mmBtu/hr)	1 = Uncontrolled (Pre-NSPS)	2 = Uncontrolled (Post-NSPS)	3 = Controlled - Low NOx burners	4 = Controlled - Flue gas recirculation (FGR)																																																																																	
Large Wall-Fired Boilers (=>100 mmBtu/hr)																																																																																						
1 = Uncontrolled (Pre-NSPS)																																																																																						
2 = Uncontrolled (Post-NSPS)																																																																																						
3 = Controlled - Low NOx burners																																																																																						
4 = Controlled - Flue gas recirculation (FGR)																																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Small Boilers (<100 mmBtu/hr)</td> </tr> <tr> <td>5 = Uncontrolled</td> </tr> <tr> <td>6 = Controlled - Low NOx burners</td> </tr> <tr> <td>7 = Controlled - Low NOx burners/FGR</td> </tr> </table>	Small Boilers (<100 mmBtu/hr)	5 = Uncontrolled	6 = Controlled - Low NOx burners	7 = Controlled - Low NOx burners/FGR																																																																																		
Small Boilers (<100 mmBtu/hr)																																																																																						
5 = Uncontrolled																																																																																						
6 = Controlled - Low NOx burners																																																																																						
7 = Controlled - Low NOx burners/FGR																																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Tangential-Fired Boilers (All Sizes)</td> </tr> <tr> <td>8 = Uncontrolled</td> </tr> <tr> <td>9 = Controlled - FGR</td> </tr> </table>	Tangential-Fired Boilers (All Sizes)	8 = Uncontrolled	9 = Controlled - FGR																																																																																			
Tangential-Fired Boilers (All Sizes)																																																																																						
8 = Uncontrolled																																																																																						
9 = Controlled - FGR																																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Residential Furnaces (<0.3 mmBtu/hr)</td> </tr> <tr> <td>10 = Uncontrolled</td> </tr> </table>	Residential Furnaces (<0.3 mmBtu/hr)	10 = Uncontrolled																																																																																				
Residential Furnaces (<0.3 mmBtu/hr)																																																																																						
10 = Uncontrolled																																																																																						

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2014 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T32

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	3.31
Maximum fuel sulfur content (%):	0.002
Latest Construction/Modification Date:	N/A

Enter the boiler type below ▾	
	17

Boilers =>100 mmBtu/hr
1 = No. 6 oil fired, normal firing (U)
2 = No. 6 oil fired, normal firing (I)
3 = No. 6 oil fired, normal firing (C)
4 = No. 6 oil fired, normal firing, low NOx burner (U)
5 = No. 6 oil fired, normal firing, low NOx burner (I)
6 = No. 6 oil fired, normal firing, low NOx burner (C)
7 = No. 6 oil fired, tangential firing (U)
8 = No. 6 oil fired, tangential firing, low NOx burner (U)
9 = No. 5 oil fired, normal firing (U)
10 = No. 5 oil fired, normal firing (I)
11 = No. 5 oil fired, tangential firing (U)
12 = No. 4 oil fired, normal firing (U)
13 = No. 4 oil fired, normal firing (I)
14 = No. 4 oil fired, tangential firing (U)
15 = No. 2 oil fired (U,I)

Boilers =>100 mmBtu/hr (cont'd)
16 = No. 2 oil fired (C)
17 = No. 2 oil fired, LNB/FGR (U,I)
18 = No. 2 oil fired, LNB/FGR (C)
19 = Vertical fired utility boiler
Small Boilers (<100 mmBtu/hr)
20 = No. 6 oil fired (I)
21 = No. 6 oil fired (C)
22 = No. 5 oil fired (C)
23 = No. 4 oil fired (C)
24 = No. 2 oil fired (I)
25 = No. 2 oil fired (C)
26 = Residential Furnace

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2014 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T32

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	3.31
Maximum fuel sulfur content (%):	0.002
Latest Construction/Modification Date:	N/A

Emission Controls

Particulate controls

Enter the control type below ▾	Message Area	Or enter a PM control efficiency below to override built in values.
0		
<u>Control Device</u>	<u>Avg. Cont. Effic.</u>	<u>User Input PM Cont. Effic.</u>
0 = None/other	0.0	0.0
1 = ESP		Message Area
2 = Scrubber		
3 = Bagfilter	0.0	
4 = Multiple cyclone		

Postcombustion SO₂ controls

Enter the control type below ▾	Message Area	Or enter an SO ₂ control efficiency below to override built in values.
0		
<u>Control Technology/Process</u>	<u>Avg. Cont. Effic.</u>	<u>User Input SO₂ Cont. Effic.</u>
0 = None/other		0.0
1 = Wet scrubber, Lime/limestone	0.0	Message Area
2 = Wet scrubber, Sodium carbonate		
3 = Wet scrubber, Magnesium oxide/hydroxide		
4 = Wet scrubber, Dual alkali		
5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel	<u>Remarks</u>	
6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity	NA	
7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray		

NO_x controls

Enter the control type below ▾		Or enter a NO _x control efficiency below to override built in values.
5 + 6		
<u>Control Technology/Process</u>	<u>Avg. Cont. Effic.</u>	<u>User Input NO_x Cont. Effic.</u>
0 = None/other		0.0
1 = Low excess air (LEA)	0.0	Message Area
2 = Staged combustion (SC)		
3 = Burners out of service (BOOS)		
4 = Flue gas recirculation (FGR)	<u>Remarks</u>	
5 = Flue gas recirculation plus staged combustion	NA	
6 = Low NO _x burners (LNB)		
7 = Reduced air preheat (RAP)		
8 = Selective noncatalytic reduction (SNCR)		
9 = Conventional selective catalytic reduction (SCR)		

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2014 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T32

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	3.31
Maximum fuel sulfur content (%):	0.002
Latest Construction/Modification Date:	N/A

Emissions Output

Criteria Pollutants

Pollutant	lb/hr ²	tpy	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Total PM (FPM + CPM)	8.0	0.0055	11	3.30E+00
Filterable PM (FPM) rates uncontrolled	4.8	0.0033	7	2.00E+00
Condensable PM (CPM) ⁴	3.1	0.0022	4	1.30E+00
Filterable PM-10 ⁵	2.4	0.0017	3	1.00E+00
Filterable PM-2.5 ⁵	0.6	0.0004	1	2.50E-01
NOx rates uncontrolled	see attached CEMs-based calculations			2.40E+01
NMTOC	0	0.0003	1	2.00E-01
CO	12	0.0083	17	5.00E+00
SO2 rates uncontrolled	0.7	0.0005	1	0.288
Total HAP ⁶	4.36E-01	0.0003	1	1.81E-01
Largest HAP ⁶	1.92E-01	0.0001	0	7.97E-02

***NOx emissions based on CEMs data.*

Toxic/Hazardous Air Pollutants.

Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Antimony rates uncontrolled	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates uncontrolled	1.35E-03	NA	1.86E-03	5.60E-04
Benzene	6.64E-03	NA	9.11E-03	2.75E-03
Beryllium rates uncontrolled	1.01E-03	NA	1.39E-03	4.20E-04
Cadmium rates uncontrolled	1.01E-03	NA	1.39E-03	4.20E-04
Chromium rates uncontrolled	1.01E-03	NA	1.39E-03	4.20E-04
Chromium VI rates uncontrolled	2.98E-04	NA	4.09E-04	1.23E-04
Cobalt rates uncontrolled	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.97E-03	NA	2.71E-03	8.17E-04
Fluoride	9.01E-02	2.16E+00	1.24E-01	3.73E-02
Formaldehyde	1.16E-01	2.78E+00	1.59E-01	4.80E-02
Lead rates uncontrolled	3.04E-03	NA	4.18E-03	1.26E-03
Manganese rates uncontrolled	2.03E-03	4.87E-02	2.78E-03	8.40E-04
Mercury	1.01E-03	2.43E-02	1.39E-03	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.70E-04	1.37E-02	7.82E-04	2.36E-04
Naphthalene	8.04E-04	NA	1.10E-03	3.33E-04
Nickel rates uncontrolled	1.01E-03	2.43E-02	1.39E-03	4.20E-04
POM rates uncontrolled	7.97E-03	NA	1.09E-02	3.30E-03
Selenium rates uncontrolled	5.07E-03	NA	6.96E-03	2.10E-03
Toluene	1.92E-01	4.62E+00	2.64E-01	7.97E-02
Xylene	3.38E-03	8.12E-02	4.64E-03	1.40E-03

Greenhouse Gases

Pollutant	lb/hr ²	tpy	lb/yr ³	Emission Factor (lb/10 ³ gal)
-----------	--------------------	-----	--------------------	---

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2014 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T32

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T32
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	3.31
Maximum fuel sulfur content (%):	0.002
Latest Construction/Modification Date:	N/A

Carbon dioxide	see attached CEMs-based calculations			22371.42
Methane	2.19E+00	1.50E-03	3.01E+00	0.907
Nitrous Oxide	4.38E-01	3.01E-04	6.01E-01	0.18

¹Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

²Hourly emission rates for all pollutants are based on hourly rated capacity.

³Annual emission rates for all pollutants are based on maximum annual fuel throughput.

⁴Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

⁵AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

⁶Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

⁷Daily emission rates are based on operation 24 hours per day at rated capacity.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Nitrogen Dioxide Emissions from Boiler #8 (ES-003-Boiler #8)

The exhaust duct at Boiler #8 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2014 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2014	0.06
February 2014	0.06
March 2014	0.06
April 2014	0.06
May 2014	0.06
June 2014	0.06
July 2014	0.04
August 2014	0.04
September 2014	0.04
October 2014	0.04
November 2014	0.05
December 2014	0.05
Annual Average	0.052

This average includes NOx emissions from fuel oil and natural gas from Boiler #8 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #8 for 2014

Boiler #8	
Gas 1,000cf/yr	Oil Gallons/yr
76,649	3,314
Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)
MMBtu/yr	
7.89E+04	4.55E+02

Total for Boiler #8 (MMBtu/yr)	7.94E+04
--------------------------------	----------

NOx Emissions from Boiler #8 (lb/yr)	4,102
NOx Emissions from Boiler #8 (ton/yr)	2.05

NOx Emissions Associated with Fuel Oil Combustion (ton/yr)	0.012
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	2.040

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

CO₂ Emissions from Boiler No.8

(ES-3)

The exhaust system on Boiler #8 is equipped with a continuous emissions monitor (CEMs) for CO₂ concentrations. The natural gas and oil flow rates to the boiler are monitored. Mass CO₂ emissions are calculated by the DAHS for GHG reporting. For the 2014 calendar year, the monthly CO₂ emissions measured by the CEM/DAHS System are as follows:

Month	Metric Tons	Tons
January 2014	246	271
February 2014	49	53
March 2014	85	94
April 2014	39	43
May 2014	72	79
June 2014	70	77
July 2014	863	951
August 2014	1,978	2,180
September 2014	257	284
October 2014	15	17
November 2014	456	503
December 2014	218	241
Annual Total	4,348	4,792

This total includes CO₂ emissions from No.2 fuel oil and natural gas from Boiler #8 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #8 for 2014

Boiler #8	
Gas 1,000cf/yr	No. 2 Oil Gallons/yr
76,649	3,314
Nat. Gas (1,030 btu/cf)	Oil (137,204 btu/gal)
MMBtu/yr	
7.89E+04	4.55E+02
Total for Boiler #7 (MMBtu/yr)	
7.94E+04	

CO ₂ Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	38.17
CO ₂ Emissions Associated with Natural Gas Combustion (ton/yr)	4,754.30

4792.5

CO₂ Emission Rate Ratios

	kg/MMBtu	Ratio
n.gas	53.06	1
No.2 oil	73.96	1.3939

7.96E+04 Dist. Factor

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**DG No.1 and No.2 - Two 2,000 kW Generators
Cogeneration Facility**

(ES-007 & ES-008)

Emission Source/Operating Scenario Data Page 1 of 2		Facility ID #: 6800043					
<i>Emergency Generators Classified as Insignificant Sources</i>		Permit #: 03069T32					
Facility Name: <u>University of North Carolina at Chapel Hill</u>		County: Orange					
		DAQ Region: Raleigh					
North Carolina Department of Environment and Natural Resources Division of Air Quality Air Pollutant Point Source Emissions Inventory - Calendar Year 2014							
1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-007 & ES-008					
2. Emission Source Description		Two Blackstart Generators located at Cogeneration Facility					
3. Operating Scenario Description		Operating Scenario #1 - No. 2 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		270 gal/hr - 2 units					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		11,551 gallons/year, Total No. 2 Fuel Oil					
6. Fuel Information (if fuel used)		% Sulfur	0.002%				
		% Ash	N/A				
		Heat Content (Btu/lb or mmCF)	137,204 Btu/gallon				
If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.							
7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)		N/A					
8. Control Device Information, if none, write "none"							
	Control Device ID # (as listed in permit)	Control Device Description					
i. (nearest stack)	None	None					
ii.	None	None					
iii.	None	None					
iv.	None	None					
9. Stack Information (sources vented to more than one stack use additional entry lines)							
Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)	
Common Stack Parameters with 2-generators and Boiler No. 8 operating concurrently							
Stk No.4	208	6	400	70	118,752	Vertical	
--	--	--	--	--	--	--	
10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	N/A	Days/Week	N/A	Weeks/Year	N/A	Hours/Year	N/A
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2007 + Dec, 2007	79.3%	Mar-May	13.9%	June-Aug	3.8%	Sept-Nov	3.0%

Two-2,000 kW No.2 oil-fired generators

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-007 & ES-008

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	0.20	8	N/A
NOx	NOx	1.51	8	N/A
PM Total	PM	0.08	8	N/A
PM-2.5	PM-2.5	0.08	8	N/A
PM-10	PM-10	0.08	8	N/A
SO2	SO2	0.00	8	N/A
VOC	VOC	0.06	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	75-07-0	0.04	8	N/A
Acrolein	107-02-8	0.01	8	N/A
Benzene	71-43-2	1.23	8	N/A
Formaldehyde	50-00-0	0.13	8	N/A
Napthalene	91-20-3	0.21	8	N/A
Propylene	115-07-1	0.34	8	N/A
Toluene	108-88-3	0.45	8	N/A
Xylene	1330-20-7	0.31	8	N/A
Greenhouse Gas Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Dioxide	CO ₂	129.20	8	N/A
Methane	CH ₄	5.24E-03	8	N/A
Nitrous Oxide	N ₂ O	1.05E-03	8	N/A

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Blackstart Generators G1 & G2

(ES-007 & ES-008)

Fuel Input Rates		
Hourly Fuel Usage (gallons):	270	(2-units)
Annual Fuel Usage (gallons):	11,551	(2-units)
Fuel Sulfur Content (%)	0.0020	
Heat Input Rates		70.00% CO control*
Fuel Heating Values (Btu/gallon)	137,204	*Cat. Oxydizer
Hourly Fuel Usage (mmBtu):	37.05	
Annual Fuel Usage (mmBtu):	1,584.82	

Emissions Output				Emission Factor
Criteria Pollutants				(lb/mmBtu)
Pollutant	lb/hr	lb/yr	tpy	
PM	3.7E+00	1.6E+02	7.92E-02	1.00E-01
PM-10	3.7E+00	1.6E+02	7.92E-02	1.00E-01
PM-2.5	3.7E+00	1.6E+02	7.92E-02	1.00E-01
NOx	7.0E+01	3.0E+03	1.51E+00	1.90E+00
NMTOC, Total	3.0E+00	1.3E+02	6.49E-02	8.19E-02
CO	9.4E+00	4.0E+02	2.02E-01	2.55E-01
SO _x	7.5E-02	3.2E+00	1.60E-03	2.02E-03
Toxic/Hazardous Air Pollutants				
Pollutant	lb/hr	lb/day	lb/yr	
Acetaldehyde	9.3E-04	2.2E-02	3.99E-02	2.52E-05
Acrolein	2.9E-04	7.0E-03	1.25E-02	7.88E-06
Arsenic	1.5E-04	3.6E-03	6.34E-03	4.00E-06
Benzene	2.9E-02	6.9E-01	1.23E+00	7.76E-04
Benzo(a)pyrene	9.5E-06	2.3E-04	4.07E-04	2.57E-07
Beryllium	1.1E-04	2.7E-03	4.75E-03	3.00E-06
Cadmium	1.1E-04	2.7E-03	4.75E-03	3.00E-06
Chromium	1.1E-04	2.7E-03	4.75E-03	3.00E-06
Formaldehyde	2.9E-03	7.0E-02	1.25E-01	7.89E-05
Lead	3.3E-04	8.0E-03	1.43E-02	9.00E-06
Manganese	2.2E-04	5.3E-03	9.51E-03	6.00E-06
Mercury	1.1E-04	2.7E-03	4.75E-03	3.00E-06
Naphthalene	4.8E-03	1.2E-01	2.06E-01	1.30E-04
Nickel	1.1E-04	2.7E-03	4.75E-03	3.00E-06
PAH	7.9E-03	1.9E-01	3.36E-01	2.12E-04
Selenium	5.6E-04	1.3E-02	2.38E-02	1.50E-05
Toluene	1.0E-02	2.5E-01	4.45E-01	2.81E-04
Xylene	7.1E-03	1.7E-01	3.06E-01	1.93E-04
Greenhouse Gas Pollutants				Em. Factor
Pollutant	lb/hr	lb/yr	tpy	(lb/mmBtu)
Carbon dioxide	6,040	258,408	129.20	163
Methane	2.5E-01	1.0E+01	5.24E-03	6.61E-03
Nitrous Oxide	4.9E-02	2.1E+00	1.05E-03	1.32E-03

Most emission factors are from DAQ spreadsheet for Large Stationary Diesel Engines >600 Hp. Greenhouse gas emission factors are from the Greenhouse Gas Reporting regulations.

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Three Enclosed Railcar Dump Pits
(ES-010)**

Emission Source/Operating Scenario Data Page 1 of 2	Facility ID #: 6800043
Railcar Dump Pits	Permit #: 03069T32
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	County: Orange
Facility Name: University of North Carolina at Chapel Hill	DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)	ES-010						
2. Emission Source Description	Three Enclosed Railcar Dump Pits						
3. Operating Scenario Description	N/A						
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>	350 tons/hr						
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>	82,817 tons/yr						
6. Fuel Information (if fuel used)	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;">% Sulfur</td> <td style="width:15%; text-align:center;">N/A</td> <td style="width:15%;">% Ash</td> <td style="width:15%; text-align:center;">N/A</td> <td style="width:30%;">Heat Content (Btu/lb or mmCF)</td> <td style="width:10%; text-align:center;">N/A</td> </tr> </table>	% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A
% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A		

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A	
8. Control Device Information, if none, write "none"		
	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
i. (nearest stack)	N/A	Enclosed Dump Pits
ii.	CD-018	Wet Spray Dust Suppression System
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)						
Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) <small>(in 0.1 feet)</small></small>	Temperature <small>(F)</small>	Velocity <small>(feet/sec)</small>	Volume Flow Rate <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
Fugitive						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	1.5	Days/Week	5	Weeks/Year	52	Hours/Year	390
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%

Railcar Dump Pits

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-010

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	5.47E-03	2	67%
PM-2.5	PM-2.5	8.13E-04	2	40%
PM-10	PM-10	2.59E-03	2	63%
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Fugitive Losses from the unloading of coal from railcars into a dump pit.

(ES-010)

Boiler #6	-	Tons/yr
Boiler #7	-	Tons/yr
Total	82,817	Tons/yr

From section 13.2.4 of the AP-42, coal handling is well approximated by aggregate handling operations. The following equation represents the particulate emissions generated by the dropping of coal into the dump pit.

$$E = k (0.0032) \frac{(u/5)^{1.3}}{(m/2)^{1.4}}$$

E = Emission Factor (lb/ton)

k = Particle Size Multiplier

u = Mean Wind Speed (mph)

m = Material Moisture Content (%)

k Value	Particulate Size	Emission Factor (lb/ton)
0.74	PM	1.32E-04
0.35	PM-10	6.25E-05
0.11	PM-2.5	1.96E-05

Average moisture content of coal is 4.5%

The dump area is fully enclosed, therefore the minimum wind speed of 1.3 mph was used.

Total Coal 82,817 tons/yr

Emissions from the unloading of coal:

	Emission Factor (lb/ton)	Emissions (lb/yr)	Emissions (ton/yr)
PM	1.32E-04	10.94	5.47E-03
PM-10	6.25E-05	5.17	2.59E-03
PM-2.5	1.96E-05	1.63	8.13E-04

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Coal Silos
(ES-1, ES-2)**

Emission Source/Operating Scenario Data Page 1 of 2		Facility ID #: <u>6800043</u>
Coal Silos <small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>		Permit #: <u>03069T32</u>
Facility Name: <u>University of North Carolina at Chapel Hill</u>		County: <u>Orange</u>
		DAQ Region: <u>Raleigh</u>

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (<i>same as in permit</i> - Use "U" prefix for non-permitted and "I" for insignificant)		ES-1 and ES-2					
2. Emission Source Description		Two Coal Storage Silos					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		350 tons/hr					
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>			82,817			tons/yr	
6. Fuel Information (<i>if fuel used</i>)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (<i>% Emissions from Emission Source Vented to Control Device or Stack</i>)	100%
--	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
<i>i. (nearest stack)</i>	CD-011	Bagfilter Installed on Silo ES-1
<i>ii.</i>	CD-012	Bagfilter Installed on Silo ES-2
<i>iii.</i>	N/A	N/A
<i>iv.</i>	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature <small>(F)</small>	Velocity <small>(feet/sec)</small>	Volume Flow Rate <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
EP-12-028	140	0.9	Ambient	61	2,500	Horizontal
EP-12-036	140	0.9	Ambient	61	2,500	Horizontal
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	1.5	Days/Week	5	Weeks/Year	52	Hours/Year	390
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, **MUST** total 100%)

Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------

Coal Silos

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant) ES-1 and ES-2

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	3.78E-03	2	99.80%
PM-2.5	PM-2.5	3.59E-03	2	97.90%
PM-10	PM-10	3.78E-03	2	99.60%
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A

HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Emissions from the loading of 2 coal storage silos.

(ES-1, ES-2)

Boiler #6	-	Tons/yr
Boiler #7	-	Tons/yr
Total	82,817	Tons/yr

The bulk density of coal is 47 lb/ft³

Total volume of coal transferred is = 3,524,128 ft³/yr
(Volume of coal transferred = volume of displaced air through bin filter)

These emissions are routed through bin filters (baghouses). Emissions from the bin filters are conservatively estimated at 0.015 gr/acfm (displaced air through bin filters).

$$\text{lb/yr} = (\text{volume of coal, ft}^3/\text{yr}) (0.015 \text{ gr/acf}) (1/7000 \text{ lb/gr})$$

Total Emissions from the silos	52,862	gr/yr
	7.552	lb/yr
	0.0038	ton/yr

100% of these emissions are PM-10

95% of these emissions are PM-2.5

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Silo Feed Conveyors
(ES-3)**

Emission Source/Operating Scenario Data Page 1 of 2		Facility ID #: 6800043					
<i>Silo Feed Conveyors</i>		Permit #: 03069T32					
<small>If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)</small>		County: Orange					
Facility Name: University of North Carolina at Chapel Hill		DAQ Region: Raleigh					
North Carolina Department of Environment and Natural Resources Division of Air Quality Air Pollutant Point Source Emissions Inventory - Calendar Year 2014							
1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-3					
2. Emission Source Description		Silo Feed Conveyors					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate <small>With Units (Ex. gal/hr, mmBtu/hr)</small>		700 tons/hr					
5. Throughput in CY (e.g. production or fuel use) <small>With Units (Ex. lbs/yr, gal/yr)</small>		82,817 tons/yr					
6. Fuel Information (if fuel used)		% Sulfur	N/A				
		% Ash	N/A				
		Heat Content (Btu/lb or mmCF)	N/A				
If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.							
7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)		100%					
8. Control Device Information , if none, write "none"							
	Control Device ID # <small>(as listed in permit)</small>	Control Device Description					
i. (nearest stack)	CD-019	Bagfilter					
ii.	N/A	N/A					
iii.	N/A	N/A					
iv.	N/A	N/A					
9. Stack Information (sources vented to more than one stack use additional entry lines)							
Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (center #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature <small>(F)</small>	Velocity <small>(feet/sec)</small>	Volume Flow Rate <small>(acfm)</small>	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>	
EP-12-6901	200	2	Ambient	45	8,500	Vertical	
--	--	--	--	--	--	--	
--	--	--	--	--	--	--	
10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)							
Hours/Day	N/A	Days/Week	N/A	Weeks/Year	N/A	Hours/Year	N/A
Typical Start & End Times in CY:				Start:	N/A	End:	N/A
11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)							
Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Emissions from silo feed conveyors.

(ES-3)

Boiler #6	-	Tons/yr
Boiler #7	-	Tons/yr
Total	82,817	Tons/yr

The bulk density of coal is 47 lb/ft³

Total volume of coal transferred is = 3,524,128 ft³/yr
(Volume of coal transferred = volume of displaced air through bin filter)

These emissions are routed through bin filters (baghouses). Emissions from the bin filters are conservatively estimated at 0.015 gr/acfm (displaced air through bin filters).

$$\text{lb/yr} = (\text{volume of coal, ft}^3/\text{yr}) (0.015 \text{ gr/acf}) (1/7000 \text{ lb/gr})$$

Total Emissions from the conveyors	52,862	gr/yr
	7.552	lb/yr
	0.0038	ton/yr

100% of these emissions are PM-10

95% of these emissions are PM-2.5

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Fuel Oil Storage Tanks

(T-001 and T-002)

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Summary of Emissions from Tanks T-001 & T-002

(ES-T-001 and ES-T-002)

VOC Emissions calculated with EPA TANKS 4.0 Program

T-001	216.52	lb/yr	0.108	Tons/yr
T-002	216.52	lb/yr	0.108	Tons/yr
Total	433.04	lb/yr	0.217	Tons/yr

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Coal Crusher/Conveyor Building
(ES-010A)**

Emission Source/Operating Scenario Data Page 1 of 2	Facility ID #: 6800043
Coal Crusher/Conveyor Building	Permit #: 03069T32
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	County: Orange
Facility Name: University of North Carolina at Chapel Hill	DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-010A
2. Emission Source Description	Coal Crusher / Conveyor Building	
3. Operating Scenario Description	N/A	
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)	60 tons/hr	
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)	87,434	tons/yr
6. Fuel Information (if fuel used)	% Sulfur	N/A
	% Ash	N/A
	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
---	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # <small>(as listed in permit)</small>	Control Device Description
<i>i. (nearest stack)</i>	CD-013	Bagfilter
<i>ii.</i>	N/A	N/A
<i>iii.</i>	N/A	N/A
<i>iv.</i>	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height <small>(in whole feet)</small>	Diameter (feet) <small>Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)</small>	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description <small>(Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)</small>
EP-12-053	47	1.8	Ambient	44	6,500	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	6	Days/Week	7	Weeks/Year	52	Hours/Year	1,457
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------

Emission Source/Operating Scenario Data Page 2 of 2		Facility ID #: 6800043		
<i>Coal Crusher/Conveyor Building</i>		Permit #: 03069T32		
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)		County: Orange		
Facility Name: <u>University of North Carolina at Chapel Hill</u>		DAQ Region: Raleigh		
North Carolina Department of Environment and Natural Resources Division of Air Quality Air Pollutant Point Source Emissions Inventory - Calendar Year 2014				
<u>Emissions:</u> Attach calculations and documentation of emission factors or other estimation methods used.				
Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-010A		
Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	0.62	2	99.80%
PM-2.5	PM-2.5	0.59	2	97.90%
PM-10	PM-10	0.62	2	99.60%
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

Emissions and data on this form required to report or verify emissions cannot be held confidential.
 To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>
 Copy and Use additional Sheets as needed.

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Emissions from the Conveyor/Crusher Building

(ES-010A)

Assume that the total amount of coal conveyed to the crusher is equal to the total amount of coal combusted in 2014.

Boiler #6	41,704	Tons/yr
Boiler #7	45,730	Tons/yr
Total	87,434	Tons/yr

The conveyor transfer points and crushers in the Coal Crusher Building are controlled by a vacuum dust pick-up system ducted to a baghouse. The air flow rate through the baghouse is 6,650 acfm. Emissions from the baghouse are conservatively estimated at 0.015 gr/acfm.

60 ton/hr, conveying rate
1,457.2 hrs/yr, conveying time

$\text{lb/yr} = (6,650 \text{ acfm}) (60 \text{ min/hr}) (\text{hr/yr}) (0.015 \text{ gr/acfm}) (1/7000 \text{ lb/gr})$

Total Emissions from the Crusher	8,721,546	gr/yr
	1,246	lb/yr
	0.62	ton/yr

100% of these emissions are PM-10

95% of these emissions are PM-2.5

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Ash Silo with Loadout
(ES-030)**

Ash Silo with Loadout

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: **6800043**Permit #: **03069T32**County: **Orange**DAQ Region: **Raleigh**Facility Name: **University of North Carolina at Chapel Hill**

**North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014**

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-030					
2. Emission Source Description		Ash Silo with Loadout					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		16 tons/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		23,868			tons/yr		
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	-------------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-031	Bagfilter
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
Fugitive						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	10	Days/Week	7	Weeks/Year	52	Hours/Year	4,460
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%
------------------------------	---------------	---------	---------------	----------	---------------	----------	---------------

Ash Silo with Loadout

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-030

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	1.60	2	99.80%
PM-2.5	PM-2.5	1.52	2	97.90%
PM-10	PM-10	1.60	2	99.60%
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Ash Silo with Loadout

(ES-030)

Ash is conveyed to the silo and loaded into trucks for off-site transport. The ash is pneumatically conveyed to the silo with the conveying air filtered through a baghouse (CD-031) prior to discharge. The ash loadout to the transfer trucks is via a pipe within a pipe configuration. The annular space between the internal and external pipes is under a vacuum. This vacuum system collects the dust generated during truck loading and ducts it to the baghouse (CD-031). Ash is composed of coal flyash and CaCO_3 / CaSO_3 from desulfurization. Ash is similar to flyash used in concrete batching operations.

23,868 ton/yr, ash loaded in 2013

1. Uncaptured Truck Loading Fugitives

Truck loading operations are in an enclosure with discharge into an enclosed truck bed. The vacuum at the ash discharge point and enclosures should insure a minimum of 95% capture. Uncontrolled emissions are based on a conservatively high estimated 0.5 lb/ton emission factor (0.02 lb/ton AP-42 for batch truck loading at concrete plants).

23,868	ton/yr, Ash Generated
0.5	lb/ton, Emission Factor
95%	Capture Efficiency
596.7	lb/yr, Emissions
0.30	ton/yr, Emissions

Fugitives from the Enclosure:

0.016	ton/yr, Emissions
-------	-------------------

2. Baghouse Emissions

The air flow rate through the baghouse is 4,490 acfm. Emissions from the baghouse are conservatively estimated at 0.015 gr/acfm.

$$\text{lb/yr} = (4,490 \text{ acfm}) (60 \text{ min/hr}) (\text{hr/yr}) (0.015 \text{ gr/acfm}) (1/7000 \text{ lb/gr})$$

4,490	acfm, Baghouse Flow Rate
4,460	hrs/yr, Operating Hours
0.015	gr/acfm, Emission Factor from Baghouse
2,575	lb/yr, Emissions
1.29	ton/yr, Emissions

3. Total Emissions

0.30	ton/yr, Emissions Truck Loading
0.016	ton/yr, Emissions, Truck Fugitives
1.29	ton/yr, Emissions, Baghouse
1.60	ton/yr, Total Emissions PM
1.60	ton/yr, Total Emissions PM-10
1.52	ton/yr, Total Emissions PM-2.5

100% as PM-10

95% as PM-2.5

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

**Wet Ash Loadout
(ES-030A)**

(This unit was not in operation during CY 2014)

Wet Ash Loadout

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 03069T32

County: Orange

DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-030A					
2. Emission Source Description		Wet Ash Loadout					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		N/A					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		0		ton/yr			
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	None	None
ii.	None	None
iii.	None	None
iv.	None	None

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
N/A	N/A	N/A	N/A	N/A	N/A	N/A
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	N/A	Days/Week	N/A	Weeks/Year	N/A	Hours/Year	N/A
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	0%	Mar-May	0%	June-Aug	0%	Sept-Nov	0%
------------------------------	----	---------	----	----------	----	----------	----

This Unit Was Not in Operation During CY 2008.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

The University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Enclosed Sorbent Railcar Dump Pit (Insignificant Source)

IS-53

13,949 tons of sorbent delivered by rail in 2014. There are no emission sources associated with truck delivery.

Emission Source/Operating Scenario Data Page 1 of 2	Facility ID #: 6800043
Enclosed Sorbent Railcar Dump Pit	Permit #: 03069T32
If Emission Source has multiple Operating Scenarios, complete one form for each. (All permitted, Insignificant and/or Non-permitted Sources)	County: Orange
Facility Name: University of North Carolina at Chapel Hill	DAQ Region: Raleigh

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		"I" Insignificant - ID No. 020					
2. Emission Source Description		Enclosed Sorbent Railcar Dump Pit					
3. Operating Scenario Description		N/A					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		50 ton/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		13,949				tons/yr	
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)	N/A

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
---	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	None	None
ii.	None	None
iii.	None	None
iv.	None	None

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
Fugitive						
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	1	Days/Week	3	Weeks/Year	52	Hours/Year	156
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	38.92%	Mar-May	25.70%	June-Aug	19.88%	Sept-Nov	15.50%
------------------------------	--------	---------	--------	----------	--------	----------	--------

Enclosed Sorbent Railcar Dump Pit

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, Insignificant and/or Non-permitted Sources)

Facility ID #: 6800043
Permit #: 03069T32
County: Orange
DAQ Region: Raleigh

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2014

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

"I" Insignificant - ID No. 020

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	1.25E-02	2	N/A
PM-2.5	PM-2.5	1.85E-03	2	N/A
PM-10	PM-10	5.90E-03	2	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T32

2014 Annual Emissions Inventory

Enclosed Sorbent (Lime) Railcar Dump Pit

(Insignificant Source - ID No. 020)

Sorbent is transported from the railcar dump pit in enclosed conveyors to the storage area. Emissions can be best estimated using the drop equation.

From section 13.2.4 of the AP-42: The following equation represents the particulate emissions generated by the dropping of sorbent into the dump pit.

$$E = k (0.0032) \frac{(u/5)^{1.3}}{(m/2)^{1.4}}$$

E = Emission Factor (lb/ton)

k = Particle Size Multiplier

u = Mean Wind Speed (mph)

m = Material Moisture Content (%)

k Value	Particulate Size	Emission Factor (lb/ton)
0.74	PM	1.787E-03
0.35	PM-10	8.45E-04
0.11	PM-2.5	2.66E-04

Average moisture content of sorbent is 0.7%

The dump area is fully enclosed, therefore the minimum wind speed of 1.3 mph was used.

Total Sorbent 13,949 tons/yr

Emissions from the unloading of sorbent into the dump pit:

	Emission Factor (lb/ton)	Emissions (lb/yr)	Emissions (ton/yr)
PM	1.79E-03	24.93	1.25E-02
PM-10	8.45E-04	11.79	5.90E-03
PM-2.5	2.66E-04	3.71	1.85E-03